

Chapter E 310

CONDUCTORS FOR GENERAL WIRING

E 310.01	General		
E 310.02	Application and construction		
E 310.03	Insulating materials		
E 310.04	Temperature limitations		
E 310.05	Wet locations		
E 310.06	Buried conductors		
E 310.07	Corrosive conditions		
E 310.08	Minimum size of conductors		
E 310.09	Stranded conductors		
E 310.10	Conductors in multiple		
E 310.11	Current-carrying capacity		
E 310.12	Table—allowable current-carrying capacities		
		E 310.13	Table—allowable current-carrying capacities of insulated copper conductors in amperes
		E 310.14	Table—allowable current-carrying capacities of insulated aluminum conductors in amperes
		E 310.15	Table—allowable current-carrying capacities of insulated aluminum conductors in amperes

E 310.01 General. (1) The purpose of this chapter is to assure that conductors have mechanical strength, insulation, and current carrying capacity adequate for the particular conditions under which they are to be used.

(2) Conductors shall be insulated, except when covered or bare conductors are specifically permitted in this code.

(3) The provisions of this chapter are not intended to apply to conductors which form an integral part of equipment such as motors, motor controllers, and the like, or which are provided for elsewhere in this code.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.02 Application and construction. (1) **CONDUCTOR APPLICATION.** Conductor insulations as specified in the following table E 310.02 (1) may be installed for any of the wiring methods recognized herein, except as otherwise provided for in the table or in section E 310.03, or as otherwise specified in this code. They are suitable for 600 volts unless otherwise specified.

(2) **CONDUCTOR CONSTRUCTION.** Insulated conductors for use at 600 volts or less shall conform to the provisions of table E 310.02 (2).

TABLE E 310.02 (1)
CONDUCTOR APPLICATION

Trade Name	Type Letter	Max. Operating Temp.	Application Provisions
Rubber-Covered Fixture Wire	*RF-1	60°C 140°F	Fixture wiring, Limited to 300 V.
Solid or 7-Strand	*RF-2	60°C 140°F	Fixture wiring, and as permitted in E 310.03.
Rubber-Covered Fixture Wire	*FF-1	60°C 140°F	Fixture wiring, Limited to 300 V.
Flexible Stranding	*FF-2	60°C 140°F	Fixture wiring, and as permitted in E 310.03.

*Fixture wires are not intended for installation as branch circuit conductors nor for the connection of portable or stationary appliances.

TABLE E 310.02 (1)—Continued

Trade Name	Type Letter	Max. Operating Temp.	Application Provisions
Heat-Resistant Rubber-Covered Fixture Wire	*RFH-1	75°C 167°F	Fixture wiring. Limited to 300 V.
Solid or 7-Strand	*RFH-2	75°C 167°F	Fixture wiring, and as permitted in E 310.08.
Heat-Resistant Rubber-Covered Fixture Wire	*FFH-1	75°C 167°F	Fixture wiring. Limited to 300 V.
Flexible Stranding	*FFH-2	75°C 167°F	Fixture wiring, and as permitted in E 310.08.
Thermoplastic-Covered Fixture Wire—Solid or Stranded	*TF	60°C 140°F	Fixture wiring, and as permitted in E 310.08.
Thermoplastic-Covered Fixture Wire—Flexible Stranding	*TFF	60°C 140°F	Fixture wiring.
Cotton-Covered, Heat-Resistant, Fixture Wire	*CF	90°C 194°F	Fixture wiring. Limited to 300 V.
Asbestos-Covered Heat-Resistant, Fixture Wire	*AF	150°C 302°F	Fixture wiring. Limited to 300 V. and Indoor Dry Location.
Silicone Rubber Insulated Fixture Wire	*SF-1	200°C 392°F	Fixture wiring. Limited to 300 V.
Solid or 7-Strand	*SF-2	200°C 392°F	Fixture wiring, and as permitted in E 310.08.
Silicone Rubber Insulated Fixture Wire	*SFF-1	150°C 302°F	Fixture wiring. Limited to 300 V.
Flexible Stranding	*SFF-2	150°C 302°F	Fixture wiring, and as permitted in E 310.08.
Code Rubber	R	60°C 140°F	Dry Locations.
Heat-Resistant Rubber	RH	75°C 167°F	Dry Locations.
Heat-Resistant Rubber	RHH	90°C 194°F	Dry Locations.
Moisture-Resistant Rubber	RW	60°C 140°F	Dry and wet locations. For over 2000 volts, insulation shall be ozone-resistant.
Moisture and Heat-Resistant Rubber	RH-RW	60°C 140°F 75°C 167°F	Dry and wet locations. For over 2000 volts, insulation shall be ozone-resistant. Dry locations. For over 2000 volts, insulation shall be ozone-resistant.
Moisture and Heat-Resistant Rubber	RHW	75°C 167°F	Dry and wet locations. For over 2000 volts, insulation shall be ozone-resistant.
Latex Rubber	RU	60°C 140°F	Dry locations.
Heat-Resistant Latex Rubber	RUH	75°C	Dry locations.
Moisture-Resistant Latex Rubber	RUW	60°C 140°F	Dry and wet locations.
Thermoplastic	T	60°C 140°F	Dry locations.
Moisture-Resistant Thermoplastic	TW	60°C 140°F	Dry and wet locations.

*Fixture wires are not intended for installation as branch circuit conductors nor for the connection of portable or stationary appliances.

TABLE E 310.02 (1)—Continued

Trade Name	Type Letter	Max. Operating Temp.	Application Provisions
Moisture and Heat-Resistant Thermoplastic	THW	75°C 167°F	Dry and wet locations.
Mineral Insulation (Metal Sheathed)	MI	85°C 185°F	Dry and wet locations with Type O termination fittings. Max. operating temperature for special applications 250°C.
Thermoplastic and Asbestos	TA	90°C 194°F	Switchboard wiring only.
Silicone-Asbestos	SA	90°C 194°F	Dry locations—max. operating temperature for special application 125°C.
Thermoplastic and Fibrous Outer Braid	TBS	90°C 194°F	Switchboard wiring only.
Varnished Cambric	V	85°C 185°F	Dry locations only. Smaller than No. 6 by special permission.
Asbestos and Varnished Cambric	AVA	110°C 230°F	Dry locations only.
Asbestos and Varnished Cambric	AVL	110°C 230°F	Dry and wet locations.
Asbestos and Varnished Cambric	AVB	90°C 194°F	Dry locations only.
Asbestos	A	200°C 392°F	Dry locations only. In raceways, only for leads to or within apparatus. Limited to 300 V.
Asbestos	AA	200°C 392°F	Dry locations only. Open wiring. In raceways, only for leads to or within apparatus. Limited to 300 V.
Asbestos	AI	125°C 257°F	Dry locations only. In raceways, only for leads to or within apparatus. Limited to 300 V.
Asbestos	AIA	125°C 257°F	Dry locations only. Open wiring. In raceways, only for leads to or within apparatus.
Paper		85°C 185°F	For underground service conductors, or by special permission.
Slow-Burning	SB	90°C 194°F	Dry locations only. Open wiring; and in raceways where temperatures will exceed those permitted for rubber-covered or varnished cambric-covered conductors.

TABLE E 310.02 (2)
CONDUCTOR INSULATIONS

Trade Name	Type Letter	Insulation	Thickness of Insulation	Outer Covering
Heat-Resistant Latex Rubber	RUH	90% Unmilled, Grainless Rubber	14-10 18 Mils 8-2 25 Mils	Moisture-resistant, flame-retardant, non-metallic covering
Thermoplastic	T	Flame Retardant, Thermoplastic Compound	14-10 2/64 Inch 8 3/64 Inch 6-2 4/64 Inch 1-4/0 5/64 Inch 213-500 6/64 Inch 501-1000 7/64 Inch 1001-2000 8/64 Inch	None
Moisture-Resistant Thermoplastic	TW	Flame-Retardant, Moisture-Resistant Thermoplastic	14-10 2/64 Inch 8 3/64 Inch 6-2 4/64 Inch 1-4/0 5/64 Inch 213-500 6/64 Inch 501-1000 7/64 Inch 1001-2000 8/64 Inch	None
Moisture and Heat-Resistant Thermoplastic	THW	Flame-Retardant, Moisture and Heat-Resistant Thermoplastic	14-10 3/64 Inch 8-2 4/64 Inch 1-4/0 5/64 Inch 213-500 6/64 Inch	None
Thermoplastic and Asbestos	TA	Thermoplastic and Asbestos	14-8 Th'pl' 20 Mils Asb. 20 Mils 6-2 30 Mils 25 Mils 1-4/0 40 Mils 30 Mils	Flame-retardant, cotton braid
Silicone-Asbestos	SA	Silicone Rubber	14-10 3/64 Inch 8-2 4/64 Inch 1-4/0 5/64 Inch 213-500 6/64 Inch 501-1000 7/64 Inch 1001-2000 8/64 Inch	Asbestos or glass
Thermoplastic and Fibrous Braid	TBS	Thermoplastic	14-10 2/64 Inch 8 3/64 Inch 6-2 4/64 Inch 1-4/0 5/64 Inch	Flame-retardant, non-metallic covering

TABLE E 310.02 (2)—Continued

Trade Name	Type Letter	Insulation	Thickness of Insulation	Outer Covering
Mineral-Insulated Metal-Sheathed	MI	Magnesium Oxide	16-4 50 Mils 3-4/0 55 Mils	Copper
Varnished Cambric	V	Varnished Cambric	14-8 3/64 Inch 6-2 4/64 Inch 1-4/0 5/64 Inch 213-500 6/64 Inch 501-1000 7/64 Inch 1001-2000 8/64 Inch (Dimen. in Mils) VC AVA AVL Asb. Asb. Asb. 14-8 (solid only)---- 30 20 25	Non-metallic covering or lead sheath
Asbestos and Varnished Cambric	AVA and AVL	Impregnated Asbestos and Varnished Cambric	AVA AVL 1st 2nd 2nd Asb. VC Asb. Asb. 14-8 10 30 15 25 6-2 15 30 20 25 1-4/0 20 30 30 30 213-500 25 40 40 40 501-1000 30 40 40 40 1001-2000 30 50 50 50	AVA-asbestos braid or glass AVL-lead sheath
Asbestos and Varnished Cambric	AVB	Impregnated Asbestos and Varnished Cambric	VC Asb. 18-8 30 20 6-2 40 30 1-4/0 40 40 Asb. VC 2nd Asb. Asb. 14-8 10 30 15 6-2 15 30 20 1-4/0 20 30 30 213-500 25 40 40 501-1000 30 40 40 1001-2000 30 50 50	Flame-retardant, cotton braid (switchboard wiring) Flame-retardant, cotton braid

Electrical Code, Volume 2
 Register, November, 1961, No. 71

WISCONSIN ADMINISTRATIVE CODE

151

TABLE E 310.02 (2)—Continued

Trade Name	Type Letter	Insulation	Thickness of Insulation	Outer Covering
Asbestos	A	Asbestos	14 30 Mils 12-8 40 Mils	Without asbestos braid
Asbestos	AA	Asbestos	14 30 Mils 12-8 30 Mils 6-2 40 Mils 1-4/0 60 Mils	With asbestos braid or glass
Code	R	Code Rubber	14-12 2/64 Inch 10 3/64 Inch 8-2 4/64 Inch 1-4/0 5/64 Inch 213-500 6/64 Inch 501-1000 7/64 Inch 1001-2000 8/64 Inch	Moisture-resistant, flame-retardant, non-metallic covering
Heat-Resistant	RH RHH	Heat-Resistant Rubber	*14-12 2/64 Inch 10 3/64 Inch 8-2 4/64 Inch 1-4/0 5/64 Inch 213-500 6/64 Inch 501-1000 7/64 Inch 1001-2000 8/64 Inch	Moisture-resistant, flame-retardant, non-metallic covering
Moisture-Resistant	RW	Moisture-Resistant Rubber	14-10 3/64 Inch 8-2 4/64 Inch 1-4/0 5/64 Inch 213-500 6/64 Inch 501-1000 7/64 Inch 1001-2000 8/64 Inch	Moisture-resistant, flame-retardant, non-metallic covering
Moisture and Heat-Resistant	RH-RW	Moisture and Heat Resistant Rubber	14-10 3/64 Inch 8-2 4/64 Inch 1-4/0 5/64 Inch 213-500 6/64 Inch 501-1000 7/64 Inch 1001-2000 8/64 Inch	Moisture-resistant, flame-retardant, non-metallic covering

*For 14-12 sizes RHH shall be 3/64 inch thickness insulation.

TABLE E 310.02 (2)—Continued

Trade Name	Type Letter	Insulation	Thickness of Insulation	Outer Covering																					
Moisture and Heat-Resistant	RHW	Moisture and Heat Resistant Rubber	14-10.....3/64 Inch 8-2.....4/64 Inch 1-4/0.....5/64 Inch 213-500.....6/64 Inch 501-1000.....7/64 Inch 1001-2000.....8/64 Inch	Moisture-resistant, flame-retardant, non-metallic covering																					
Latex Rubber	RU	90% Unmilled, Grainless Rubber	14-10.....18 Mils 8-2.....25 Mils	Moisture-resistant, flame-retardant, non-metallic covering																					
	RUW	90% Unmilled, Grainless Rubber	14-10.....18 Mils 8-2.....25 Mils	Moisture-resistant, flame-retardant, non-metallic covering																					
Asbestos	AI	Impregnated Asbestos	14.....30 Mils 12-8.....40 Mils	Without asbestos braid																					
Asbestos	AIA	Impregnated Asbestos	<table style="margin-left: auto; margin-right: auto;"> <tr> <td></td> <td>Sol.</td> <td>Str.</td> </tr> <tr> <td>14.....</td> <td>30 Mils</td> <td>30 Mils</td> </tr> <tr> <td>12-8.....</td> <td>30 Mils</td> <td>40 Mils</td> </tr> <tr> <td>6-2.....</td> <td>40 Mils</td> <td>60 Mils</td> </tr> <tr> <td>1-4/0.....</td> <td>60 Mils</td> <td>75 Mils</td> </tr> <tr> <td>213-500.....</td> <td></td> <td>90 Mils</td> </tr> <tr> <td>501-1000.....</td> <td></td> <td>105 Mils</td> </tr> </table>		Sol.	Str.	14.....	30 Mils	30 Mils	12-8.....	30 Mils	40 Mils	6-2.....	40 Mils	60 Mils	1-4/0.....	60 Mils	75 Mils	213-500.....		90 Mils	501-1000.....		105 Mils	With asbestos braid or glass
	Sol.	Str.																							
14.....	30 Mils	30 Mils																							
12-8.....	30 Mils	40 Mils																							
6-2.....	40 Mils	60 Mils																							
1-4/0.....	60 Mils	75 Mils																							
213-500.....		90 Mils																							
501-1000.....		105 Mils																							
Paper		Paper		Lead sheath																					
Slow Burning	SB	3 Braids Impregnated Fire Retardant, Cotton Thread	14-10.....3/64 Inch 8-2.....4/64 Inch 1-4/0.....5/64 Inch 213-500.....6/64 Inch 501-1000.....7/64 Inch 1001-2000.....8/64 Inch	Outer cover finished smooth and hard																					

Note: The fibrous covering over individual rubber-covered conductors of lead-sheathed or multiple-conductor cable is not required to be flame retardant. For armored cable, see section E 334.02. For non-metallic-sheathed cable, see section E 336.02. For type UF cable, see section E 339.01.

(3) **MARKING.** Insulated wires, cables and cords of all kinds except paper-insulated wire shall have a continuous distinctive marking so that their maker may be readily identified. All wires, cables and cords shall also be plainly tagged or marked as follows:

(a) The maximum working voltage for which the wire was tested or approved. This may be omitted for slow-burning and asbestos-covered switchboard wires.

(b) The words "National Electrical Code Standard", or "NEC Std."

(c) Name of the manufacturing company and, if desired, trade name of the wire.

(d) Month and year when manufactured. This may be omitted for slow-burning wires.

(e) The proper type letter for the particular style of wire or cable as given in the following sections.

(4) **CLASSIFICATION.** In addition to the type letters specified in table E 310.02 (2), the following letters shall apply:

(a) A type letter or letters used alone indicates a single insulated conductor.

(b) The letter "D" used as a suffix indicates a twin wire with 2 insulated conductors laid parallel under an outer fibrous covering.

(c) The letter "M" used as a suffix indicates an assembly of 2 or more insulated conductors twisted together under an outer fibrous covering.

(d) The letter "L" used as a suffix indicates an outer covering of lead.

(e) *Voltage.* Type letters, when used alone, indicate conductors for use at not more than 600 volts. Conductors for use at higher voltages shall be indicated by adding numerical suffixes to the type letters as follows:

- 10—for use at not more than 1000 volts.
- 20—for use at not more than 2000 volts.
- 30—for use at not more than 3000 volts.
- 40—for use at not more than 4000 volts.
- 50—for use at not more than 5000 volts.

Note: The working voltages referred to in the table are the operating voltages between phases of single and 2-phase systems, and 3-phase systems with grounded or ungrounded neutral.

(f) All NEC standard conductors shall be examined and tested at the factory and, if approved, shall be labeled before shipment.

(5) **IDENTIFICATION OF INSULATION.** All rubber-insulated conductors and all thermoplastic-insulated conductors, No. 14 and larger, shall have a readily recognizable durable marking to indicate the grade of insulation; except that single-conductor, code-rubber insulated conductors having a lead sheath; and multi-conductor cables, armored cable, and non-metallic-sheathed cable having code-rubber or non-moisture-resistant thermoplastic-insulated conductors, need not be so marked.

(6) **IDENTIFIED CONDUCTORS.** Single insulated conductors of No. 6 or smaller, intended for use as identified conductors of circuits, except

(a) for fixture wires as outlined below, and (b) for mineral insulated-metal sheathed cable, shall have an outer identification of a white or natural gray color. Twin and twisted-pair conductors and 3-conductor cables shall have one conductor, and 4-conductor cables shall have at

least one conductor identified in this manner. (c) For fixture wires the identification shall be as above, or by means of 1. ridges, or 2. grooves, or 3. stripes colored white or natural gray so located on the exterior of the wires as to identify it.

Note: Wires having their outer covering finished to show a white or natural gray color but having colored tracer threads in the braid, identifying the source of manufacture, are considered as meeting the provisions herein.

(7) Single conductors, intended for use as unidentified conductors, and conductors other than the identified conductor in multi-conductor cables, shall be finished to show a color or combination of colors other than, and contrasting with, white or natural gray. The colors contrasting with white or natural gray, may be provided by means of an approved stripe or stripes on black conductors. For identification requirements for conductors larger than No. 6 see subsection E 200.06 (2).

(8) INSULATION THICKNESS; OVER 600 VOLTS. The thickness of insulation for conductors for use at over 600 volts shall conform to tables E 310.02 (8) (a) through E 310.02 (8) (d):

TABLE E 310.02 (8) (a)

THICKNESS OF RUBBER INSULATION FOR RUBBER-COVERED WIRE AND CABLE, IN 64THS OF AN INCH

Conductor Size AWG or MCM	Classification				
	R 10	R 20	RW 30**	RW 40**	RW 50**
	RH 10 RHW 10	RH 20 RHW 20	RH-RW 30** RHW 30**	RH-RW 40** RHW 40**	RH-RW 50** RHW 50**
14-12-----	4	5			
10- 8*-----	4	5	7	9	10*
6-2-----	5	6	8	9	10
1-4/0-----	6	7	8	9	10
213-500-----	7	8	9	10	11
501-1000-----	8	9	9	10	11
1001-2000-----	9	9	10	11	12

*No. 8 AWG is the minimum conductor size for 5000 volts operation.

**Shall be of approved ozone-resistant type for operation at voltages over 2000.

TABLE E 310.02 (8) (b)

THICKNESS OF VARNISHED-CAMBRIC INSULATION FOR SINGLE-CONDUCTOR CABLE, IN 64THS OF AN INCH

Conductor Size AWG or MCM	For Voltages Not Exceeding				
	1000	2000	3000	4000	5000
14-----	4				
12-----	4	5			
10-----	4	5	6		
8-2-----	4	5	6	7	9
1-4/0-----	5	6	6	7	9
213-500-----	6	6	7	8	10
501-1000-----	7	7	7	8	10
1001-2000-----	8	8	8	9	10

TABLE E 310.02 (8) (e)
THICKNESS OF VARNISHED-CAMBRIC INSULATION FOR
MULTIPLE-CONDUCTOR CABLE, IN 64THS OF AN INCH

Conductor Size AWG or MCM	For Voltages Not Exceeding									
	1000		2000		3000		4000		5000	
	C	B	C	B	C	B	C	B	C	B
14.....	4	0								
12.....	4	0	5	0						
10.....	4	0	5	0	5	2				
8-2.....	4	0	5	0	5	2	6	3	6	4
1-4/0.....	5	0	6	0	6	2	6	3	6	4
213-500.....	6	0	6	0	6	2	6	3	7	4
501-1000.....	6	2	6	2	6	3	6	4	7	4
1001-2000.....	7	2	7	2	7	3	7	4	7	5

Note: The thickness given in columns headed "C" are for the insulation on the individual conductors. Those given in the columns headed "B" are for the thickness of the overall belt of insulation.

TABLE E 310.02 (8) (d)
THICKNESS OF ASBESTOS AND VARNISHED-CAMBRIC
INSULATION FOR SINGLE-CONDUCTOR CABLE, TYPES
AVA, AVB AND AVI, IN MILS

Conductor Size AWG or MCM	1st Wall Asbestos	Varnished Cambric					2nd Wall Asbestos
	For Voltages Not Exceeding						
	1000- 5000	1000	2000	3000	4000	5000	1000- 5000
14-2.....	15	45	60	80	100	120	25
1-4/0.....	20	45	60	80	100	120	30
213-500.....	25	45	60	80	100	120	40
501-1000.....	30	45	60	80	100	120	40
1001-2000.....	30	55	75	95	115	140	50

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.03 Insulating materials. (1) The rubber insulations include those made from natural and synthetic rubber, neoprene and other vulcanizable materials.

(2) Thermoplastic insulation may stiffen at temperatures below minus 10° C. (14° F.) and care should be used in its installation at such temperatures. It may be deformed when subject to pressure; care should be taken in its installation, as for example, at bushings, or points of support. See subsection E 373.06 (2).

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.04 Temperature limitations. No conductor shall be used under such conditions that its temperature, even when carrying current, will exceed the temperature specified in table E 310.02 (1) for the type of insulation involved.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.05 Wet locations. Insulated conductors used underground, in concrete slabs or other masonry in direct contact with earth, in wet

locations, or where condensation or accumulation of moisture within the raceway is likely to occur, shall be moisture-resistant, rubber-covered (type RW); moisture and heat-resistant, rubber-covered (type RHW); moisture-resistant, thermoplastic-covered (type TW); moisture and heat-resistant, thermoplastic-covered (type THW); lead covered; mineral insulated-metal sheathed (type MI); or of a type approved for the purpose.

Note: Such conductors are not suitable for direct burial in the earth unless of a type specifically approved for the purpose.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.06 Buried conductors. Cables of one or more conductors for direct burial in the earth shall be type USE, except that branch circuit and feeder cable may be type UF. Where single conductor cables are installed, all conductors of each service, feeder, sub-feeder or branch circuit, including the neutral conductor, shall be run continuously in the same trench or raceway. Supplementary mechanical protection, such as a covering board, concrete pad, raceway, etc., may be required by the administrative authority.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.07 Corrosive conditions. Conductors exposed to oils, greases, vapors, gases, fumes, liquids or other substances having a deleterious effect upon the conductor or insulation shall be of a type approved for the purpose.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.08 Minimum size of conductors. Conductors, whether solid or stranded, shall not be smaller than No. 14, except for printing press control circuits; as provided for flexible cords in section E 400.07; for fixture wire in section E 410.18; for fractional horsepower motors in section E 430.022; for cranes and hoists in section E 610.14; for elevator control and signal circuits in section E 620.12; for machine tools in section E 670.21; and for remote-control, low-energy power, low voltage power and signal circuits in section E 725.13.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.09 Stranded conductors. Except when used as bus bars or in type MI cable, conductors No. 6 and larger, installed in raceways, shall be stranded.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.10 Conductors in multiple. Conductors in sizes 1/0 and larger may be run in multiple provided they are of the same length and have the same circular-mil area and type of insulation. Where conductors are run in multiple, they shall be arranged and terminate at both ends in such a manner as to insure equal division of the total current between all conductors that are involved.

Note: When conductors are used in multiple, space in enclosures should be given consideration.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

E 310.11 Current-carrying capacity. The maximum, continuous, current-carrying capacities of copper conductors are given in tables E 310.12 and E 310.13. The current-carrying capacities of aluminum conductors are given in tables E 310.14 and E 310.15.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

Notes to Tables E 310.12 through E 310.15

1. *Explanation of tables.* For explanation of type letters, and for recognized size of conductors for the various conductor insulations, see sections E 310.02 and E 310.03. For installation requirements, see sections E 310.01 through E 310.07, and the various chapters of this code. For flexible cords see tables E 400.09 and E 400.11.

2. *Application of tables.* For open wiring on insulators and for concealed knob-and-tube work, the allowable current-carrying capacities of tables E 310.13 and E 310.15 shall be used. For all other recognized wiring methods, the allowable current-carrying capacities of tables E 310.12 and E 310.14 shall be used, unless otherwise provided in this code.

3. *Aluminum conductors.* For aluminum conductors, the allowable current-carrying capacities shall be in accordance with tables E 310.14 and E 310.15.

4. *Bare conductors.* Where bare conductors are used with insulated conductors, their allowable current-carrying capacity shall be limited to that permitted for the insulated conductors of the same size.

5. *Type MI cable.* The temperature limitation on which the current-carrying capacities of type MI cable are based, is determined by the insulating materials used in the end seal. Termination fittings incorporating unimpregnated organic insulating materials are limited to 85°C. operation.

6. *Ultimate insulation temperature.* In no case shall conductors be associated together in such a way with respect to the kind of circuit, the wiring method employed, or the number of conductors, that the limiting temperature of the conductors will be exceeded.

7. *Use of conductors with higher operating temperatures.* Where the room temperature is within 10° C. of the maximum allowable operating temperature of the insulation, it is desirable to use an insulation with a higher maximum allowable operating temperature; although insulation can be used in a room temperature approaching its maximum allowable operating temperature limit if the current is reduced in accordance with the correction factors for different room temperatures.

8. *More than three conductors in a raceway or cable.* Tables E 310.12 and E 310.14 give the allowable current-carrying capacities for not more than 3 conductors in a raceway or cable. Where the number of conductors in a raceway or cable exceeds 3, the allowable current-carrying capacity of each conductor shall be reduced as shown in the following table:

Number of Conductors	Per Cent of Values in Tables E 310.12 and E 310.14
4 to 6.....	80
7 to 24.....	70
25 to 42.....	60
43 and above.....	50

Exception. When conductors of different systems, as provided in section E 300.03, are installed in a common raceway the derating factors shown above apply to the number of Power and Lighting (chapters E 210, E 215, E 220 and E 230) conductors only.

9. Where type RH-RW rubber insulated wire is used in wet locations the allowable current-carrying capacities shall be those of column 2 in tables E 310.12 through E 310.15. Where used in dry locations the allowable current-carrying capacities shall be those of column 3 in tables E 310.12 through E 310.15.

10. *Overcurrent protection.* Where the standard ratings and settings of overcurrent devices do not correspond with the ratings and settings allowed for conductors, the next higher standard rating and setting may be used.

11. *Neutral conductor.* A neutral conductor which carries only the unbalanced current from other conductors, as in the case of normally balanced circuits of 3 or more conductors, shall not be counted in determining current-carrying capacities as provided for in Note 8.

a. In a 3-wire circuit consisting of two phase wires and the neutral of a 4-wire, 3-phase system, a common conductor carries approximately the same current as the other conductors and is not therefore considered as a neutral conductor.

12. *Voltage Drop.* The allowable current-carrying capacities in tables E 310.12 through E 310.15 are based on temperature alone and do not take voltage drop into consideration.

13. *Deterioration of insulation.* It should be noted that even the best grades of rubber insulation will deteriorate in time, so eventually will need to be replaced.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

TABLE E 310.12
ALLOWABLE CURRENT-CARRYING CAPACITIES OF INSULATED
COPPER CONDUCTORS IN AMPERES
 Not More than Three Conductors in Raceway or Cable or Direct
 Burial (Based on Room Temperature of 30°C, 86°F.)

Size AWG MCM	Rubber Type R Type RW	Rubber Type RH	Paper	Asbestos Var-Cam Type AVA Type AVL	Impreg- nated Asbestos Type AI (14-8) Type AIA	Asbestos Type A (14-8) Type AA
	Type RU Type RUW (14-2)	RUH (14-2)	Thermo- plastic Asbestos Type TA SA			
	Type RH-RW See Note 9	Type RH-RW See Note 9	Var-Cam Type V			
	Thermo- plastic Type T Type TW	Type RHW Thermo- plastic Type THW	Asbestos Var-Cam Type AVB			
			MI Cable			
			RHH**			
14	15	15	25	30	30	30
12	20	20	30	35	40	40
10	30	30	40	45	50	55
8	40	45	50	60	65	70
6	55	65	70	80	85	95
4	70	85	90	105	115	120
3	80	100	105	120	130	145
2	95	115	120	135	145	165
1	110	130	140	160	170	190
0	125	150	155	190	200	225
00	145	175	185	215	230	250
000	165	200	210	245	265	285
0000	195	230	235	275	310	340
250	215	255	270	315	335	-----
300	240	285	300	345	380	-----
350	260	310	325	390	420	-----
400	280	335	360	420	450	-----
500	320	380	405	470	500	-----
600	355	420	455	525	545	-----
700	385	460	490	560	600	-----
750	400	475	500	580	620	-----
800	410	490	515	600	640	-----
900	435	520	555	-----	-----	-----
1000	455	545	585	680	730	-----
1250	495	590	645	-----	-----	-----
1500	520	625	700	785	-----	-----
1750	545	650	735	-----	-----	-----
2000	560	665	775	840	-----	-----

CORRECTION FACTORS, ROOM TEMPS. OVER 30°C, 86°F.

C.	F.					
40	104	.82	.88	.90	.94	.95
45	113	.71	.82	.85	.90	.92
50	122	.58	.75	.80	.87	.89
55	131	.41	.67	.74	.83	.86
60	140	-----	.58	.67	.79	.83
70	158	-----	.85	.52	.71	.76
75	167	-----	-----	.43	.66	.72
80	176	-----	-----	.30	.61	.69
90	194	-----	-----	-----	.50	.61
100	212	-----	-----	-----	-----	.51
120	248	-----	-----	-----	-----	-----
140	284	-----	-----	-----	-----	-----

**The current-carrying capacities for type RHH conductors for sizes AWG 14, 12 and 10 shall be the same as designated for type RH conductors in this table.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

TABLE E 310.13
ALLOWABLE CURRENT-CARRYING CAPACITIES OF INSULATED
COPPER CONDUCTORS IN AMPERES
 Single Conductor in Free Air (Based on Room
 Temperature of 30°C. 86°F.)

Size AWG MCM	Rubber Type R Type RW	Rubber Type RH	Thermo- plastic Asbestos Type TA SA	Asbestos Var-Cam Type AVA Type AVL	Impreg- nated Asbestos Type AI (14-8) Type AIA	Asbestos Type A (14-8) Type AA	Slow Burning Type SB
	Type RU Type RUW (14-2)	RUH (14-2)	Var-Cam Type V				
	Type RH-RW See Note 9	Type RHW See Note 9	Asbestos Var-Cam Type AVB				
	Thermo- plastic Type T Type TW	Thermo- plastic Type THW	MI Cable				
			RHH**				
14	20	20	30	40	40	45	30
12	25	25	40	50	50	55	40
10	40	40	55	65	70	75	55
8	55	65	70	85	90	100	70
6	80	95	100	120	125	135	100
4	105	125	135	160	170	180	130
3	120	145	155	180	195	210	150
2	140	170	180	210	225	240	175
1	165	195	210	245	265	280	205
0	195	230	245	285	305	325	235
00	225	265	285	330	355	370	275
000	260	310	330	385	410	430	320
0000	300	360	385	445	475	510	370
250	340	405	425	495	530	-----	410
300	375	445	480	555	590	-----	460
350	420	505	530	610	655	-----	510
400	455	545	575	665	710	-----	555
500	515	620	660	765	815	-----	630
600	575	690	740	855	910	-----	710
700	630	755	815	940	1005	-----	780
750	655	785	845	980	1045	-----	810
800	680	815	880	1020	1085	-----	845
900	730	870	940	-----	-----	-----	905
1000	780	935	1000	1165	1240	-----	965
1250	890	1065	1130	-----	-----	-----	-----
1500	980	1175	1260	1450	-----	-----	1215
1750	1070	1280	1370	-----	-----	-----	-----
2000	1155	1385	1470	1715	-----	-----	1405

CORRECTION FACTORS, ROOM TEMPS. OVER 30°C. 86°F.

C. F.							
40 104	.82	.88	.90	.94	.95	-----	-----
45 113	.71	.82	.85	.90	.92	-----	-----
50 122	.58	.75	.80	.87	.89	-----	-----
55 131	.41	.67	.74	.83	.86	-----	-----
60 140	-----	.58	.67	.79	.83	.91	-----
70 158	-----	.35	.52	.71	.76	.87	-----
75 167	-----	-----	.43	.66	.72	.86	-----
80 176	-----	-----	.30	.61	.69	.84	-----
90 194	-----	-----	-----	.50	.61	.80	-----
100 212	-----	-----	-----	-----	.51	.77	-----
120 248	-----	-----	-----	-----	-----	.69	-----
140 284	-----	-----	-----	-----	-----	.59	-----

**The current-carrying capacities for type RHH conductors for sizes AWG 14, 12 and 10 shall be the same as designated for type RH conductors in this table.
 Weather-proof covered conductors used for service drops have the same current-carrying capacity as type SB.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

TABLE E 310.14
ALLOWABLE CURRENT-CARRYING CAPACITIES OF INSULATED
ALUMINUM CONDUCTORS IN AMPERES

Not More than Three Conductors in Raceway or Cable or Direct Burial (Based on Room Temperature of 30°C, 86°F.)

Size AWG MCM	Rubber Type R, RW, RU, RUW (12-2)	Rubber Type RH RUH (14-2)	Thermo- plastic Asbestos Type TA SA	Asbestos Var-Cam Type AVA Type AVL	Impreg- nated Asbestos Type AI (14-8) Type AIA	Asbestos Type A (14-8) Type AA
	Type RH-RW Note 9	Type RH-RW Note 9	Var-Cam Type V			
	Thermo- plastic Type T, TW	Type RHW Thermo- plastic Type THW	Asbestos Var-Cam Type AVB			
			MI Cable RHH**			
12	15	15	25	25	30	30
10	25	25	30	35	40	45
8	30	40	40	45	50	55
6	40	50	55	60	65	75
4	55	65	70	80	90	95
3	65	75	80	95	100	115
*2	75	90	95	105	115	130
*1	85	100	110	125	135	150
*0	100	120	125	150	160	180
*00	115	135	145	170	180	200
*000	130	155	165	195	210	225
*0000	155	180	185	215	245	270
250	170	205	215	250	270	-----
300	190	230	240	275	305	-----
350	210	250	260	310	335	-----
400	225	270	290	335	360	-----
500	260	310	330	380	405	-----
600	285	340	370	425	440	-----
700	310	375	395	455	485	-----
750	320	385	405	470	500	-----
800	330	395	415	485	520	-----
900	355	425	455	-----	-----	-----
1000	375	445	480	560	600	-----
1250	405	485	530	-----	-----	-----
1500	435	520	530	650	-----	-----
1750	455	545	615	-----	-----	-----
2000	470	560	650	705	-----	-----

CORRECTION FACTORS, ROOM TEMPS. OVER 30°C, 86°F.

C.	F.						
40	104	.82	.88	.90	.94	.95	-----
45	113	.71	.82	.85	.90	.92	-----
50	122	.58	.75	.80	.87	.89	-----
55	131	.41	.67	.74	.83	.86	-----
60	140	-----	.58	.67	.79	.83	.91
70	158	-----	.35	.52	.71	.76	.87
75	167	-----	-----	.43	.66	.72	.86
80	176	-----	-----	.30	.61	.69	.84
90	194	-----	-----	-----	.50	.61	.80
100	212	-----	-----	-----	-----	.51	.77
120	248	-----	-----	-----	-----	-----	.69
140	284	-----	-----	-----	-----	-----	.59

*For three wire, single phase service and sub-service circuits, the allowable current-carrying capacity of RH, RH-RW, RHH, RHW, and THW aluminum conductors shall be for sizes #2-100 Amp., #1-110 Amp., #1/0-125 Amp., #2/0-150 Amp., #3/0-170 Amp., and #4/0-200 Amp.

**The current-carrying capacities for type RHH conductors for sizes AWG 12, 10 and 8 shall be the same as designated for type RH conductors in this table.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.

TABLE E 310.15
ALLOWABLE CURRENT-CARRYING CAPACITIES OF INSULATED
ALUMINUM CONDUCTORS IN AMPERES
 Single Conductor in Free Air (Based on Room
 Temperature of 30°C. 86°F.)

Size AWG MCM	Rubber Type R, RW, RU, RUW (12-2)	Rubber Type RH (14-2)	Thermo- plastic Asbestos Type TA SA	Asbestos Var-Cam Type AVA Type AVL	Impreg- nated Asbestos Type AI (14-8) Type AIA	Asbestos Type A (14-8) Type AA	Slow Burning Type SB
	Type RH-RW Note 9	Type RH-RW Note 9	Var-Cam Type V				
	Thermo- plastic Type T, TW	Type RHW	Asbestos Var-Cam Type AVB				
		Thermo- plastic Type THW	MI Cable RHH**				
12	20	20	30	40	40	45	30
10	30	30	45	50	55	60	45
8	45	55	55	65	70	80	55
6	60	75	80	95	100	105	80
4	80	100	105	125	135	140	100
3	95	115	120	140	150	165	115
2	110	135	140	165	175	185	135
1	130	155	165	190	205	220	160
0	150	180	190	220	240	255	185
00	175	210	220	255	275	290	215
000	200	240	255	300	320	335	250
0000	230	280	300	345	370	400	290
250	265	315	330	385	415	-----	320
300	290	350	375	435	460	-----	360
350	330	395	415	475	510	-----	400
400	355	425	450	520	555	-----	435
500	405	485	515	595	635	-----	490
600	455	545	585	675	720	-----	560
700	500	595	645	745	795	-----	615
750	515	620	670	775	825	-----	640
800	535	645	695	805	855	-----	670
900	580	700	750	-----	-----	-----	725
1000	625	750	800	980	990	-----	770
1250	710	855	905	-----	-----	-----	-----
1500	795	950	1020	1175	-----	-----	985
1750	875	1050	1125	-----	-----	-----	-----
2000	960	1150	1220	1425	-----	-----	1165

CORRECTION FACTORS, ROOM TEMPS. OVER 30°C. 86°F.

C. F.							
40 104	.82	.88	.90	.94	.95	-----	-----
45 113	.71	.82	.85	.90	.92	-----	-----
50 122	.58	.75	.80	.87	.89	-----	-----
55 131	.41	.67	.74	.83	.86	-----	-----
60 140	-----	.58	.67	.79	.83	.91	-----
70 158	-----	.35	.52	.71	.76	.87	-----
75 167	-----	-----	.43	.66	.72	.86	-----
80 176	-----	-----	.30	.61	.69	.84	-----
90 194	-----	-----	-----	.50	.61	.80	-----
100 212	-----	-----	-----	-----	.51	.77	-----
120 248	-----	-----	-----	-----	-----	.69	-----
140 284	-----	-----	-----	-----	-----	.69	-----

**The current-carrying capacities for type RHH conductors for sizes AWG 12, 10 and 8 shall be the same as designated for type RH conductors in this table.
 Weatherproof-covered conductors used for service drops have the same current-carrying capacity as type SB.

History: Cr. Register, November, 1961, No. 71, eff. 12-1-61.