

Ind 20 Filed January 7, 1964

STATE OF WISCONSIN)
DEPT. OF INDUSTRIAL COMMISSION) SS.

TO ALL TO WHOM THESE PRESENTS SHALL COME, GREETINGS:

I, Stephen J. Reilly, Administrative Officer - Secretary of the Industrial Commission of Wisconsin, and custodian of the official records of said Commission, do hereby certify that the attached copy of amendment to Ind 20.07 Rules on Dusts, Fumes, Vapors and Gases was adopted by the Industrial Commission on January 2, 1964.

I further certify that said copy has been compared by me with the original on file in this Commission and that the same is a true copy thereof and of the whole of such original.

IN TESTIMONY WHEREOF, I have hereunto set my hand and affixed the official seal of the department at the Capitol, in the city of Madison, this

6th day of January.

A.D., 1964.

Stephen J. Reilly
Administrative Officer-Secretary

Pursuant to authority vested in the Industrial Commission of Wisconsin by Section 101.01 - 101.29 Wisconsin Statutes, and pursuant to Chapter 227, The Industrial Commission on January 2, 1964, voted to amend Ind 20.07 of the Rules on Dusts, Fumes, Vapors and Gases. The amended section is attached.

The amendment shall become effective on the first day of the month following its publication in the Wisconsin Administrative code as provided in Section 227.

INDUSTRIAL COMMISSION OF WISCONSIN



Stephen J. Reilly
Administrative Officer-Secretary

January 6, 1964

Ind 20.07 Protection from harmful fumes, vapors or gases.

(1) The exhaust ventilation for the protection of persons exposed to equipment and processes which create fumes, vapors or gases in harmful proportions shall be accomplished by the provision of appropriate hoods at the source, with duct connections to appropriate exhaust fans or other approved suction devices. The protection provided in any room, pit, vat or tank, or at any equipment or process, such as at machines, vats, tanks, furnaces, forges, salamanders or similar equipment, shall be designed to include all sources of contamination at that apparatus and prevent the flow or drift of generated fumes, vapors or gases away from the exhaust hood.

(2) Unvented gas and oil fired heating apparatus specifically designed to provide temporary heat for construction projects is not subject to the provisions of section Ind 20.07 (1) provided such apparatus is so designed, operated and maintained that the concentration of products of combustion in any work area does not exceed the threshold limit values specified in section Ind 20.02.

(a) When requested by the Industrial commission, manufacturers of such unvented equipment shall supply the industrial commission with data showing the composition and concentration of the combustion gases under operating conditions.