

Ind 9

Filed May 31, 1967
3:15 P.M.

STATE OF WISCONSIN)
DEPT. OF INDUSTRIAL COMMISSION) SS.

TO ALL TO WHOM THESE PRESENTS SHALL COME, GREETINGS:

I, Stephen J. Reilly, Secretary of the Industrial Commission of Wisconsin, and custodian of the official records of said Commission, do hereby certify that the attached amendments to Wisconsin Administrative Code Ind 9.05 (2)(b) and Ind 9.35 were adopted by the Industrial Commission on May 31, 1967.

I further certify that said copy has been compared by me with the original on file in this Commission and that the same is a true copy thereof and of the whole of such original.

IN TESTIMONY WHEREOF, I have hereunto set my hand and affixed the official seal of the department at the Capitol, in the city of Madison, this 31st

day of May, A.D., 1967.


Executive Secretary

ORDER OF THE INDUSTRIAL COMMISSION

Pursuant to authority vested in the Industrial Commission by section 101.01 to 101.29 Wis. Stats., the Industrial Commission hereby repeals, recreates, and adopts rules as follows:

Repeal Section Ind 9.05 (2) and recreate as follows:

Ind 9.05 (2)(b) Each individual container shall be located with respect to the nearest important building or group of buildings or line of adjoining property which may be built on in accordance with the following table:

Water Capacity per Container	Under-Ground	Minimum Distances	
		Containers Aboveground	Between Aboveground Containers
Less than 125 gallons	10 feet	None	None
125 to 500 gallons	10 feet	10 feet	3 feet
501 to 2,000 gallons	25 feet*	25 feet*	3 feet
2,001 to 30,000 gallons	50 feet	50 feet	5 feet
30,001 to 70,000 gallons	50 feet	75 feet	1/4 of sum of diameters of adjacent containers
70,001 to 90,000 gallons	50 feet	100 feet	


* Note: The above distance requirements may be reduced to not less than 10 feet for a single container of 1200 gallons water capacity or less, providing such a container is at least 25 feet from any other LP-Gas container of more than 125 gallons water capacity.

Repeal Section Ind 9.35 and recreate as follows:

Ind 9.35 Capacity of Liquid Containers. A storage container shall not exceed 90,000 gallons water capacity.

The rules contained herein shall take effect on July 1, 1967 as provided in section 227.

INDUSTRIAL COMMISSION OF WISCONSIN


Stephen J. Reilly
Executive Secretary