

## Chapter Ind 60

### CHILD DAY CARE FACILITIES

Ind 60.001	Scope	Ind 60.23	Stair and shaft enclosure
Ind 60.01	Definitions	Ind 60.24	Fire extinguishers
Ind 60.10	Occupancy separation	Ind 60.25	Hazardous areas
Ind 60.11	Capacity of buildings	Ind 60.30	Class of construction
Ind 60.12	Doors	Ind 60.31	Exiting
Ind 60.13	Windows and outside openings	Ind 60.32	Required exit width
Ind 60.14	Access to attic and roof	Ind 60.33	Passageways
Ind 60.15	Sanitary facilities	Ind 60.34	Stair and shaft enclosure
Ind 60.16	Electrical work	Ind 60.35	Fire extinguishers
Ind 60.17	Illumination	Ind 60.36	Fire alarm systems
Ind 60.18	Heating and ventilating	Ind 60.37	Hazardous areas
Ind 60.19	Operating features	Ind 60.38	Exit and emergency lighting
Ind 60.20	Class of construction		
Ind 60.21	Exiting		
Ind 60.22	Passageways		

**Ind 60.001 Scope.** The requirements of this chapter shall apply to all public and private day care centers accommodating children, including all buildings, or parts of buildings, used as child day care facilities. Chapter Ind 60 shall not apply to public schools defined in section 115.01 (1), Wis. Stats., or private schools defined in section 121.51 (3), Wis. Stats., or to short-time programs (i.e., Boy Scouts, Girl Scouts, Sunday schools, etc.).

(1) Part I of this chapter is general requirements applicable to all child day care facilities within the scope of chapter Ind 60.

(2) Part II of this chapter is applicable to day care centers serving 4 to 8 children.

(3) Part III of this chapter is applicable to day care centers serving 9 or more children.

(4) Chapters Ind 50 through Ind 53 are applicable for general and structural design requirements.

**Note:** All references to code chapters and sections prefaced by the letters Ind refer to rules of the department of industry, labor and human relations published in the Wisconsin Administrative Code; i.e., Chapters Ind 50 and Ind 53 are a part of Wisconsin Administrative Code Chapters Ind 50-64—Building and Heating, Ventilating and Air Conditioning Code.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.01 Definitions.** (1) **DAY CARE CENTER.** Any place which receives at any one time for compensation 4 or more children under the age of 7 years, for care and supervision, for less than 24 hours a day for more than 10 days a month, without the attendance of a parent, relative or legal guardian.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

#### Part I

#### GENERAL REQUIREMENTS

**Ind 60.10 Occupancy separation.** (1) Where centers are located in conjunction with an assembly hall or a hazardous occupancy, the

Register, December, 1974, No. 228  
Building and heating, ventilating  
and air conditioning code

requirements of sections Ind 55.05 and Ind 57.50 (2), respectively, shall be applicable. If there is no requirement, a one-hour fire-resistive separation shall be provided.

(a) Day care facilities in a church or school building need not comply with the requirements of this section provided all other occupancy requirements are complied with; i.e., the fire wall requirement may be waived if more stringent requirements of chapter Ind 55 or chapter Ind 56 are complied with.

(b) Private garages attached to day care centers serving 4-8 children shall be separated by a one-hour fire-resistive wall.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.11 Capacity of buildings.** (1) The occupant load shall be the maximum number of children intended to occupy that floor, but not more than one child per 35 square feet of net floor area. Licensing limitations of the department of health and social services may supersede this requirement.

**Note:** The minimum staff-to-child ratio shall meet the requirements of PW-CY 40.12 of the department of health and social services, which is as follows:

Age	Minimum number of staff to children
0-1 years	1 to 3 children
1-2 years	1 to 4 children
2-2½ years	1 to 6 children
2½-3 years	1 to 8 children
3-4 years	1 to 10 children
4-5 years	1 to 12 children
5 years or over	1 to 16 children

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.12 Doors.** (1) All exit doors, and all doors along the path of travel to an exit, shall meet the requirements of section Ind 51.15 with the following exceptions:

(a) The width of all required exit doors may be reduced to 3 feet.

(b) The width of all required exit doors may be reduced to 2 feet 8 inches in existing buildings not accommodating more than 8 children.

(c) All such doors used by not more than 25 persons need not swing outward.

(2) Every closet door latch shall be such that children can open the door from inside the closet.

(3) Every toilet room door lock shall be designed to permit opening of the locked door from the outside in an emergency, and the opening device shall be readily accessible to the staff.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.13 Windows and outside openings.** (1) All classrooms and areas used for instruction, study or sleeping purposes shall be provided with vision panels or windows facing directly upon a street, alley, or open court. The vision panels or windows shall be glazed with glass or other approved material.

(2) The windows or vision panels shall have an aggregate mini-

mum glass area of 10% of the floor area. The minimum openable area of the doors and windows shall be equal to 5% of the floor area of the room served.

(3) See subsection Ind 60.18 (2) for exception.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.14 Access to attic and roof.** (1) Every 2-story building shall have a permanent means of access to the attic space from inside the building. Every building more than 2 stories in height shall have a permanent means of access to the roof. Where a scuttle opening is provided, the opening shall be not less than 20 x 30 inches.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.15 Sanitary facilities.** (1) One water closet and one lavatory for the first 10 children and one water closet and one lavatory for every 15 children in excess of 10 shall be provided.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.16 Electrical work.** (1) The electrical systems in existing buildings proposed to be used as day care centers shall conform to the Wisconsin state electrical code.

(2) Special protective receptacle covers shall be installed in all areas occupied by children.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.17 Illumination.** (1) The illumination for occupied areas, other than sleeping areas, shall have a minimum intensity of 20 foot-candles at a horizontal plane 24 inches above the floor. All other spaces shall meet the requirements of section Ind 19.04, Wis. Adm. Code chapter Ind 19, Illumination Code.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.18 Heating and ventilating.** (1) The heating system shall be capable of maintaining an inside temperature of not less than 67° F.

(2) Fresh air at the rate of 5 cubic feet per minute per occupant shall be provided for centers that do not comply with the requirements of Ind 60.13 (2).

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.19 Operating features.** (1) Fire prevention inspections shall be conducted monthly. A copy of the latest completed inspection form shall be posted in a conspicuous place in the day care facility.

(2) A fire evacuation plan shall be practiced not less than once per month. Fire alarm and/or smoke detection systems shall be tested at weekly intervals. It is recommended that fire safety be a part of the educational program of the center.

(3) Furnishings, decorations, or other objects shall not be so placed as to obstruct exits, access thereto, egress therefrom, or visibility thereof.

Register, December, 1974, No. 228  
Building and heating, ventilating  
and air conditioning code

(4)\* Flammable and combustible liquids shall be stored in areas accessible only to designated individuals, and as recommended in NFPA standard No. 30, Flammable and Combustible Liquids Code.

**Note:** NFPA standard No. 30 is not a mandatory standard.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

## Part II

### DAY CARE CENTERS SERVING 4 TO 8 CHILDREN

**Ind 60.20 Class of construction.** (1) Buildings which are 2 stories or less in height shall be constructed of wood frame unprotected type No. 8 construction, or better, as specified in section Ind 51.03.

(2) Buildings which are 3 stories in height shall be constructed of metal frame unprotected type No. 6 construction, or better, as specified in section Ind 51.03.

(3) Buildings which are more than 3 stories in height shall be constructed of fire-resistive type No. 1 or No. 2 construction, as specified in section Ind 51.03.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.21 Exiting.** (1) Children under the age of 2½ years shall be restricted to the first floor, as determined in section Ind 51.02 (14), or to ground floors provided with 2 means of egress directly to grade.

(2) Each floor occupied by children shall have not less than 2 exits.

(3) The exits shall be located to provide the best possible means of egress.

(4) Where the floor above exit discharge grade is used by children for sleeping purposes, one exit shall lead directly from the floor to the exterior.

(5) Travel distance from any point to an outside exit door or stair enclosure leading to the outside shall not exceed 75 feet. Travel distance may be increased to 125 feet when the building is provided with a sprinkler system in accordance with the requirements of section Ind 51.23.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.22 Passageways.** (1) The minimum unobstructed passageway width shall not be less than 3 feet.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.23 Stair and shaft enclosure.** (1) A self-closing door shall be provided at the stair between the basement or ground floor and the first floor.

(2) A self-closing door or smoke detector shall be provided at the stair between the first floor and the second floor when the second floor is used by the children for sleeping purposes. (This requirement does not apply to buildings which are provided with a fire alarm system as described in section Ind 51.24.)

\* See Appendix A for further explanatory material.

Register, December, 1974, No. 228  
Building and heating, ventilating  
and air conditioning code

(3) Stairs and shafts serving 3 or more floor levels shall comply with the requirements of subsection Ind 51.02 (11) and Table 51.03-A.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.24\* Fire extinguishers.** (1) A portable fire extinguisher suitable for Class B fires shall be provided for the kitchen and cooking area.

**History:** Cr. Register, October, 1974, No. 226, eff. 10-1-74.

**Ind 60.25 Hazardous areas.** (1) A boiler, furnace, or any area containing gas- or oil-fired units other than laundry or kitchen equipment shall be protected by one of the following methods:

(a) One-hour fire-resistive enclosure. The door in the enclosure shall be a 1¾-inch thick, solid wood core door. Combustion air shall be provided in accordance with section Ind 59.59.

(b) Protected by a smoke detection system.

(2) Hazardous equipment in areas occupied by children shall be separated by one-hour fire-resistive partitions.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

### Part III DAY CARE CENTERS SERVING 9 OR MORE CHILDREN

**Ind 60.30 Class of construction.** (1) Class of construction for day care centers shall comply with Table 60.30. Day care centers located in buildings of more than 4 stories shall be provided with one independent stairway serving the day care center only and restricted to the height indicated in Table 60.30.

**TABLE 60.30**

Type of Construction	Maximum Allowable Height (feet)	Maximum Allowable Number of Stories			
		1	2	3	4
Fire-resistive Type A No. 1 and Type B No. 2	85	X	X	X	X
Metal Frame Protected No. 3 and Heavy Timber No. 4	75	X	X	X	
Exterior Masonry No. 5	50	X	(c)	(a) & (b) or (a) & (d)	
Metal Frame Unprotected No. 6	50	X	(c)	(a)	
Wood Frame Protected No. 7	40	X	X		
Wood Frame Unprotected No. 8	35	X	(c)		

X = permitted.

\* See Appendix A for further explanatory material.

Register, December, 1974, No. 228  
Building and heating, ventilating  
and air conditioning code

(a) All floors and supporting members shall have a one-hour fire-resistive rating.

(b) The entire building shall be equipped with an automatic sprinkler system in accordance with section Ind 51.23.

(c) All ceilings shall be covered with ½-inch gypsum wallboard or equivalent.

(d) All floor systems shall be of noncombustible construction.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.31 Exiting.** (1) Each floor shall have not less than 2 exits. All required exits shall lead directly, or through an enclosed stairway, to the outside.

(2) The exits shall be located to provide the best possible means of egress.

(3) Travel distance measured along safe passageways between:

(a) Any point in a sleeping room or suite and an exit access door of that room or suite shall not exceed 50 feet;

(b) Any room door intended as an exit access and an exit shall not exceed 50 feet;

(c) Any point in a room or suite and an exit shall not exceed 100 feet.

(4) The travel distances for children under 2½ years of age in (3) above shall be reduced by 50%.

(5) The travel distances in (3) above may be increased by 50 feet in buildings completely equipped with an automatic sprinkler system. No increase in travel distance is permitted for children under the age of 2½ years.

(6) Children under the age of 2½ years shall be restricted to the first floor, as determined in subsection Ind 51.02 (14), or to ground floors provided with 2 means of egress directly to grade.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.32 Required exit width.** The total required exit width from a building level shall be in accordance with the requirements of subsections Ind 51.15 (6) and Ind 51.16 (3).

(2) If horizontal exits (section Ind 51.19) are provided for any floor, the number of persons accommodated on such floor may be increased at the rate of 100 persons for each 40 inches of width of such exits, provided such increase shall not exceed 100% of the number of persons accommodated by the stairways.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74; r. and recr. Register, December, 1974, No. 228, eff. 1-1-75.

**Ind 60.33 Passageways.** (1) The minimum unobstructed width of corridors and passageways shall be determined in the same manner as specified for stairways and exits in section Ind 60.32. The minimum width shall be not less than 3 feet 8 inches.

(2) The minimum passageway width shall not be less than 3 feet in existing buildings proposed to be used as day care centers, provided the capacity of the day care center does not exceed 40 persons.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

Register, December, 1974, No. 228  
Building and heating, ventilating  
and air conditioning code

**Ind 60.34 Stair and shaft enclosure.** (1) All stairs and vertical shafts serving 3 or more floor levels shall comply with subsection Ind 51.02 (11) and Table 51.03-A. All required stair enclosures must lead to the outside without interruptions.

(2) No storage closets shall be placed under any stairway, platform or landing. A room may be placed under a stairway or stair landing of 2-hour fire-resistive construction, or better, provided such room does not have combustible material or hazardous equipment stored or operated therein. The door to such room shall be a self-closing, solid, flush type wood door, 1¾ inches in thickness, or better.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.35\* Fire extinguishers.** (1) Portable fire extinguishers suitable for Class B fires shall be installed in kitchens and cooking areas, and extinguishers suitable for Class A fires shall be installed throughout the remainder of the center.

TABLE 60.35

Basic Minimum Extinguisher Rating for Area Specified	Maximum Travel Distance to Extinguishers (feet)	Area to be Protected per Extinguisher (square feet)
1A	75	3,000
2A	75	6,000
3A	75	9,000
4A	75	11,250
6A	75	11,250

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.36 Fire alarm systems.** (1) Every building accommodating more than 20 children shall be provided with a fire alarm system complying with the requirements of section Ind 51.24.

(a)\* Exception. Buildings used for other purposes prior to occupancy as a day care center shall be provided with an approved fire alarm system. The department will accept fire alarm systems complying with the requirements of NFPA standard No. 72A, Local Protective Signaling Systems, or portable alarms approved by the department.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.37 Hazardous areas.** (1) Hazardous areas, including boiler or furnace rooms, fuel storage, maintenance shops, woodworking shops, painting areas, and laundries having gas- or oil-fired units with a maximum aggregate input of 37,000 Btu or more, shall be separated from other parts of the building by construction having not less than a one-hour fire-resistive rating. All openings shall be protected by ¾-hour self-closing doors in buildings of 3 stories or less in height. Enclosures shall have a 2-hour fire-resistive rating with 1½-hour "B" label doors in buildings more than 3 stories in height. If the hazard is severe, automatic sprinklers shall be provided

\* See Appendix A for further explanatory material.

in addition to the fire-resistive enclosure when deemed necessary by the department.

**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

**Ind 60.38 Exit and emergency lighting.** (1) All required exit doors and exit stairways in day care centers shall be plainly marked by a red, illuminated, translucent exit sign bearing the word EXIT or OUT in plain letters not less than 6 inches high.

(2) All illuminated exit signs shall be supplied from an emergency source recognized by Wis. Adm. Code chapter E 700, Vol. 2, Wisconsin State Electrical Code.


**History:** Cr. Register, October, 1974, No. 226, eff. 11-1-74.

Register, December, 1974, No. 228  
Building and heating, ventilating  
and air conditioning code

APPENDIX A

The following notes, bearing the same number as the text of the building and heating, ventilating and air conditioning code to which they apply, contain useful explanatory material to clarify the referenced definitions and rules.

- A-51.01 (12) BUILDING. The intent was to consider permanent awnings as part of a building.
- A-51.01 (42) FAMILY. The intent of this definition is to clarify the use of the word "family" in reference to subsection Ind 57.001 (2) (a); it is not intended as a variance to requirements stated under Ind 57.001 (2) (b).
- A-51.01 (67a) HABITABLE ROOM. It is the intent that rooms designated as recreation, study, den, family room, office, etc. and providing the only space for living and/or sleeping are considered habitable rooms.
- A-51.01 (115) SETBACK. The intent was to not include gutters, downspouts, outdoor lighting fixtures, signs and similar attachments as parts of a building.
- A-51.01 (121) STORIES, NUMBER OF. For further clarification, refer to A-51.02 (14).
- A-51.01 (144) WALL (DIVISION).
  - (a) *Building division wall* is intended to denote a wall constructed in a manner sufficient to meet requirements for a party wall [see "Wall (Party)"] and is acceptable as a dividing wall or enclosing wall when determining the volume of a building as referred to in sections Ind 50.10, 52.001 and 59.20. Also see Chapter A-E 2 of Wis. Adm. Code—Examining Board of Architects, Professional Engineers, Designers and Land Surveyors.
  - (b) *Fire division wall* is intended to relate to construction that provides separation between portions of a building to satisfy allowable floor area limitations, separation between 2 classes of construction, or separation of hazardous occupancies. For other separations, see "occupancy separations" and isolation of hazards sections of this code.
- A-51.02 (14) DETERMINATION OF NUMBER OF STORIES. The following illustrations are provided to give visual aid to this rule and the definition of Ind 51.01 (121) Stories, Number of.



NOTE: PENTHOUSE AREAS EXCEEDING 50% OF ROOF AREA WILL BE CONSIDERED AN ADDITIONAL STORY






ILLUSTRATION SHOWING POSSIBLE 2 STORY CONDITION OR 3 STORY WITH PENTHOUSE

NOTE: FOR ADDITIONAL VARIATIONS TO NO. OF STORIES SEE IND. 5,02 (3)(b). ILLUSTRATION A-2



FOUR STORY BUILDING ILLUSTRATION A-3

Register, December, 1974, No. 228 Building and heating, ventilating and air conditioning code



A-51.042 (5) The use of the term "high hazard" as referred to in this section is intended to apply to the following list of operations and occupancies:

1. Aircraft hangars.
2. Dry cleaning establishments: using or storing gasoline or other volatile flammable liquids.
3. Enameling or japanning operations.
4. Mills: sugar, starch, cereal, feed, flour and grist mills.
5. Paint and varnish: manufacturing, storing, handling, spraying, and other related operations.
6. Pyroxylin products: manufacture and storage.
7. Repair garages.
8. Smoke houses.
9. Storage of: explosive gases under pressure (15 psi and over 2,500 cubic feet) such as acetylene, hydrogen, natural gas, etc.
10. Storage of: materials with a flash point under 200° F, such as celluloid products, kerosene, oils, etc.
11. Woodworking establishments.

A-51.15 (6) EXAMPLE TO DETERMINE TOTAL AGGREGATE EXIT WIDTH.

5	300
4	400
3	500
2	200
1	600
B <sub>1</sub>	100
B <sub>2</sub>	300
B <sub>3</sub>	400

Grade

Type No. 1 sprinklered construction.

Aggregate exit width required from a floor into the stairwell is 30 inches per 100 people on that floor; i.e.,

5th floor to stairwell =  $3 \times 30 = 90''$

4th floor to stairwell =  $4 \times 30 = 120''$

3rd floor to stairwell =  $5 \times 30 = 150''$

Stair width required:

5th to 4th - 300 persons (100%)  $\times 30''/100$  persons =  $90''$

4th to 3rd - [400 persons (100%) + 300 persons (50%)]  $30''/100$  persons =  $165''$

3rd to 2nd - [500 persons (100%) + 400 persons (50%) + 300 persons (25%)]  $30''/100$  persons =  $232.5''$

2nd to 1st - [200 persons (100%) + 500 persons (50%) + 400 persons (25%)]  $30''/100$  persons =  $255''$

1st to exterior - [600 persons (100%) + (200 persons + 100 persons) (50%) + (500 persons + 300 persons) (25%)]  $30''/100$  persons =  $285''$


B<sub>1</sub> to 1st - [100 persons (100%) + 300 persons (50%) + 400 persons (25%)]  $30''/100$  persons =  $105''$  (Use  $150''$ )

B<sub>2</sub> to B<sub>1</sub> - [300 persons (100%) + 400 persons (50%)]  $30''/100$  persons =  $150''$


B<sub>3</sub> to B<sub>2</sub> - 400 persons (100%)  $\times 30''/100$  persons =  $120''$

Stair width required from B<sub>1</sub> to 1 is  $150''$  as stair cannot decrease in width along path to exit [Ind 51.16 (2) (c)].

A-52.04 REQUIREMENTS FOR BARRIER-FREE ENVIRONMENTS. The following illustrations are provided to give the designer visual aids for making facilities accessible.



STANDARD WHEELCHAIR DIMENSIONS




DOORS IN SERIES




INTERNATIONAL SYMBOL FOR BARRIER FREE ENVIRONMENTS


Register, December, 1974, No. 228  
Building and heating, ventilating  
and air conditioning code



90° TURN





S-TURN




90° TURN

TURNING SPACE





180° - 360° TURNS




TOILET FACILITIES

Register, December, 1974, No. 228.  
Building and heating, ventilating  
and air conditioning code



TOILET FACILITIES

Register, December, 1974, No. 228  
Building and heating, ventilating  
and air conditioning code



A-57.18 The intent of this section is to apply to floor levels not more than one story below grade (at building)

A-57.18 (6) It is the intent of this subsection that each living unit needs only one means of exit from within the unit and that the entire building be provided with no less than 2 exits.

A-60.19 (4). The standard is available from the National Fire Protection Association, 470 Atlantic Ave., Boston, Massachusetts 02210.

A-60.24 Class A fires are fires in ordinary combustible materials such as wood, cloth, paper, rubber, and many plastics. Class B fires are fires in flammable liquids, gases and greases.

A-60.35 See A-60.24.

A-60.36 (1) (a). See A-60.19 (4).