

*Interim eff. limitations
filed June 10, 1975 9:00 am*

NR 210



State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

L. P. Voigt
Secretary

BOX 450
MADISON, WISCONSIN 53701

IN REPLY REFER TO: _____

STATE OF WISCONSIN)
)
DEPARTMENT OF NATURAL RESOURCES) SS

TO ALL TO WHOM THESE PRESENTS SHALL COME, GREETINGS:

I, L. P. Voigt, Secretary of the Department of Natural Resources and custodian of the official records, do hereby certify that the annexed copy of Natural Resources Board Order No. W-26-75 (I) has been compared by me with the original order on file in this office of the Department of Natural Resources, Madison, Wisconsin, and that the same is a true copy thereof, and of the whole of such original order; that said order was duly passed and published as set forth therein.

IN TESTIMONY WHEREOF, I have hereunto set my hand and affixed the official seal of the Department at the Pyare Square Building in the Village of Shorewood Hills, this 5th day of June, 1975.

L. P. Voigt, Secretary

(SEAL)

STATE OF WISCONSIN NATURAL RESOURCES BOARD

.....
IN THE MATTER of repealing and recreating .
Section NR 210.11 of the Wisconsin .
Administrative Code pertaining to Sewage .
Treatment Works
.....

ORDER NO. W-26-75 (I)

ORDER OF THE STATE OF WISCONSIN NATURAL RESOURCES BOARD

REPEALING AND RECREATING RULES

Pursuant to authority vested in the State of Wisconsin Natural Resources Board by sections 147.04(3), 147.04(5) and Chapter 227, Wisconsin Statutes, the State of Wisconsin Natural Resources Board hereby repeals and recreates section NR 210.11 as follows:

NR 210.11 Monitoring. (1) Except as provided in subsection (2) of this section, discharges from sewage treatment works subject to the provisions of this chapter, other than from aerated lagoons and stabilization ponds, shall be monitored daily for pH and twice weekly for fecal coliform bacteria using grab samples and, for classes of such works as defined in Wis. Adm. Code chapter NR 214,

(a) Daily for BOD₅ and suspended solids using a 24 hour composite sample in Class I and Class II treatment works, and

(b) Three times weekly for BOD₅ and suspended solids using a 3 hour composite sample in Class III and Class IV treatment works.

(2) The department may in issuing WPDES permits for such Class III and Class IV treatment works specify either more or less frequent monitoring than set forth in subsection (1) above if it determines that such monitoring is necessary or adequate to characterize the effluent and to insure compliance with effluent limitations of the permit or water quality standards in the receiving water.

(3) Discharges from aerated lagoons subject to the provisions of this chapter shall as a minimum be monitored daily for pH and weekly for BOD₅, suspended solids and fecal coliform bacteria using grab samples.

(4) Discharges from stabilization ponds subject to the provisions of this chapter shall as a minimum be monitored weekly for pH, twice monthly for BOD₅ and suspended solids, and twice quarterly for fecal coliform bacteria using grab samples.


The foregoing rules were approved and adopted by the State of Wisconsin Natural Resources Board on December 20, 1974.

The rules contained herein shall take effect upon publication in the official state newspaper.

Dated at Madison, Wisconsin this 5th day of June, 1975

STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES

By



L. P. Voigt, Secretary

(SEAL)