

HEALTH AND SOCIAL SERVICES

279

(a) A letter of past business contact from each of the following: a general contractor, customer, architect or engineer and approving agency (insurance company).

(b) A list of 5 installations of automatic fire sprinkler systems installed in a one-year period prior to March 1, 1967, with the following items included for each specific installation listed.

1. Installation hours per job and number of sprinkler heads installed in each system. Sprinkler heads taken off domestic water supply shall not qualify.

2. Approval agency for each installation listed.

3. Other information the department may require.

(2) **APPLICATION.** The individual making application or writing the examination for the automatic fire sprinkler contractor license shall be a principal or officer of the firm who shall be knowledgeable and responsible for the design, installation and certification of all automatic fire sprinkler systems or portions of systems installed by the licensed contractor.

(3) **QUALIFICATION.** The individual which has qualified the contractor for licensure shall remain as a principal or officer of the firm. Upon separation for any reason from the contractor's employ, the firm shall be required to have his replacement show evidence of qualifications by application to the department and register this change with the department within 90 days. Where deemed necessary, the department may require a written or oral examination to determine the qualification of the applicant. An individual may qualify not more than one automatic fire sprinkler contractor at any one time.

(4) **REGISTRATION.** The automatic fire sprinkler contractor shall register with the department, on forms furnished by the department, the principal or officer who qualifies the contractor for licensure.

History: Cr. Register, October, 1975, No. 238, eff. 11-1-75.

H 63.04 Examinations. (1) **LICENSE EXAMINATION.** Not less than 2 automatic fire sprinkler examinations for the licensing of journeyman and automatic fire sprinkler contractors will be conducted annually at such time and place as the department may direct. An apprentice is eligible to make application for examination 90 days prior to the expiration and completion date of the indentured apprenticeship. License shall be issued upon receipt of a passing grade in the examination and expiration of the apprenticeship tenure. Application forms for examination for licensure and renewal of licenses may be obtained from the department.

(2) **DATE OF FILING APPLICATION.** All applications for examination shall be on file in the office of the section of plumbing and fire protection systems at least 4 weeks prior to the date of examination. Failure to have the application on file within the required time shall necessitate postponement of the applicant's appearance to the next examination. All applications shall expire after a period of one year from the date of filing.

*Emergency
Order
11-1-75*

(3) FEES. (a) Fees for the examinations and licenses are regulated by section 145.08, Wis. Stats. No fees shall be returned after an applicant has appeared for examination.

(b) A fee of \$5 shall be paid at the time of registration and for each subsequent year during which he is engaged in his apprenticeship prior to January 1, to cover administration costs.

(4) NOTICE OF EXAMINATION TO APPLICANTS. Notice of the time and place of examination shall be sent by first class mail to those who have approved applications on file. Such notice shall be mailed to the address given on the application blank and shall be presented by the applicant to gain admittance to the examination room. Failure to receive the notice due to change in address shall not be the responsibility of the department.

(5) CHARACTER OF EXAMINATIONS. (a) The examinations shall be conducted by the committee of examiners. They shall consist of written tests and may be practical or oral in part. The examination will cover the theory and practice of automatic fire sprinkler systems, the interpretation of charts and blueprints and plans of automatic fire sprinkler installations, and such other tests as the committee may deem necessary to properly pass upon the qualifications of the candidate.

(b) Applicants shall participate in all portions of the examination and shall acquire a passing grade of 75%. Applicants who fail to acquire a passing grade will be required to rewrite the complete examination.

(6) MATERIALS USED IN EXAMINATION. Applicants shall furnish the necessary tools and material for the examination as requested by the examiners.

(7) REEXAMINATION. Applicants failing an initial examination may be reexamined within 3 months. Applicants shall not be eligible for a second reexamination until the expiration of 6 months after the first reexamination, and not for the third and subsequent reexaminations until the expiration of one year after the last reexamination.

History: Cr. Register, October, 1975, No. 238, eff. 11-1-75.

H 63.05 Temporary permits. Temporary permits shall become void upon the date of the first examination following issuance of permit and shall be surrendered to the department. Not more than 2 permits shall be issued to an individual or contractor in any 12-month period or no more than 3 permits shall be issued in a 5-year period. Applicants for temporary permits shall comply with all other applicable rules and statutes.

History: Cr. Register, October, 1975, No. 238, eff. 11-1-75.

H 63.06 License renewal. (1) ANNUAL NOTICE FOR RENEWAL OF LICENSES. Notice for the renewal of licenses shall be sent to all journeyman automatic fire sprinkler fitters and automatic fire sprinkler system contractors, whose licenses were in force during the previous year, to the address given on the latest license renewal blank on file unless notice of another address is given. Failure to receive the notice for renewal of license shall not be an excuse for failure to renew.

(2) **DELINQUENT OR ELAPSED LICENSES.** Whenever a journeyman automatic fire sprinkler fitter or contractor fails to renew his license for a period of 2 years, the department shall require evidence to show that he is competent to perform the work of either a contractor or journeyman fire sprinkler fitter before such license is renewed.

History: Cr. Register, October, 1975, No. 238, eff. 11-1-75.

H 63.07 Allowable maintenance. Weekly or monthly test of sprinkler alarm equipment, weekly or monthly test of fire pumps, valves, appurtenances and refilling of storage and pressure tanks shall not require licensure under chapter 145, Wis. Stats. Maintenance personnel may replace automatic fire sprinkler heads under emergency conditions.

History: Cr. Register, October, 1975, No. 238, eff. 11-1-75.