

## Chapter Ind 56

### SCHOOLS AND OTHER PLACES OF INSTRUCTION

Ind 56.001 Scope (p. 191)	Ind 56.32 General (p. 199)
Ind 56.01 Maximum height (p. 191)	Ind 56.33 Anchoring requirements (p. 199)
Ind 56.02 Classes of construction (p. 191)	Ind 56.34 Exit doors and exit lights (p. 199)
Ind 56.03 Protection of basement levels (p. 192)	Ind 56.35 Subdivisions and fire stops (p. 199)
Ind 56.05 Exterior wall openings (p. 192)	Ind 56.36 Barrier-free requirements (p. 199)
Ind 56.06 Exits (p. 193)	Ind 56.37 Sanitary fixtures (p. 200)
Ind 56.07 Required-exit width (p. 195)	Ind 56.38 Fire alarms (p. 200)
Ind 56.08 Exit doors (p. 195)	Part III—Mobile Training Classrooms
Ind 56.09 Passageways (p. 196)	Ind 56.40 Scope (p. 200)
Ind 56.13 Auditoriums, gymnasiums and field houses (p. 196)	Ind 56.41 Definitions (p. 200)
Ind 56.14 Seats, desks and aisles (p. 197)	Ind 56.42 General (p. 200)
Ind 56.15 Isolation of hazards (p. 197)	Ind 56.43 Exit doors and exit lights (p. 200)
Ind 56.16 Sanitary facilities (p. 197)	Ind 56.44 Barrier-free requirements (p. 200)
Ind 56.17 Lighting (p. 198)	Ind 56.45 Sanitary fixtures (p. 200)
Ind 56.18 Fire extinguishers (p. 198)	Ind 56.46 Fire alarms (p. 201)
Ind 56.19 Fire alarms (p. 199)	
Ind 56.20 Standpipes (p. 199)	
Part II—Relocatable Classrooms	
Ind 56.30 Scope (p. 199)	
Ind 56.31 Definitions (p. 199)	

**Ind 56.001 Scope.** The requirements of this chapter shall apply to all public and private schools, universities, colleges, academies, seminaries, libraries, museums and art galleries; including all buildings or parts of buildings used primarily for instructional purposes.

**Note:** Section 101.02 (15) (a), Stats., exempts rural school buildings from the provisions of this code. See s. Ind 51.01 (114a) for definition of a rural school building.

**History:** 1-2-56; am. Register, May, 1971, No. 185, eff. 6-1-71; am. Register, December, 1977, No. 264, eff. 1-1-78; am. Register, January, 1980, No. 289, eff. 2-1-80.

**Ind 56.01 Maximum height.** (1) Buildings occupied primarily by pupils up to and including grade 12 shall not exceed 4 stories or 48 feet in height.

(a) *Exception.* Buildings provided with complete automatic sprinkler or automatic smoke detection systems, occupied primarily by students of grades 9 through 12, shall be no more than 6 stories or 72 feet in height.

**Note:** Also see requirements for classes of construction.

**History:** 1-2-56; r. Register, May, 1971, No. 185, eff. 6-1-71; cr. Register, September, 1973, No. 213, eff. 10-1-73.

**Ind 56.02 Classes of construction.** (1) Every building not more than one story in height may be of type No. 7 or No. 8 construction as specified in section Ind 51.03.

(2) Every 2-story building shall be not less than type No. 6 construction as specified in section Ind 51.03 with the exception that all floors and their supports shall be at least noncombustible one-hour fire-resistive rating.

Register, May, 1980, No. 293  
Building and heating, ventilating  
and air conditioning code

(3) Every building 3 or more stories in height shall be of type No. 1 or No. 2 construction as specified in section Ind 51.03.

(4) Auditoriums, gymnasiums or field houses, or those parts of buildings similarly used, shall comply with the following:

(a) Limitations when occupancy is restricted to first story or ground floor only.

Type of Construction	Maximum Number of Occupants in Any Room Used for Auditorium, Gymnasium, or Field House Purposes	
	With Stage	Without Stage
Type No. 1 and No. 2	No limit	No limit
Type No. 3 and No. 4	750	1500
Type No. 5 and No. 6	500	1000
Type No. 7 and No. 8	300	750

1. Exception. For unlimited capacity, the fire protection of structural steel supporting the roof may be omitted for one-story buildings meeting type No. 1, 2 and 3 construction provided the building has no ground or basement floors. Heavy timber columns and roof framing may be substituted for structural steel framing. The roof decking shall be of noncombustible or heavy timber construction.

(b) Limitations when occupancy is above the first story.

Type of Construction	Maximum Number of Occupants	No. of Stories
Type No. 1 and No. 2	No limit	See Ind 56.01†
Type No. 3 thru No. 6	400	2nd story
Type No. 3 thru No. 6	200	3rd and 4th story

†One smokeproof stair tower from the level of the assembly hall leading directly to the exterior at street grade shall be provided for every 750 persons capacity, or fraction thereof. These stairways shall be at least 44 inches wide and shall be in addition to other required stairways in the building.

**History:** 1-2-56; r. and recr. Register, May, 1971, No. 186, eff. 6-1-71; am. (1) and (2) and r. and recr. (3), Register, June, 1972, No. 198, eff. 1-1-73; cr. (4), Register, September, 1973, No. 213, eff. 10-1-73; r. and recr. (4) (a) 1., Register, May, 1974, No. 221, eff. 6-1-74; am. (4) (a) 1., Register, December, 1978, No. 276, eff. 1-1-79.

**Ind 56.03 Protection of basement levels.** Buildings with basements shall at such levels be protected with an approved automatic sprinkler system (Ind 51.23) or an approved automatic smoke detection system, either of which shall be electrically connected to the required fire alarm (Ind 56.19).

**Note:** See section Ind 51.01 for definitions of "automatic" and "basement."

**History:** Cr. Register, January, 1980, No. 289, eff. 2-1-80.

**Ind 56.05 Exterior wall openings.** (1) One-story buildings with no floor levels below the first floor need not be provided with exterior wall openings other than required exits.

(2) Buildings more than one story shall be provided with wall openings for emergency purposes above the first story as specified in section Ind 52.02 (2) except as follows:

Register, May, 1980, No. 293  
Building and heating, ventilating  
and air conditioning code