

State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

Anthony S. Earl Secretary

BOX 7921 MADISON, WISCONSIN 53707

			IN REPLY REFER TO:
STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES)	SS	JUL 25 1980

TO ALL TO WHOM THESE PRESENTS SHALL COME, GREETINGS:

I, Anthony S. Earl, Secretary of the Department of Natural Resources and custodian of the official records of said Department, do hereby certify that the annexed copy of Natural Resources Board Order No. WQ-3-79a was duly approved and adopted by this Department on June 28, 1979. I further certify that said copy has been compared by me with the original on file in this Department and that the same is a true copy thereof, and of the whole of such original.

> IN TESTIMONY WHEREOF, I have hereunto set my hand and affixed the official seal of the Department at General Executive Facility #2 in the City of Madison, this 25th day of July

(SEAL)

Tent. eff. date 9. 1. 80.

ORDER OF THE STATE OF WISCONSIN NATURAL RESOURCES BOARD

AMENDING RULES

IN THE MATTER of amending section
NR-112.15(8)(b)1.c. of the Wisconsin
Administrative Code pertaining to
injection of pesticides into the
well discharge pipe of an irrigation
system

WQ-3-79a

Analysis Prepared by Department of Natural Resources

Section NR 112.15(8)(b)1.c., Wisconsin Administrative Code, is being amended to correct a typographical error contained in the previous order amending section NR 112.15(8)(b), Wis. Adm. Code, permitting the injection of pesticides into the well discharge pipe of an irrigation system. The sentence "Injection of pesticides into the well pump discharge line is prohibited" was inadvertently allowed to remain in the rule rather than being deleted as is necessary for the implementation of the intended amendment.

Pursuant to the authority vested in the State of Wisconsin Natural Resources Board by sections 162.01, 162.03(1)(e) and 227.014, Wisconsin Statutes, the State of Wisconsin Natural Resources Board hereby amends rules interpreting sections 144.025(2)(c) and 144.025(2)(e), and 162.01, Wisconsin Statutes, as follows:

SECTION 1 - Section NR 112.15 (8) (b) 1.c. is amended to read:

c. Injection of fertilizer into the well pump discharge pipe is acceptable, providing it is done with an approved positive displacement type of chemical feed pump at a point following a barometric pipe loop extending at least 30 feet above the highest part of the irrigation system; or a reduced pressure backflow preventer made to and meeting AWWA C506-78 or ASSE 1013 standards; or an underwriters laboratories (UL) approved check valve and preferably a

double UL check valve installed in the well pump discharge pipe at the well site. The chemical feed pump shall be shut off at least 5 minutes prior to shutting off of the well pump so as to purge the chemical from the water system. Injection-of-posticides-into-the-well-pump-discharge-line-is prohibited.

The foregoing rules were approved and adopted by the State of Wisconsin Natural Resources Board on June 28, 1979.

The rules contained herein shall take effect upon publication as provided in section 227.026(1) intro., Wisconsin Statutes.

D-4-3		W- 37 - :		July 25, 1980
Dared	at	Madison,	Wisconsin	

STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES

Anthony S. Farl, Secretary

(SEAT.)



State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

Anthony S. Earl Secretary


BOX 7921 MADISON, WISCONSIN 53707

July 24, 1980

IN REPLY REFER TO:

1020

Mr. Orlan L. Prestegard Revisor of Statutes 411 West C A P I T O L



Dear Mr. Prestegard:

Enclosed are two copies, including one certified copy, of State of Wisconsin Natural Resources Board Order No. WQ-3-79a. These rules were reviewed by the Assembly Environmental Resources Committee and the Senate Natural Resources and Tourism Committee pursuant to section 227.018, Wisconsin Statutes. There were no objections.

You will note that this order takes effect upon publication. Kindly publish it in the Administrative Code accordingly.

Sincerely,

Secretary S. Kari

Enc.