

Chapter Comm 66

APPENDIX

The material contained in this Appendix is for clarification purposes only and is numbered to correspond to the number of the rule as it appears in the text of the code.

A-66.04 (1) (e) Lower thresholds for municipalities with preexisting stricter sprinkler ordinances. Section 101.14 (4m) (d) and (e), Stats, provides the following thresholds above which fire sprinklers or two-hour fire resistance can be required by a municipality with a preexisting stricter sprinkler ordinance.

| Class of Construction | Total Floor Area Within Individual Dwelling Units | Number of Units | Total Floor Area of Nondwelling Unit Portions (Common use areas, such as corridors, stairways, basements, cellars, vestibules, community rooms, laundry rooms, pools, etc.) |
|---|---|-----------------|---|
| Type 1 – Fire resistive Type A | 8,000 sq ft. | 8 units | 12,000 sq ft. |
| Type 2 – Fire Resistive Type B | | | 10,000 sq ft. |
| Type 3 – Metal Frame Protected | | | 8,000 sq ft. |
| Type 4 – Heavy Timber Type 5A – Masonry Protected Type 5B – Masonry Unprotected Type 6 – Metal Frame Unprotected Type 7 – Wood Frame Protected Type 8 – Wood Frame Unprotected | | | 5,600 sq ft. |
| | | | 4,800 sq ft. |
| | | | |
| | | | |
| | | | |

The department believes the following municipalities have a preexisting stricter sprinkler ordinance:

| | | | |
|------------|-----------------|------------|-----------------|
| Appleton | Greenfield | Muskego | Shorewood Hills |
| Brookfield | Madison | New Berlin | Sussex |
| Franklin | Menomonee Falls | Oak Creek | West Allis |
| Greendale | Monona | Racine | West Bend |