

Chapter E 514

GASOLINE DISPENSING AND SERVICE STATIONS

E 514.01	Definitions	E 514.04	Wiring and equipment above hazardous areas
E 514.02	Hazardous areas	E 514.05	Circuit disconnects
E 514.03	Wiring and equipment within hazardous areas	E 514.06	Sealing
		E 514.07	Grounding

E 514.01 Definitions. (1) This classification shall include locations where gasoline or other volatile flammable liquids or liquefied flammable gases are transferred to the fuel tanks (including auxiliary fuel tanks) of self-propelled vehicles.

(2) Other areas used as lubratoriums, service rooms and repair rooms, and offices, salesrooms, compressor rooms and similar locations shall conform to chapter E 511 with respect to electrical wiring and equipment.

Note 1: Where the authority enforcing the code can satisfactorily determine that flammable liquids having a flash point below 100° F such as gasoline will not be handled, he may classify such an area as non-hazardous.

Note 2: For further information regarding safeguards for gasoline dispensing and service stations see NFPA Flammable Liquids Code (No. 30).

History: Cr. Register, April, 1964, No. 100, eff. 5-1-64.

E 514.02 Hazardous areas. (1) The area enclosed within the dispenser and extending 18 inches in all directions from the enclosure of the dispenser shall be considered a class I, division 1 location which shall extend upward to a level of 4 feet above adjacent driveway level, and which shall include any space within or under this area which may contain electrical wiring or equipment.

(2) In an outside location, any area (excluding class I, division 1, but including buildings not suitably cut off) within 20 feet horizontally from the exterior enclosure of any dispensing pump shall be considered class I, division 2 location which will extend to a level 18 inches above driveway or ground level.

(3) In an outside location, any area (excluding class I, division 1, but including buildings not suitably cut off) within 10 feet horizontally from any tank fill-pipe shall be considered class I, division 2 location which shall extend upward to a level 18 inches above driveway or ground level.

(4) Electrical wiring and equipment, any portion of which is below the surface of areas defined as class I, division 1 or division 2 in subsections E 514.02 (1), (2), (3) above shall be considered to be a class I, division 1 location which shall extend at least to the point of emergence.

(5) The spherical volume within a 3 foot radius from point of discharge of any tank vent pipe shall be considered a class I, division 1 location and for any vent that does not discharge upward the cylindrical volume below the division 1 location extending to ground shall be considered class I, division 2 location. The volume between a 3 feet to 5 feet radius from point of discharge of a vent shall be considered a class I, division 2 location. The hazardous area shall not extend beyond an unpierced wall.

History: Cr. Register, April, 1964, No. 100, eff. 5-1-64.

E 514.03 Wiring and equipment within hazardous areas. All electrical equipment and wiring within the hazardous areas defined in section E 514.02 shall conform to applicable provisions of chapter E 501.

Note: For special requirements for conductor insulation, see section E 501.13.

History: Cr. Register, April, 1964, No. 100, eff. 5-1-64.

E 514.04 Wiring and equipment above hazardous areas. Wiring and equipment above hazardous areas defined in section E 514.02 shall conform to sections E 511.05 and E 511.06.

History: Cr. Register, April, 1964, No. 100, eff. 5-1-64.

E 514.05 Circuit disconnects. Each circuit leading to or through a dispensing pump shall be provided with a switch or other acceptable means to disconnect simultaneously from the source of supply all conductors of the circuit including the grounded neutral, if any.

History: Cr. Register, April, 1964, No. 100, eff. 5-1-64.

E 514.06 Sealing. (1) An approved seal shall be provided in each conduit run entering or leaving a dispensing pump or other enclosure located in a class I, division 1 or division 2 location when the connecting conduit originates in a nonhazardous location. There shall be no union, coupling, box or fitting in the conduit between the sealing fitting and the point at which the conduit emerges into the pump or other equipment, or into any cavities or enclosures in direct communication therewith.

Note: This paragraph states that the first fitting after the conduit emerges from the slab or from the concrete must be the sealing fitting. Above the fitting, the remainder of the wiring and equipment is required to conform to the rules for the area classification involved.

(2) Additional seals shall be provided in conformance with section E 501.05 and subsections E 501.05 (1) (c) and E 501.05 (2) (b) shall apply to horizontal as well as to vertical boundaries of the defined hazardous areas.

History: Cr. Register, April, 1964, No. 100, eff. 5-1-64.

E 514.07 Grounding. Metallic portions of dispensing pumps, metallic raceways, and all non-current-carrying portions of electrical equipment, regardless of voltage, shall be grounded as provided in chapter E 250.

History: Cr. Register, April, 1964, No. 100, eff. 5-1-64.