## Chapter Ind 55

## THEATERS AND ASSEMBLY HALLS

Ind 55.001	Theaters	Ind 55.35	Automatic sprinklers
Ind 55.01	Assembly halls	Ind 55.39	Use of "safety-base" film
Ind 55.02	Class of construction		Motion picture machine
Ind 55.03	Height above grade	Lind Doilly	booths, general
Ind 55 04	Exposure and courts	Ind 55.41	Construction of booth
Ind 55.05	Separation from other	Ind 55.42	Doors
1110 00:00		Ind 55.43	
Ind EF DO	occupancies		Openings Ventilation of booths
Ind 55.06	Capacity	Ind 55.44	Ventilation of booths
Ind 55.07	Number and location of	Ind 55.45	Relief outlets
T	exits	Ind 55.46	Electric wiring
Ind 55.08	Type of exits		Motion picture machine
Ind 55.09	Stairways	Ind 55.48	Fire protection in booth;
Ind 55.10	Exit doorways and doors		care and use of film
Ind 55.11	Exit lights	Ind 55.49	Portable booths
Ind 55.12	Width of exits Seating Width of aisles Lobbies and foyers Inclines and aisle steps Obstruction Mirrors and false open-	Ind 55.50	Maintenance
Ind 55.13	Seating	Ind 55.51	Grandstands
Ind 55.14	Width of aisles	Ind 55.52	Exits
Ind 55.15	Lobbies and fovers	Ind 55.53	Aisles and passageways
Ind 55.16	Inclines and sisle steps	Ind 55.54	Seating
Ind 55.17	Obstruction	Ind 55 55	Guard rails
Ind 55,18	Mirrors and false open-	Ind 55.56	Portable grandstands or
	ings	1110 00:00	bleachers
Ind 55.19	Decorations	Ind 55.57	Inspection
Ind 55.20	Elevator and want shafts	T 3 EF ED	Tents
Ind 55.21	Store concustion	100 00.00	
Ind 55.22	Diage separation	Inu 00.09	Structural requirements
Ind 55.22	Proseenium wall	ina 55.60	Flame resistance
	Proscenium curtain	ing 55.61	Fire hazards
Ind 55.24	Stage separation Proscenium wall Proscenium curtain Automatic smoke outlet Stage vestibules Foolight trough	Ind 55.62	Exits
Ind 55.25	Stage vestibules	Ind 55.63	Electrical installations
Ind 55.26	Footlight trough	Ind 55.64	Fire extinguishing
Ind 55.27	rneproor paint		equipment
Ind 55.28	Stage accessory rooms	Ind 55.65	Illumination : exit lights
Ind 55.29	Boiler and furnace		and signs
	rooms	Ind 55.66	Boiler and furnace
Ind 55.30	Lights and lighting		room
Ind 55.32	Sanitary equipment	Ind 55.67	Toilet facilities
Ind 55.33	Standpipes	Ind 55.68	Outdoor theaters
Ind 55.84	Fire extinguishers		C GUGOVA VILVEDUVAR
	OFFICE ADDITOLD		

Ind 55.001 Theaters. In the theater classification, are included all buildings or parts of buildings, containing an assembly hall, having a stage which may be equipped with curtains or permanent or movable scenery, or which is otherwise adaptable to the showing of plays, operas, motion pictures or similar forms of entertainment.

Ind 55.01 Assembly halls. (1) In the assembly hall classification are included all buildings, or parts of buildings, other than theaters, which will accommodate more than 100 persons for entertainment, recreation, worship or dining purposes.

Note: For assembly areas in connection with schools and other places of instruction, refer to Wis. Adm. Code chapter Ind 56. (a) Every assembly hall which will accommodate not more than

(a) Every assembly hall which will accommodate not more than 100 persons shall conform to the requirements of Wis. Adm. Code chapter Ind 54, covering factories, office and mercantile buildings. History: 1-2-56; am. (1) (intro. par.), Register, March, 1972, No. 195, eff. 4-1-72.

Ind 55.02 Class of construction. (1) The capacities of buildings or parts of buildings in this classification for the various types of con-

> Register, May, 1974, No, 221 Building and heating, ventilating and air conditioning code

WISCONSIN ADMINISTRATIVE CODE

Theaters, assembly halls

struction shall not exceed, and shall comply with, the following requirements:

## MAXIMUM CAPACITIES

Type of Construction	With Stage	Without Stage
Type No. 1 and No. 2		No limit
Type No. 3 and No. 4	750	1,500
Type No. 5 and No. 6	500	1,000
Type No. 7 and No. 8	300	750

(a) Exception. One-story buildings are permitted for unlimited capacities providing the following conditions are satisfied:

1. The class of construction requirements satisfy Type No. 3, 4 or 6.

2. There are no ground floors or basements.

3. The setback satisfies the requirements of Table 51.03-A for over 30 feet distance.

(2) Type No. 7 and No. 8 construction. (See Ind 51.03.) Where buildings of these classifications are erected of Type No. 7 or No. 8 construction, the following restrictions shall apply:

(a) Not more than one story in height without a balcony, and with no ground floor or basement except a heating and fuel room enclosed with fire-resistive construction as specified in section Ind 55.29, with all interior openings protected with self-closing fire-resistive doors as specified in section Ind 51.047.

(b) Located at least 20 feet from any other building or adjoining property line.

(c) Is not built in connection with a building used for any other purpose.

(d) Is provided with foundation walls and piers of masonry construction.

(e) Where motion picture booths are required, they shall be enclosed with 2-hour fire-resistive construction.

*Exception:* In places of worship, a full basement and a balcony seating not more than 30 persons may be provided.

(3) Balconies accommodating more than 100. In any theater or assembly hall, balconies which accommodate more than 100 persons shall be of Type No. 1 or No. 2 construction as specified in section Ind 51.03.

History: 1-2-56; (1); (1) (a); (2); (2) (a); (2) (b); (2) (c); (2) (d); (2) (e); (2) (f); (3); am. Register, June, 1956; No. 6, eff. 7-1-56; am. (1) (a), Register, August, 1957, No. 20, eff. 9-1-57; am. Register, January, 1961, No. 61, eff. 2-1-61; am. (2) (a), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (2) (a) eff. 8-1-71 and exp. 1-1-72; cr. (2) (a) eff. 1-1-72, Register, July, 1971, No. 187; r. and recr. (1), am. (2) intro, par, and (3), Register, June, 1972, No. 198, eff. 1-1-73; cr. (1) (a), Register, September, 1973, No. 213, eff. 10-1-73; am. (2) (a), Registter, May, 1974, No. 221, eff. 6-1-74.

Ind 55.03 Height above grade. (1) THEATERS. The height of the sills of the principal entrance doors to any theater, as defined in section Ind 55.001, shall be not more than 18 inches above the outside grade at that point. The floor level at the highest row of seats on the main floor shall not be more than 6 feet above the outside grade at the main entrance; the floor level at the lowest row of seats on

Register, May, 1974, No. 221 Building and heating, ventilating and air conditioning code

112