DEPT. OF INDUSTRY, LABOR & HUMAN RELATIONS 111 Theaters, assembly halls

Chapter Ind 55

THEATERS AND ASSEMBLY HALLS

Inđ	55.001	Theaters	Ind 55.35	Automatic sprinklørs
Ind	55.01	Assembly halls	Ind 55.39 Ind 55.40	Use of "safety-base" film
	55.02	Class of construction	Ind 55.40	Motion picture machine
Ind	55,08	Height above grade	a ser e regere	booths, general
Ind	55 04		Ind 55.41	Construction of booth
	55.05	Separation from other		Doora
		ogginno oglag	TnA 5548	Openings
Ind	55.06	Capacity	Ind 55.44	Ventilation of booths
	55.07	Number and location of		Relief outlets
		exite	Ind 5546	Electric wiring
Ind	55.08	Type of exits	Ind 55.47	Motion picture machine
	55.09	Stalrways	Ind 55.48	Fire protection in booth;
	55.10	Exit doorways and doors		care and use of film
	55.11	Exit lights	Ind 55.49	Portable booths
	55.12	Width of exits	Ind 55 50	Maintenance
	55.13	Exit lights Width of exits Seating	Ind 55 51	Grandstands
	55.14	Width of sisles	Ind 55 52	Exits
	55.15	Width of aisles Lobbies and foyers	Ind 55 53	Aisles and passageways
	55.16	Inclines and aisla stens	Ind 55 54	Seating
Ind	55.17	Inclines and aisle steps Obstruction Mirrors and false open-	Ind 55 55	Guard rails
	55.18	Mirrors and false open-	Ind 55 56	Portable grandstands or
		ings	1111 00100	bleachers
Ind	55.19	Decorations	Ind 55.57	Inspection
	55.20	Elevator and vent shafts	Ind 55 58	Tents
	55.21	Stage separation Proscenium wall	Ind 55 59	Structural requirements
	55.22	Proscenium well	Ind 55 60	Flame resistance
	55.23	Proscenium curtain	Ind 55.61	Fire hazards
	55.24	Automatic smoke outlet	Ind 55 62	Ēxits
	55.25	Stage vestibules	Ind 55.63	Electrical installations
	55.26	Footlight trough	Ind 55.63 Ind 55.64	Fire extinguishing
Ind	55.27	Fireproof paint	Ind DOVOT	equipment
	55.28	Stage accessory rooms	Ind 55.65	Illumination; exit lights
	55.29	Boiler and furnace	Ing 00.00	and signs
	00120	rooms	Ind 55.66	
Ind	55.30	Lights and lighting	THU 00.00	room
	55.32	Sanitary equipment	Tnd 55 87	Toilet facilities
	55.33	Standpipes	Ind 55.68	Outdoor theaters
	55.34	Fire extinguishers	TUG 00.00	CULTON FILCEFOLD
		THO WANDERDIGIE		

Ind 55.001 Theaters. In the theater classification, are included all buildings or parts of buildings, containing an assembly hall, having a stage which may be equipped with curtains or permanent or movable scenery, or which is otherwise adaptable to the showing of plays, operas, motion pictures or similar forms of entertainment.

Ind 55.01 Assembly halls. (1) In the assembly hall classification are included all buildings, or parts of buildings, other than theaters, which will accommodate more than 100 persons for entertainment, recreation, worship or dining purposes.

Note: For assembly areas in connection with schools and other places of instruction, refer to Wis. Adm. Code chapter Ind 56.

(a) Every assembly hall which will accommodate not more than 100 persons shall conform to the requirements of Wis. Adm. Code chapter Ind 54, covering factories, office and mercantile buildings. History: 1-2-56; am. (1) (intro. par.), Register, March, 1972, No. 195, eff. 4-1-72.

WISCONSIN ADMINISTRATIVE CODE Theaters, assembly halls

Ind 55.02 Class of construction. (1) The capacities of buildings or parts of buildings in this classification for the various types of construction shall not exceed, and shall comply with, the following requirements:

MAXIMUM CAPACITIES

Type of Construction	With Stage	Without Stage
Type No. 1 and No. 2		Nolimit
Type No. 3 and No. 4		1,500
Type No. 5 and No. 6	500	1,000
Type No. 7 and No. 8	300	750

(a) *Exception*. One-story buildings are permitted for unlimited capacities providing the following conditions are satisfied:

1. The class of construction requirements satisfy Type No. 3, 4 or 6.

2. There are no ground floors or basements.

3. The setback satisfies the requirements of Table 51.03-A for over 30 feet distance.

(2) Type No. 7 and No. 8 construction. (See Ind 51.03.) Where buildings of these classifications are erected of Type No. 7 or No. 8 construction, the following restrictions shall apply:

(a) Not more than one story in height without a balcony, and with no basement except a heating and fuel room enclosed with fireresistive construction as specified in section Ind 55.29, with all interior openings protected with self-closing fire-resistive doors as specified in section Ind 51.047.

(b) Located at least 20 feet from any other building or adjoining property line.

(c) Is not built in connection with a building used for any other purpose.

(d) Is provided with foundation walls and piers of masonry construction.

(e) Where motion picture booths are required, they shall be enclosed with 2-hour fire-resistive construction.

Exception: In places of worship, a full basement and a balcony seating not more than 30 persons may be provided.

(3) Balconies accommodating more than 100. In any theater or assembly hall, balconies which accommodate more than 100 persons shall be of Type No. 1 or No. 2 construction as specified in section Ind 51.03.

History: 1-2-56; (1); (1) (a); (2); (2) (a); (2) (b); (2) (c); (2) (d); (2) (e); (2) (f); (3); am. Register, June, 1956; No. 6, eff. 7-1-56; am. (1) (a), Register, August, 1957, No. 20, eff. 9-1-57; am. Register, January, 1981, No. 61, eff. 2-1-61; am. (2) (a), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (2) (a) eff. 8-1-71 and exp. 1-1-72; cr. (2) (a) eff. 1-1-72; Register, July. 1971. No. 187: r. and recr. (1), am. (2) intro. par., and (3), Register, June, 1972, No. 198, eff. 1-1-73; cr. (1) (a), Register, September, 1973, No. 213, eff. 10-1-73.

Ind 55.03 Height above grade. (1) THEATERS. The height of the sills of the principal entrance doors to any theater, as defined in section Ind 55.001, shall be not more than 18 inches above the outside grade at that point. The floor level at the highest row of seats on the main floor shall not be more than 6 feet above the outside grade at the main entrance; the floor level at the lowest row of seats on

Register, September 1973, No. 213 Building and heating, ventilating and air conditioning code

112