Chapter Ind 55

THEATERS AND ASSEMBLY HALLS

ſ

Ind 55.001	Theaters	Ind 55.35	Automatic sprinklers
Ind 55.01	Assembly halls	Ind 55.39	Use of "safety-base" film
Ind 55.02	Class of construction	Ind 55.40	Motion picture machine
Ind 55.03	Height above grade	1	booths, general
Ind 55 04	Exposure and courts	Ind 55.41	Construction of booth
Ind 55.05	Separation from other		Doors
1114 00.00	occupancies	Ind 55.43	Openings
Ind 55.06	Capacity	Ind 55.44	Ventilation of booths
Ind 55.07	Number and location of		Relief outlets
114 00.01	exits	Ind 55.46	Electric wiring
Ind 55.08	Type of exits	Ind 55.47	Motion picture machine
Ind 55.09	Staliways	Ind 55.48	Fire protection in booth ;
Ind 55.10	Exit doorways and doors	110 00.10	care and use of film
Ind 55.11	Tivit Hahta	Ind 55.49	Portable booths
Ind 55.12	Width of orita	Ind 55.50	Maintenance
Ind 55.13	Seating	Ind 55.51	Grandstands
Ind 55.14	Width of sigles	Ind 55 52	Exits
Ind 55.15	Width of exits Seating Width of aisles Lobbles and foyers Inclines and aisle steps Obstruction Mircore and folse open-	Ind 55 53	Aisles and passageways
Ind 55.16	Inclines and sisle store	Ind 55 54	Seating
Ind 55.17	Obstruction	Ind 55.55	Guard rails
Ind 55.18	Mirrors and false open-	Ind 55.56	Portable grandstands or
Ma 00.10	ings	1110 00.00	bleachers
Ind 55.19	Decorations	Ind 55.57	Inspection
Ind 55.20	Elevator and vent shafts		Tents
Ind 55.21	Diama aspanalian	Tod FEEO	Structural requirements
Ind 55.22	Stage separation Proscenium wall Proscenium curtain Automatic smoke outlet Stage vestibules Foollight trough Fireproof paint	Ind 55.60	Flame resistance
Ind 55.23	Progranting ountain	Ind 55.61	Fire hazards
Ind 55.24	Automatic smoke outlet	Ind 55.62	Exits
Ind 55.25	Stage vestibules	Ind 55.63	Electrical installations
Ind 55.26	Footlight trough	Ind 55.64	Fire extinguishing
Ind 55.27	Fireproof paint	110 00.01	equipment
Ind 55.28	Stage accessory rooms		Illumination ; exit lights
Ind 55.29	Boiler and furnace	1114 00.00	and signs
144 00.40	rooms	Ind 55.66	Boiler and furnace
Ind 55.30	Lights and lighting	TUG 00:00	room
Ind 55.32	Sanitary equipment	Ind 55.67	
Ind 55.83	Standpipes	Ind 55.68	Outdoor theaters
Ind 55.84	Fire extinguishers	TUG 00.00	CALADI HICALCIS
1.1.4 00,01	THE OTHERBUSIELS		

Ind 55.001 Theaters. In the theater classification, are included all buildings or parts of buildings, containing an assembly hall, having a stage which may be equipped with curtains or permanent or movable scenery, or which is otherwise adaptable to the showing of plays, operas, motion pictures or similar forms of entertainment.

Ind 55.01 Assembly halls. (1) In the assembly hall classification are included all buildings, or parts of buildings, other than theaters, which will accommodate more than 100 persons for entertainment, recreation, worship or dining purposes.

Note: For assembly areas in connection with schools and other places of instruction, refer to Wis. Adm. Code chapter Ind 56. (a) Every assembly hall which will accommodate not more than

(a) Every assembly hall which will accommodate not more than 100 persons shall conform to the requirements of Wis. Adm. Code chapter Ind 54, covering factories, office and mercantile buildings. History: 1-2-56; am. (1) (intro. par.), Register, March, 1972, No. 195, eff. 4-1-72.

Ind 55.02 Class of construction. (1) The capacities of buildings or parts of buildings in this classification for the various types of con-

> Register, July, 1974, No. 223 Building and heating, ventilating and air conditioning code

WISCONSIN ADMINISTRATIVE CODE

Theaters, assembly halls

struction shall not exceed, and shall comply with, the following requirements:

MAXIMUM CAPACITIES

Type of Construction	With Stage	Without Stage
Type No. 1 and No. 2 Type No. 3 and No. 4	No limit	No limit
Type No. 3 and No. 4	750	1,500 1,000 750
Type No. 5 and No. 6	500	1,000
Type No. 7 and No. 8	300	750

(a) Exception. For unlimited capacity, the fire protection of structural steel supporting the roof may be omitted for one-story buildings meeting type No. 1, 2 and 3 construction provided the building has no ground or basement floors. Heavy timber columns and roof framing may be substituted for structural steel framing. The roof decking shall be of noncombustible construction meeting the fire-resistive ratings of Table 51.03-A.

(2) Type No. 7 and No. 8 construction. (See Ind 51.03.) Where buildings of these classifications are erected of Type No. 7 or No. 8 construction, the following restrictions shall apply:

(a) Not more than one story in height without a balcony, and with no ground floor or basement except a heating and fuel room enclosed with fire-resistive construction as specified in section Ind 55.29, with all interior openings protected with self-closing fire-resistive doors as specified in section Ind 51.047.

(b) Located at least 20 feet from any other building or adjoining property line.

(c) Is not built in connection with a building used for any other purpose.

(d) Is provided with foundation walls and piers of masonry construction.

(e) Where motion picture booths are required, they shall be enclosed with 2-hour fire-resistive construction.

Exception: In places of worship, a full basement and a balcony seating not more than 30 persons may be provided.

(3) Balconies accommodating more than 100. In any theater or assembly hall, balconies which accommodate more than 100 persons shall be of Type No. 1 or No. 2 construction as specified in section Ind 51.03.

History: 1-2-56; (1); (1) (a); (2); (2) (a); (2) (b); (2) (c); (2) (d); (2) (e); (2) (f); (3); am. Register, June, 1956; No. 6, eff. 7-1-56; am. (1) (a), Register, August, 1957, No. 20, eff. 9-1-57; am. Register, January, 1961, No. 61, eff. 2-1-61; am. (2) (a), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (2) (a) eff. 8-1-71 and exp. 1-1-72; cr. (2) (a) eff. 1-1-72, Register, July, 1971, No. 187; r. and recr. (1), am. (2) intro. par., and (3), Register, June, 1972, No. 198, eff. 1-1-73; cr. (1) (a), Register, September, 1978, No. 213, eff. 10-1-73; am. (2) (a), Register, May, 1974, No. 221, eff. 6-1-74; am. (1) (a), Register, July, 1974, No. 223, eff. 8-1-74.

Ind 55.03 Height above grade. (1) THEATERS. The height of the sills of the principal entrance doors to any theater, as defined in section Ind 55.001, shall be not more than 18 inches above the outside grade at that point. The floor level at the highest row of seats on the main floor shall not be more than 6 feet above the outside grade at the main entrance; the floor level at the lowest row of seats on

Register, July, 1974, No. 223 Building and heating, ventilating and air conditioning code

112