

Chapter NR 277

PHOTOGRAPHIC PROCESSING

NR 277.01	Purpose	NR 277.10	Effluent limitations, best practicable treatment
NR 277.02	Applicability	NR 277.11	Effluent limitations, best available treatment
NR 277.03	Definitions	NR 277.12	Standards of performance
NR 277.04	Compliance with effluent limitations and standards	NR 277.13	Pretreatment standards for new sources
NR 277.05	Modification of effluent limitations	NR 277.14	Pretreatment standards for existing sources
NR 277.06	Application of effluent limitations and standards		

NR 277.01 Purpose. The purpose of this chapter is to establish effluent limitations, standards of performance, and pretreatment standards for discharges of process wastes from the photographic processing subcategory of the photographic category of point sources.

Note: The authority for promulgation of this chapter is set forth in Wis. Adm. Code chapter NR 205.

History: Cr. Register, June, 1977, No. 258, eff. 7-1-77.

NR 277.02 Applicability. The effluent limitations, standards of performance, pretreatment standards, and other provisions in this chapter are applicable to pollutants or pollutant properties in discharges of process waste resulting from developing or printing of paper, prints, slides, negatives, enlargements, movie film and other sensitized photographic products in facilities which process more than 1600 sq. ft. (150 sq. m.) per day of such products.

History: Cr. Register, June, 1977, No. 258, eff. 7-1-77.

NR 277.03 Definitions. Definitions of terms and meanings of abbreviations used in this chapter are set forth in Wis. Adm. Code chapter NR 205.

History: Cr. Register, June, 1977, No. 258, eff. 7-1-77.

NR 277.04 Compliance with effluent limitations and standards. Discharge of pollutants from facilities subject to the provisions of this chapter shall not exceed, as appropriate:

- (1) By July 1, 1977 effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available;
- (2) By July 1, 1977 pretreatment standards for existing discharges to publicly owned treatment works;
- (3) By July 1, 1983 effluent limitations representing the degree of effluent reduction attainable by the application of the best available technology economically achievable;
- (4) Standards of performance for new sources; or
- (5) Pretreatment standards for new sources discharging to publicly owned treatment works.

History: Cr. Register, June, 1977, No. 258, eff. 7-1-77.

Register, July, 1977, No. 259
Environmental Protection

NR 277.05 Modification of effluent limitations. (1) Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available may be modified in accordance with this section.

(2) An individual discharger or other interested person may submit evidence to the department that factors relating to the equipment or facilities involved, the process applied, or other such factors related to such discharger are fundamentally different from the factors considered in the establishment of the effluent limitations. On the basis of such evidence or other available information the department will make a written determination that such factors are or are not fundamentally different for that facility compared to those specified in the applicable sections of the EPA development document identified in subsection (3) below. If such fundamentally different factors are found to exist, the department shall establish for the discharge effluent limitations in the WPDES permit either more or less stringent than the limitations in this chapter, to the extent dictated by such fundamentally different factors. Such limitations must be approved by EPA which may approve, disapprove, or specify other limitations.

(3) The EPA development document for effluent limitations guidelines and new source performance standards, identified by subcategory title, by EPA document number and by publication date, applicable in accordance with subsection (2) above is:

Photographic Processing, EPA 440/1-76/060-1, July 1976

(4) Copies of the development document identified in subsection (3) above are available for inspection at the office of the department of natural resources, the secretary of state's office, and the office of the revisor of statutes, and may be obtained for personal use from the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20460.

History: Cr. Register, June, 1977, No. 268, eff. 7-1-77.

NR 277.06 Application of effluent limitations and standards.

(1) The effluent limitations and standards set forth in this chapter shall be used in accordance with this section to establish the quantity or quality or pollutants or pollutant properties which may be discharged by a point source subject to the provision of this chapter, except as;

(a) They may be modified in accordance with section NR 277.05,

(b) They may be superseded by more stringent limitations and standards necessary to achieve water quality standards or meet other legal requirements, or

(c) They may be supplemented or superseded by standards or prohibitions for toxic pollutants or by additional limitations for other pollutants required to achieve water quality.

(2) The production basis for application of the limitations and standards set forth in this chapter shall be the daily average of a

Register, July, 1977, No. 269
Environmental Protection

maximum month for the facility subject to the provisions of this chapter.

History: Cr. Register, June, 1977, No. 258, eff. 7-1-77.

NR 277.10 Effluent limitations, best practicable treatment. The following effluent limitations for all or specific subcategories establish, except as provided in section NR 277.05, the quantity or quality of pollutants or pollutant properties which may be discharged by a facility subject to the provisions of this chapter after application to process wastes of the best practicable control technology currently available.

- (1) The pH of all discharges shall be within the range of 6.0 to 9.0.
- (2) The 30-day average limitations for Ag and CN shall be respectively 0.015 and 0.019 pounds/1000 sq.ft. of product, or 0.07 and 0.09 kg/1000 sq.m.
- (3) The daily maximum limitations shall be twice the 30-day average limitations set forth in subsection (2).

History: Cr. Register, June, 1977, No. 268, eff. 7-1-77.

NR 277.11 Effluent limitations, best available treatment. (Reserved)

NR 277.12 Standards of performance. (Reserved)

NR 277.13 Pretreatment standards for new sources. (Reserved)

NR 277.14 Pretreatment standards for existing sources. (Reserved)