

Chapter ILHR 59

HAZARDOUS OCCUPANCIES

| | | | |
|-------------|--|------------|--|
| ILHR 59.001 | Scope (p. 309) | ILHR 59.18 | Vehicular guardrails (p. 316) |
| ILHR 59.01 | Definitions (p. 309) | ILHR 59.19 | Illumination levels (p. 317) |
| ILHR 59.10 | Scope (p. 309) | ILHR 59.20 | Sanitary facilities (p. 317) |
| ILHR 59.11 | Construction (p. 310) | ILHR 59.21 | Isolation of hazards and separations (p. 317) |
| ILHR 59.12 | Height and area (p. 310) | ILHR 59.22 | Occupancy separations - mixed occupancies (p. 318) |
| ILHR 59.13 | Types of exits (p. 314) | ILHR 59.23 | Fire protection systems (p. 318) |
| ILHR 59.14 | Number and location of exits (p. 314) | ILHR 59.24 | Fire alarms (p. 318) |
| ILHR 59.15 | Required exit width (p. 315) | | |
| ILHR 59.16 | Capacity of structures (p. 316) | | |
| ILHR 59.17 | Enclosure of stairways and shafts (p. 316) | | |

Note: Chapter Ind 59 was renumbered chapter ILHR 59 effective January 1, 1984.

ILHR 59.001 Scope. This chapter applies to all hazardous occupancies as indicated in the scope of each subchapter.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82.

ILHR 59.01 Definitions. (1) "Combustible liquid" means a liquid as defined in s. Ind 8.01 (19).

(2) "Flammable liquid" means a liquid as defined in s. Ind 8.01 (37).

(3) "Motor vehicle" means any self-propelled device fueled by a flammable or combustible liquid used to transport people or goods.

(4) "Open parking structure" means a structure as defined in s. ILHR 62.10.

(5) "Private garage" means a structure or a part of a structure, either attached to a one- or 2-family dwelling or unattached but serving the dwelling, housing one or more motor vehicles owned by the occupant of the dwelling and used only for personal or family service, not serving as a place of employment.

(6) "Repair garage" means a structure or any part of a structure in which one or more motor vehicles are primarily repaired or serviced.

(7) "Storage garage" means any structure or part of a structure in which one or more motor vehicles are stored or parked and which is not a repair garage, private garage or open parking structure.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82.

ILHR 59.10 Scope. (1) The requirements of this subchapter apply to storage garages and repair garages.

(2) This subchapter does not apply to the following occupancies:

(a) Storage garages serving community-based residential facilities within the scope of ch. ILHR 61;

Note: See s. ILHR 61.10 (2).

(b) Areas of factories and plants used for the manufacture or assembly of motor vehicles or their components;

(c) Drive-in or drive-through facilities not used for the storage of motor vehicles including, but not limited to those of banks, restaurants, hospitals, car washes, film processing centers or other similar occupancies; and

(d) Attached storage garages 500 sq. ft. or less in area serving a residential occupancy as specified in ch. ILHR 57.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82; am. (1) and (2) (d), Register, March, 1991, No. 423, eff. 4-1-91.

ILHR 59.11 Construction. (1) **FLOORS.** (a) The floor areas accommodating motor vehicles shall be of earth, gravel or noncombustible, nonabsorbent materials.

(b) Service pits and other similar depressions in the floor of a storage or repair garage shall be ventilated in accordance with ch. ILHR 64.

(2) **CLEARANCE REQUIREMENTS.** Headroom clearances shall be maintained in accordance with s. ILHR 51.164.

(3) **CANOPIES.** Free standing canopies and their supports or other similar structures over fuel dispensing equipment, when located less than 10 feet from a property line, shall be constructed of noncombustible materials.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82; am. (1) (a), Register, October, 1982, No. 322, eff. 11-1-82.

ILHR 59.12 Height and area. (1) **STORAGE GARAGES.** Storage garages shall not exceed the number of stories and corresponding area limitations of Table 59.12-1 or 59.12-2.

(2) **REPAIR GARAGES.** Repair garages shall not exceed the number of stories and 75% of the corresponding area limitations of Table 59.12-1 or 59.12-2.

(3) **ALLOWABLE INCREASE OF FLOOR AREAS.** (a) *Automatic fire sprinkler system protection.* 1. Chapter ILHR 59 buildings not protected by automatic fire sprinkler systems may not exceed the height and area limitations specified in subs. (1) or (2) and Table 59.12-1.

2. a. Chapter ILHR 59 buildings protected by complete automatic fire sprinkler systems may not exceed the height and area limitations specified in subs. (1) or (2) and Table 59.12-2.

b. The area of one story aircraft hangars of type No. 1 to 6 construction may be unlimited provided the building is completely protected by an automatic fire sprinkler system and the building is provided with street access around its entire perimeter.

(b) *Fire divisions.* No storage or repair garage shall be limited in area where divided into sections which do not exceed the maximum areas tabulated in this section by fire division walls as specified in s. ILHR 51.02 (13). All openings in such walls shall be protected by swinging, sliding or overhead fire-resistive door assemblies as specified in s. ILHR 51.047. Doors protecting such openings may be held open if equipped with rate of rise heat or photoelectric activated automatic closing devices. Doors used as required exits shall comply with the requirements of s. ILHR 51.15.

(4) **MINI-GARAGES.** Mini-garage buildings on the same property may be located less than 30 feet of each other with no restriction on the percentage of wall openings provided the combined gross area of the buildings, including the area between the buildings, is no more than the area permitted by this section.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82; correction in (3) (a) made under s. 13.93 (2m) (b) 7, Stats., cr. (4), Register, August, 1985, No. 356, eff. 1-1-86; emerg. r. table 59.12 and cr. tables 59.12-1 and 59.12-2, am. (1) and (2), r. and recr. (3) (a), eff. 9-6-86; r. table 59.12 and cr. table 59.12-1 and 59.12-2, am. (1) and (2), r. and recr. (3) (a), Register, November, 1986, No. 371, eff. 12-1-86.

TABLE 59.12-1 — ALLOWABLE HEIGHT (STORIES) AND AREA (SQARE FEET) FOR BUILDINGS WITHOUT COMPLETE AUTOMATIC FIRE
 SPRINKLER SYSTEM PROTECTION (MAXIMUM GROSS FLOOR AREA PER FLOOR)

NOTE #1: DO NOT USE FOR BUILDINGS EXCEEDING 60 FEET IN HEIGHT

NOTE #2: FOR STORAGE GARAGES ONLY. USE 75% OF VALUES FOR REPAIR GARAGES

| CLASS OF CONSTRUCTION | BUILDING FRONTAGE STREET* EXPOSURE | NUMBER OF STORIES | | | | | | | | |
|----------------------------------|---|-------------------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | Over 8 |
| 1. Fire-Resistive Type A | 1 | 25,000 | 22,000 | 19,000 | 16,000 | 13,000 | 11,000 | 9,000 | 8,000 | 6,000 |
| | 2 | 30,500 | 27,000 | 24,000 | 20,500 | 17,500 | 15,000 | 13,000 | 12,000 | 10,000 |
| | 3 | 36,000 | 33,000 | 29,000 | 25,000 | 22,000 | 19,000 | 17,000 | 16,000 | 14,000 |
| | 4 | 41,500 | 39,000 | 34,000 | 29,500 | 26,500 | 23,000 | 21,000 | 20,000 | 18,000 |
| 2. Fire-Resistive Type B | 1 | 23,000 | 20,000 | 17,000 | 14,000 | 11,000 | 9,000 | 7,000 | 6,000 | |
| | 2 | 28,500 | 25,000 | 22,000 | 18,500 | 15,500 | 13,000 | 11,000 | 10,000 | N.P. |
| | 3 | 34,000 | 31,000 | 27,000 | 23,000 | 20,000 | 17,000 | 15,000 | 14,000 | |
| | 4 | 39,500 | 37,000 | 32,000 | 27,500 | 24,500 | 21,000 | 19,000 | 18,000 | |
| 3. Metal Frame Protected | 1 | 21,000 | 18,000 | 15,000 | 12,000 | | | | | |
| | 2 | 26,500 | 23,000 | 19,500 | 16,000 | N.P. | N.P. | N.P. | N.P. | N.P. |
| | 3 | 32,000 | 28,000 | 24,000 | 20,000 | | | | | |
| | 4 | 37,500 | 33,000 | 28,500 | 24,000 | | | | | |
| 4. Heavy Timber | 1 | 17,000 | 14,000 | 11,000 | 9,000 | | | | | |
| | 2 | 22,000 | 19,000 | 16,000 | 13,500 | N.P. | N.P. | N.P. | N.P. | N.P. |
| | 3 | 27,000 | 24,000 | 21,000 | 18,000 | | | | | |
| | 4 | 32,000 | 29,000 | 26,000 | 22,500 | | | | | |
| 5A. Exterior Masonry Protected | 1 | 15,500 | 13,500 | 9,500 | 8,000 | | | | | |
| | 2 | 20,000 | 17,000 | 14,000 | 12,500 | N.P. | N.P. | N.P. | N.P. | N.P. |
| | 3 | 24,500 | 21,500 | 18,500 | 15,500 | | | | | |
| | 4 | 29,000 | 26,000 | 23,000 | 19,500 | | | | | |
| 5B. Exterior Masonry Unprotected | 1 | 14,000 | 11,500 | 9,000 | 7,000 | | | | | |
| | 2 | 18,000 | 15,000 | 12,500 | 10,000 | N.P. | N.P. | N.P. | N.P. | N.P. |
| | 3 | 22,000 | 19,000 | 16,000 | 13,000 | | | | | |
| | 4 | 26,000 | 23,000 | 19,500 | 16,000 | | | | | |
| 6. Metal Frame Unprotected | 1 | 14,000 | 11,500 | 9,000 | | | | | | |
| | 2 | 18,000 | 15,000 | 12,500 | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. |
| | 3 | 22,000 | 19,000 | 16,000 | | | | | | |
| | 4 | 26,000 | 23,000 | 19,500 | | | | | | |
| 7. Wood Frame Protected | 1 | 12,500 | | | | | | | | |
| | 2 | 16,000 | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. |
| | 3 | 19,000 | | | | | | | | |
| | 4 | 22,000 | | | | | | | | |
| 8. Wood Frame Unprotected | 1 | 10,000 | | | | | | | | |
| | 2 | 12,000 | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. |
| | 3 | 14,000 | | | | | | | | |
| | 4 | 16,000 | | | | | | | | |

N.P. MEANS NOT PERMITTED

* 4-HOUR FIRE DIVISION WALL SHALL BE CONSIDERED AS A STREET FOR THE PURPOSE OF COMPUTING THE AREA LIMITATIONS FOR THIS TABLE.

TABLE 59.12-2 — ALLOWABLE HEIGHT (STORIES) AND AREA (SQUARE FEET) FOR BUILDINGS COMPLETELY PROTECTED BY AUTOMATIC FIRE SPRINKLER SYSTEM (MAXIMUM GROSS FLOOR AREA PER FLOOR)

NOTE #1: USE FOR ALL BUILDINGS

NOTE #2: FOR STORAGE GARAGES ONLY. USE 75% OF VALUES FOR REPAIR GARAGES

| | BUILDING FRONTAGE STREET* EXPOSURE | NUMBER OF STORIES | | | | | | | | | | |
|---|------------------------------------|-------------------|---------|---------|--------|--------|--------|--------|--------|--------|--------|--|
| | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | Over 9 | |
| 1. Fire-resistive Type A | 1 | | | | | | | | | | | |
| One street required for unlimited area. | 2 | | | | | | | | | | | |
| See s. ILHR 51.01 (124) | 3 | | | | | | | | | | | |
| | 4 | | | | NO | LIMIT | | | | | | |
| 2. Fire-resistive type B | 1 | | 69,000 | 60,000 | 51,000 | 42,000 | 33,000 | 27,000 | 21,000 | 18,000 | N.P. | |
| One street required for unlimited area. | 2 | NO | 85,500 | 75,000 | 66,000 | 55,500 | 46,500 | 39,000 | 33,000 | 30,000 | | |
| See s. ILHR 51.01 (124) | 3 | LIMIT | 102,000 | 93,000 | 81,000 | 69,000 | 60,000 | 51,000 | 45,000 | 42,000 | | |
| | 4 | | 118,500 | 111,000 | 96,000 | 82,500 | 73,500 | 63,000 | 57,000 | 54,000 | | |
| 3. Metal frame protected | 1 | 84,000 | 63,000 | 54,000 | 45,000 | 36,000 | N.P. | N.P. | N.P. | N.P. | N.P. | |
| | 2 | 106,000 | 79,500 | 69,000 | 58,500 | 48,000 | | | | | | |
| | 3 | 128,000 | 96,000 | 84,000 | 72,000 | 60,000 | | | | | | |
| | 4 | 150,000 | 112,500 | 99,000 | 85,500 | 72,000 | | | | | | |
| 4. Heavy Timber | 1 | 68,000 | 51,000 | 42,000 | 33,000 | 27,000 | N.P. | N.P. | N.P. | N.P. | N.P. | |
| | 2 | 88,000 | 66,000 | 57,000 | 48,000 | 40,500 | | | | | | |
| | 3 | 108,000 | 81,000 | 72,000 | 63,000 | 54,000 | | | | | | |
| | 4 | 128,000 | 96,000 | 87,000 | 78,000 | 67,500 | | | | | | |
| 5A. Exterior Masonry Protected | 1 | 62,000 | 46,500 | 40,500 | 28,500 | 24,000 | N.P. | N.P. | N.P. | N.P. | N.P. | |
| | 2 | 80,000 | 60,000 | 51,000 | 42,000 | 37,500 | | | | | | |
| | 3 | 98,000 | 73,500 | 64,500 | 55,500 | 46,500 | | | | | | |
| | 4 | 116,000 | 87,000 | 78,000 | 69,000 | 58,500 | | | | | | |
| 5B. Exterior Masonry Unprotected | 1 | 56,000 | 42,000 | 34,500 | 27,000 | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | |
| | 2 | 72,000 | 54,000 | 45,000 | 37,500 | | | | | | | |
| | 3 | 88,000 | 66,000 | 57,000 | 48,000 | | | | | | | |
| | 4 | 104,000 | 78,000 | 69,000 | 58,500 | | | | | | | |
| 6. Metal Frame Unprotected | 1 | 56,000 | 42,000 | 34,500 | 27,000 | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | |
| | 2 | 72,000 | 54,000 | 45,000 | 37,500 | | | | | | | |
| | 3 | 88,000 | 66,000 | 57,000 | 48,000 | | | | | | | |
| | 4 | 104,000 | 78,000 | 69,000 | 58,500 | | | | | | | |
| 7. Wood Frame Protected | 1 | 50,000 | 37,500 | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | |
| | 2 | 64,000 | 48,000 | | | | | | | | | |
| | 3 | 76,000 | 57,000 | | | | | | | | | |
| | 4 | 88,000 | 66,000 | | | | | | | | | |
| 8. Wood Frame Unprotected | 1 | 40,000 | 30,000 | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | N.P. | |
| | 2 | 48,000 | 36,000 | | | | | | | | | |
| | 3 | 56,000 | 42,000 | | | | | | | | | |
| | 4 | 64,000 | 48,000 | | | | | | | | | |

N.P. MEANS NOT PERMITTED

*4-HOUR FIRE DIVISION WALL SHALL BE CONSIDERED AS A STREET FOR THE PURPOSE OF COMPUTING THE AREA LIMITATIONS FOR THIS TABLE.

Hazardous occupancies

INDUSTRY, LABOR AND HUMAN RELATIONS

ILHR 59

FP ILHR 59.13 Types of exits. (1) **GENERAL.** (a) Only the following types of exits shall be used to comply with the provisions of s. ILHR 59.14:

1. Standard exit as specified in s. ILHR 51.15, except as provided in sub. (2);
2. Stairways as specified in s. ILHR 51.16, except as provided in sub. (2);
3. Smokeproof stair tower as specified in s. ILHR 51.17;
4. Interior enclosed stairway as specified in s. ILHR 51.18;
5. Horizontal exit as specified in s. ILHR 51.19;
6. Fire escapes as specified in s. ILHR 51.20; and
7. Nonparking access ramps with a maximum slope of 1:8.

(b) At least half of the exits required under s. ILHR 59.14 shall be standard exits, stairways, smokeproof stair towers or interior enclosed stairways to grade.

(2) **EXCEPTIONS.** (a) A spiral stairway shall not serve as a required exit, but may be used as an employe convenience stairway if located in nonpublic areas.

(b) The width of required exit stairways serving unoccupied areas, such as storage areas, equipment mezzanines and similar areas not exceeding 750 sq. ft. may be reduced to 3 feet 0 inches.

(c) Doors in standard exits serving rooms, spaces or areas with an occupancy load of 25 persons or less are not required to swing in the direction of egress.

(d) A door not complying with s. ILHR 51.15 (2), may be used as a standard exit serving storage garages or storage areas not exceeding 3,000 square feet in area.

Note: Where accessibility and interior circulation for persons with functional limitations must be provided, the requirements of s. ILHR 52.04 (9) govern.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82; am. (2) (d), Register, August, 1985, No. 356, eff. 1-1-86.

FP ILHR 59.14 Number and location of exits. (1) **GENERAL.** (a) Except as provided in par. (b), every floor level and every room, space or area of a storage garage and a repair garage shall be provided with at least 2 exits.

(b) One exit is permitted from the following:

1. Any room, space or area used for storage garage purposes with an occupancy load of 10 persons or less and which does not exceed 3,000 sq. ft. in net floor area;
2. Any room, space or area used for repair garage purposes and does not exceed 750 sq. ft. in net floor area;
3. Any room, space or area used as other than a storage or repair garage with an capacity of 25 persons or less; and
4. A mezzanine floor level, provided the mezzanine is:
 - a. Three thousand square feet or less in net floor area;

- b. Used only for storage purposes;
- c. Open on at least one side to the floor below; and
- d. Not more than 12 feet above the floor below.

(2) **EXIT DISTANCE.** Exits shall be provided and distributed as follows:

(a) *Storage garages.* 1. No area of a storage garage shall be more than 100 feet from an exit, unless the entire storage garage is protected by an automatic sprinkler system.

2. No area of a storage garage entirely protected by an automatic fire sprinkler system shall be more than 200 feet from an exit.

(b) *Repair garages.* 1. No area of a repair garage shall be more than 75 feet from an exit, unless the entire repair garage is protected by an automatic fire sprinkler system.

2. No area of a repair garage entirely protected by an automatic fire sprinkler system shall be more than 150 feet from an exit.

(c) **Measurement of exit distance.* The exit distances required by this section shall be measured along public passageways and aisles to:

- 1. Standard exits leading to grade as specified in s. ILHR 51.15;
- 2. Doors opening into smokeproof stair towers as specified in s. ILHR 51.17, interior enclosed stairways as specified in s. ILHR 51.18, or fire escapes as specified in s. ILHR 51.20; or
- 3. Horizontal exits as specified in s. ILHR 51.19.

(3) **LOCATION OF EXITS.** Except as provided in sub. (1) (b), exits in all storage garages and repair garages shall be located and distributed so that in the event an exit is blocked, another exit is available from every area of the storage garage or repair garage.

(4) **EXIT LIGHTS.** All required exits shall be identified by an approved exit light. Directional exit lights shall be provided to direct occupants to the exits. Exit lights and directional exit lights shall be as specified in s. ILHR 51.15 (5).

(5) **EXIT MAINTENANCE.** Exits shall be maintained in accordance with s. ILHR 52.21.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82; cr. (4), Register, December, 1983, No. 336, eff. 1-1-84; emerg. am. (2) (a) 2. and (b), eff. 9-6-86; am. (2) (a) 2. and (b), Register, November, 1986, No. 371, eff. 12-1-86.

ILHR 59.15 Required exit width. (1) **GENERAL.** Every floor level of a storage garage and repair garage shall be provided with at least the required aggregate width of exits as specified in ss. ILHR 51.15 (6) and 51.16 (3).

(2) **HORIZONTAL EXITS.** Horizontal exits may provide up to one-half of the required aggregate width of exits for a floor level.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82.

*See Appendix A for further explanatory material.

ILHR 59.16 Capacity of structures. In calculating the required aggregate width of exits under s. ILHR 59.15 and the required number of sanitary facilities under s. ILHR 59.20, the capacities of structures and floor levels shall be computed on the following basis:

- (1) Storage garages and repair garages - 300 sq. ft. per person; and
- (2) Other areas as dictated by the appropriate sections of chs. ILHR 54 to 62.

Note: See ss. ILHR 54.05, 55.06, 56.07 for additional requirements.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82.

FP ILHR 59.17 Enclosure of stairways and shafts. (1) **TWO FLOOR LEVELS.** (a) All stairways and vertical openings serving 2 floor levels shall be enclosed with smoke partitions, unless:

1. The stairway or opening serves an open storage mezzanine less than 3,000 square feet in area;

2. The opening is not a required means of egress and the opening is separated from any exit access corridor or exit stairway by at least smoke partitions as specified in par. (a); or

3. The two-connected floor levels:

- a. Are provided with six air changes of ventilation;
- b. Are provided with interconnected fire detectors in accordance with NFPA 72;
- c. Do not have open flame equipment located in the lower level; and
- d. Have only pneumatic power equipment available for use.

(b) Smoke partitions enclosing stairways or vertical openings shall be constructed of solid and rigid materials.

(c) Openings in smoke partitions shall be protected with doors equipped with automatic closing devices.

(2) **THREE OR MORE FLOOR LEVELS.** Stairways and shafts serving 3 or more floor levels shall be enclosed pursuant to s. ILHR 51.18 with fire-resistive construction as specified in Table 51.03-A.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82; reprinted to correct error in (2), Register, February, 1982, No. 314; am. (2), Register, October, 1982, No. 322, eff. 11-1-82; r. and recr. (1), Register, March, 1991, No. 423, eff. 4-1-91.

ILHR 59.18 Vehicular guardrails. Vehicular guardrails shall be provided at all floor openings and at all differences in floor level elevations as follows:

- (1) **DRIVE LANES.** Vehicular guardrails shall be installed at the end of drive lanes and shall be designed for a minimum horizontal live load of 1000 pounds per linear foot acting at 18 inches above the floor level; and

- (2) **PARKING STALLS.** Vehicular guardrails shall be installed at the end of parking stalls and shall be designed for a minimum horizontal live load of 500 pounds per linear foot acting at 18 inches above the floor level.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82.

Register, March, 1991, No. 423

ILHR 59.19 Illumination levels. (1) **EXITS.** All stairways and exits and the passageways leading to them shall be illuminated to facilitate egress. The intensity of illumination shall be not less than 10 footcandles at the floor or step level. **FP**

(2) **DRIVING AREAS.** The minimum illumination level for driving areas at a horizontal plane 30 inches above the floor shall be an intensity of at least 2 footcandles.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82.

ILHR 59.20 Sanitary facilities. (1) **GENERAL.** Sanitary facilities shall be provided as specified in ss. ILHR 54.12, 55.32 or 56.16, as appropriate for the use of the building.

(2) **UNATTENDED STORAGE GARAGES.** Sanitary facilities are not required to be provided in unattended storage garages.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82.

ILHR 59.21 Isolation of hazards and separations. All fuel-fired heating equipment, except direct vent sealed combustion chamber appliances, within a storage garage and a repair garage, including, but not limited to boilers, furnaces and water heaters, shall be isolated from the remainder of the storage garage or repair garage by at least 2-hour fire-resistive construction as specified in s. ILHR 51.04 or shall be installed as specified in sub. (3). **FP**

(1) **PROTECTION OF OPENINGS.** All openings in required enclosures shall be protected with self-closing fire-resistive door assemblies as specified in s. ILHR 51.047. The installation or use of hold-open devices for these doors shall be prohibited.

(2) **PROHIBITED OPENINGS.** (a) Except as provided in par. (b), openings shall be prohibited in any building component separating garage areas and fuel-fired heating equipment where the fuel-fired heating equipment is located below the elevation of the garage floor.

(b) Supply and return air grilles or registers in garage areas are permitted if the bottom of the grille or register opening is at least 18 inches above the garage floor.

(3) **SUSPENDING EQUIPMENT.** (a) Except as provided in par. (b), boilers up to 200,000 Btu input, water heaters up to 200,000 Btu input, gas and liquid fuel-fired space heaters, suspended furnaces, vented and unvented unit heaters may be used without an enclosure where approved by the department. Where suspended furnaces, vented and unvented unit heaters, boilers and water heaters are used without an enclosure, all units shall be located at least 8 feet above the floor or, in aircraft hangars, 10 feet above the upper surface of the wing or engine enclosure of the aircraft. The blow-off pipe for suspended boilers and water heaters shall be extended down to within 6 inches of the floor.

(b) The rated enclosure for heating equipment in storage or repair garages may be omitted if the burner of the equipment is located at least 8 feet off the floor and the equipment is protected from physical damage.

Note: See s. ILHR 64.21 for additional requirements.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82; am. (intro.) and (2) (a), Register, December, 1983, No. 336, eff. 1-1-84; am. (intro.) and cr. (3), Register, August, 1985, No. 356, eff. 1-1-86.

ILHR 59.22 Occupancy separations. A storage garage or repair garage shall be separated from any other occupancy in accordance with s. ILHR 51.08.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82; am. table, Register, October, 1982, No. 322, eff. 11-1-82; am. table, Register, December, 1983, No. 336, eff. 1-1-84; r. and recr., Register, March, 1991, No. 423, eff. 4-1-91.

ILHR 59.23 Fire protection systems. (1) **SPRINKLER SYSTEMS.** Automatic fire sprinkler systems shall be provided as outlined in ss. ILHR 52.01, 52.011, 52.012 and 52.013.

FP (2) **STANDPIPES.** (a) Fire department standpipes shall be provided as follows:

1. In all storage garages and repair garages 3 or more stories in height; and

2. In all storage garage and repair garage floor levels more than 500 sq. ft. in area, located below grade and not accessible to fire fighting vehicles.

(b) Required fire department standpipes with a fire department siamese connection greater than 50 feet to a street shall be interconnected to a standpipe system with such a connection 50 feet or less to a street.

(c) Required fire department standpipes shall be provided in each stair enclosure serving a storage or repair garage and shall be provided with approved 2½ in. valve hose connections at each floor level with one connection in the stair tower and one immediately outside.

(d) Fire department standpipes shall conform to the requirements specified in s. ILHR 51.21 (3) (e) to (i).

(e) 1. The department will recognize alternative systems and designs in lieu of required fire department standpipes, if an equivalent degree of safety is provided in storage or repair garages 60 feet or less in height.

2. The department will accept storage garages or repair garages without fire department standpipes, if clearances are provided to allow fire fighting vehicles access throughout the storage or repair garages.

3. Fire department standpipes as specified in this subsection need not be provided in buildings 60 feet or less in height completely protected by an automatic fire sprinkler system.

4. Fire department standpipes shall be provided in buildings more than 60 feet in height in accordance with s. ILHR 51.21 (3).

FP (3) ***FIRE EXTINGUISHERS.** Portable fire extinguishers shall be provided and maintained as specified in s. ILHR 51.22.

Note: See ch. ILHR 52, subch. II for requirements pertaining to automatic fire sprinkler systems.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82; r. (2), renum. (3) to be (2), Register, June, 1983, No. 330, eff. 7-1-83; emerg. cr. (1) (e) 3. and 4., eff. 9-6-86; cr. (1) (e) 3. and 4., Register, November, 1986, No. 371, eff. 12-1-86; renum. and am. (1) to be (2), renum. (2) to be (3), cr. (1), Register, March, 1991, No. 423, eff. 4-1-91.

ILHR 59.24 Fire alarms. A fire alarm system complying with s. ILHR 51.24 shall be provided in every storage garage and repair garage where

*See Appendix A for further explanatory material.

Register, March, 1991, No. 423

INDUSTRY, LABOR AND HUMAN RELATIONS

319

Hazardous occupancies

ILHR 59

more than 10 persons are employed above the second story except storage garages and repair garages which are provided with a complete automatic sprinkler system.

History: Cr. Register, December, 1981, No. 312, eff. 1-1-82.