

**Chapter Comm 90**

**APPENDIX**

The material contained in this appendix is for clarification purposes only. The notes, illustrations, etc., are numbered to correspond to the number of the rule as it appears in the text of the code.

**A-90.03 (15) Plan submittal and fees.**

The following is a listing of when the department may waive submittal of pool plans and fees for the reconstruction and alteration of existing pools. This listing is based upon SPGL-7, Guidelines for Pool Designers, June 22, 1992, issued by Department of Health and Family Services.

1. A disinfection system equipped with a positive displacement pump is replaced by an approved pass-through (erosion) type system or visa versa, the replacement of a gas chlorine system with a positive displacement pump or approved pass-through feeder.

**Note:** The installation of a gas chlorine system will require plan review and a fee.

2. A recirculation pump is replaced by another pump from a different manufacturer provided that the capacity of the new pump is at least equal to the pump which is replaced.

3. A filter is replaced with an approved filter of the same type but with greater filter media surface.

4. The replacement of metal piping and fittings with the same size PVC piping and fittings.

5. A supplemental disinfecting system is installed (e.g., Tarn Pure, Ozone, etc.) provided that the halogen residual is maintained as stated in ch. HFS 172 and that there is no decrease in the required water recirculation flow rate.

**A-90.19 (6) Sample sketch depicting whirlpool location and measurements for access, as specified in s. Comm 90.19 (6) (a) 2.**

