

Chapter NR 665**APPENDIX III****EPA INTERIM PRIMARY DRINKING WATER STANDARDS**

Parameter	Maximum level (mg/L)
Arsenic	0.05
Barium	1.0
Cadmium	0.01
Chromium	0.05
Fluoride	1.4-2.4
Lead	0.05
Mercury	0.002
Nitrate (as N)	10
Selenium	0.01
Silver	0.05
Endrin	0.0002
Lindane	0.004
Methoxychlor	0.1
Toxaphene	0.005
2,4-D	0.1
2,4,5-TP Silvex	0.01
Radium	5 pCi/L
Gross Alpha	15 pCi/L
Gross Beta	4 millirem/yr
Turbidity	1/TU
Coliform Bacteria	1/100 ml

Note: Turbidity is applicable only to surface water supplies.