1

2

3

4

5

6

7

8

9

10

11

State of Misconsin 2017 - 2018 LEGISLATURE

LRBa2218/1 MDK:emw

ASSEMBLY AMENDMENT 2, TO ASSEMBLY BILL 904

February 19, 2018 - Offered by Representative Ballweg.

At the locations indicated, amend the bill as follows:

1. Page 7, line 16: delete lines 16 to 23 and substitute:

"(aL) Forced-air furnaces. Carbon monoxide detectors shall be provided in units served by a fuel-burning, forced-air furnace, except that carbon monoxide detectors are not required in a unit if a carbon monoxide detector is provided in the first room or area served by each main duct leaving the furnace and one of the following is satisfied:

1. The carbon monoxide alarm signals are automatically transmitted to all units served by the furnace and to a designated location at a facility staffed by trained personnel on a continuous basis where alarm and supervisory signals are monitored and facilities are provided for notification of the fire department.

1

2

3

2. In addition to the first room or area served by each main duct leaving the furnace, a carbon monoxide detector is installed in every 4th unit on the same floor as that first room or area.".

4 (END)