

2017 DRAFTING REQUEST

Assembly Amendment (AA-AB904)

For: Joan Ballweg (608) 266-8077

Drafter: mkunkel

By: Bethany

Secondary Drafters:

Date: 2/19/2018

May Contact:

Same as LRB: a2183

Submit via email: YES
Requester's email: Rep.Ballweg@legis.wisconsin.gov
Carbon copy (CC) to:

Pre Topic:

No specific pre topic given

Topic:

Carbon monoxide detectors for forced-air furnaces

Instructions:

See attached

Drafting History:

<u>Vers.</u>	<u>Drafted</u>	<u>Reviewed</u>	<u>Submitted</u>	<u>Jacketed</u>	<u>Required</u>
/1	mkunkel 2/19/2018	anienaja 2/19/2018	lparisi 2/19/2018	lparisi 2/19/2018	

FE Sent For: <END>

Kunkel, Mark

From: Pleviak, Krista
Sent: Monday, February 19, 2018 1:12 PM
To: Kunkel, Mark
Subject: Amendment Request for Tomorrow's Floor Session

Importance: High

Mark:

I just spoke with Bethany in Rep. Ballweg's office. They would like an Assembly companion to LRBa2183 (SA to SB 748). The Assembly bill is AB 904. The bill is on the floor tomorrow, so they need it today.

It looks like this is yours. If you're busy today and want me to do it, let me know.

Krista

Krista R. Pleviak

Legislative Attorney
Wisconsin Legislative Reference Bureau
P.O. Box 2037
Madison, WI 53701-2037
(608) 266 - 7290
krista.pleviak@legis.wisconsin.gov



State of Wisconsin
2017 - 2018 LEGISLATURE

LRBa2183/P1
MDK:emw

Now

1/3/18
a 2218/1

PRELIMINARY DRAFT - NOT READY FOR INTRODUCTION

SENATE AMENDMENT,

TO SENATE BILL 748

Companion
Amendment

AA to AB 904

1 At the locations indicated, amend the bill as follows:

2 1. Page 7, line 16: delete lines 16 to 23 and substitute:

3 "(aL) *Forced-air furnaces.* Carbon monoxide detectors shall be provided in
4 units served by a fuel-burning, forced-air furnace, except that carbon monoxide
5 detectors are not required in a unit if a carbon monoxide detector is provided in the
6 first room or area served by each main duct leaving the furnace and one of the
7 following is satisfied:

8 1. The carbon monoxide alarm signals are automatically transmitted to all
9 units served by the furnace and to a designated location at a facility staffed by
10 trained personnel on a continuous basis where alarm and supervisory signals are
11 monitored and facilities are provided for notification of the fire department.

