

Chapter SPS 364

HEATING, VENTILATING AND AIR CONDITIONING

Subchapter I — Scope

SPS 364.0001 Scope.

Subchapter II — Changes, Additions or Omissions to the International Mechanical Code (IMC)

SPS 364.0100 Changes, additions or omission to the International Mechanical Code (IMC).
 SPS 364.0101 Administration.
 SPS 364.0202 Definitions.
 SPS 364.0300 Health care facilities.
 SPS 364.0301 General regulations.
 SPS 364.0304 Installation.
 SPS 364.0307 Auxiliary and secondary drain systems.
 SPS 364.0309 Temperature control.
 SPS 364.0312 Heating and cooling load calculations.
 SPS 364.0313 Other requirements.
 SPS 364.0401 Ventilation.
 SPS 364.0402 Natural ventilation.
 SPS 364.0403 Mechanical ventilation.
 SPS 364.0404 Enclosed parking garages.

SPS 364.0501 General.
 SPS 364.0502 Required systems.
 SPS 364.0505 Domestic kitchen exhaust equipment.
 SPS 364.0506 Commercial kitchen grease ducts and exhaust equipment.
 SPS 364.0507 Commercial kitchen hoods.
 SPS 364.0513 Smoke control systems.
 SPS 364.0514 Energy recovery ventilation systems.
 SPS 364.0601 General.
 SPS 364.0602 Plenums.
 SPS 364.0606 Smoke detection system control.
 SPS 364.0607 Ducts and air-transfer openings.
 SPS 364.0701 Combustible air.
 SPS 364.0801 Chimneys and vents.
 SPS 364.0802 Door swing.
 SPS 364.0918 Forced-air warm-air furnaces.
 SPS 364.1001 Boilers, water heaters and pressure vessels.
 SPS 364.1101 Refrigeration.
 SPS 364.1500 Referenced standards.
 SPS 364.1600 Appendices.

Note: Chapter Comm 64 as it existed on June 30, 2002 was repealed and a new chapter Comm 64 was created, [Register December 2001 No. 552](#), effective July 1, 2002. Chapter Comm 64 was renumbered chapter SPS 364 under s. 13.92 (4) (b) 1., Stats., [Register December 2011 No. 672](#).

Note: Chapters SPS 361 to 366 are affected by [2017 Wisconsin Acts 59, 198, 243, 317, 329, 330, and 331](#). Future rule-making will update chs. SPS 361 to 366 to reflect this legislation.

Subchapter I — Scope

SPS 364.0001 Scope. (1) This chapter shall regulate the design, installation, maintenance, alteration and inspection of mechanical systems that provide control of environmental conditions and related processes within buildings. This chapter shall also regulate those mechanical systems, system components, equipment and appliances specifically addressed herein. The use of fuel gas distribution piping and equipment, fuel gas-fired appliances and fuel gas-fired appliance venting systems shall be regulated by ch. [SPS 365](#).

(2) Notwithstanding any other provision of this chapter, the department may not adopt or enforce minimum ventilation standards for indoor drive-through self-service storage facilities described in Table 364.0403 that are more restrictive than the standards under this chapter applicable to warehouses.

(3) Notwithstanding any other provision of this chapter, the department may not adopt or enforce minimum ventilation standards for a building in which a boat that is not a motorized vehicle under s. [SPS 364.0202 \(1\) \(f\)](#) is or may be stored that are more restrictive than the standards under this chapter that would otherwise apply.

History: CR 00-179: cr. [Register December 2001 No. 552](#), eff. 7-1-02; CR 06-120: r. and recr. [Register February 2008 No. 626](#), eff. 3-1-08; correction made under s. 13.92 (4) (b) 7., Stats., [Register December 2011 No. 672](#); [CR 16-094](#); cr. (2), (3) [Register April 2018 No. 748](#), eff. 5-1-18; [renum. 364.0001 to 364.0001 \(1\)](#) under s. 13.92 (4) (b) 1., Stats., [Register April 2018 No. 748](#).

Subchapter II — Changes, Additions or Omissions to the International Mechanical Code (IMC)

SPS 364.0100 Changes, additions or omission to the International Mechanical Code (IMC). Changes, additions or omissions to the IMC are specified in this subchapter and are rules of the department and are not requirements of the IMC.

Note: The sections in this subchapter are generally numbered to correspond with the section numbering in the IMC; e.g., s. SPS 364.0102 corresponds to IMC section 102.

History: CR 00-179: cr. [Register December 2001 No. 552](#), eff. 7-1-02; CR 04-016: am. [Register December 2004 No. 588](#), eff. 1-1-05.

SPS 364.0101 Administration. Except for IMC section 102.8, the requirements in IMC chapter 1 are not included as part of this chapter.

History: [CR 16-094](#); cr. [Register April 2018 No. 748](#), eff. 5-1-18.

SPS 364.0202 Definitions. (1) ADDITIONS. These are department definitions in addition to the definitions for this chapter in IMC section 202:

(am) “DHS” means the department of health services.

(b) “Enclosed parking garage” means an enclosed building where motorized vehicles are stored or parked.

(d) “Health care facility” means a hospital, nursing home, outpatient surgical facility, or community-based residential facility.

(e) “Living area” means those areas within a dwelling unit involving living rooms, bedrooms, dens, family rooms, and recreation rooms, but not rooms used for cooking, bathing, washing, and sanitation purposes.

(f) “Motorized vehicle” means a self-propelled motor-driven vehicle that is used for moving people or products on land, water, or air. “Motorized vehicle” does not include a boat that is dry stored and not operated in the building in which it is stored.

Note: “Motorized vehicle” in this definition is intended to apply to motorized equipment transporting people and goods for pleasure, construction or commerce, rather than equipment dedicated to warehousing and yard operations, such as forklifts; or for grounds and facility maintenance, such as lawnmowers; or for amusement facilities, such as go-carts.

(2) SUBSTITUTIONS. Substitute the following meanings for the corresponding definitions in IMC section 202: “Approved” has the meaning given in s. [SPS 362.0202 \(2\)](#).

History: CR 00-179: cr. [Register December 2001 No. 552](#), eff. 7-1-02; CR 01-139: r. (2) (b), [renum. \(2\) \(c\) to be \(2\) \(b\)](#) [Register June 2002 No. 558](#), eff. 7-1-02; correction in (2) (b) made under s. 13.93 (2m) (b) 7., Stats., [Register April 2003 No. 568](#); [CR 06-120](#): am. (1) (intro.), r. (1) (a), (b) and (2) (b), r. and recr. (1) (d), [renum. \(2\) \(a\) to be \(2\) \(b\)](#) [Register February 2008 No. 626](#), eff. 3-1-08; correction in (2) made under s. 13.92 (4) (b) 1., Stats., [Register February 2008 No. 626](#); corrections in (1) (c) made under s. 13.92 (4) (b) 6., Stats.; [CR 10-103](#): am. (1) (d) [Register August 2011 No. 668](#), eff. 9-1-11; corrections in (2) made under s. 13.92 (4) (b) 1., 7., Stats., [Register August 2011 No. 668](#); correction in (2) made under s. 13.92 (4) (b) 7., Stats., [Register December 2011 No. 672](#); [CR 16-094](#); cr. (1) (b), [renum. \(1\) \(c\) to \(1\) \(am\)](#), [am. \(1\) \(d\)](#), cr. (1) (e), (f) [Register April 2018 No. 748](#), eff. 5-1-18.

SPS 364.0300 Health care facilities. (1) This is a department rule in addition to the requirements in IMC chapter 3: In addition to the requirements in chs. [SPS 361 to 366](#), the heating and ventilation systems for health care facilities only shall conform to the applicable provisions of FGI Guidelines for Design and Construction of Hospitals and Outpatient Facilities 2014, except as provided in sub. (2).

Note: The Guidelines for Design and Construction of Health Care Facilities are not intended for use in the design or construction of HVAC systems for other types of institutional health care facilities including community-based residential facilities (CBRFs) or residential care apartment complexes (RCACs).

(2) (a) The requirements in parts 1 and 5 of FGI guidelines are not included as part of this chapter.

(b) This is a department rule in addition to the requirements in part 6 of the FGI guidelines: Addenda a, b, d, e and f for ASHRAE 170 are included as part of this chapter, except as provided in sub. 2.

(c) Substitute the following definition for the corresponding definition listed in ASHRAE 170 section 3: "Alteration", has the meaning as given in IEBC section 202.

Note: IEBC section 202 defines "alteration" as "any construction or renovation to an existing structure other than a repair or addition. Alterations are classified as Level 1, Level 2, and Level 3".

History: CR 06-120: cr. Register February 2008 No. 626, eff. 3-1-08; CR 10-103: renum. to (1), cr. (2) Register August 2011 No. 668, eff. 9-1-11; CR 16-094: am. (1) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0301 General regulations. (1) SCOPE. Substitute the following wording for the requirements in IMC section 301.1: This chapter shall govern the approval and installation of all equipment and appliances that comprise parts of the building mechanical systems regulated by chs. SPS 361 to 366 in accordance with subch. I.

(2) ENERGY UTILIZATION. This is a department informational note to be used under IMC section 301.7.

Note: See ch. SPS 363 for additional requirements.

(3) LISTED AND LABELED. Substitute the following wording for the requirements in IMC section 301.7:

(a) *General.* All appliances regulated by this chapter shall be listed and labeled as specified in this chapter, unless approved by the department in accordance with par. (b) or the product approval criteria in s. SPS 361.50.

(b) *Unlisted appliances.* The department may approve an installation of an unlisted appliance after receipt of all of the following:

1. A statement from the appliance manufacturer indicating the national standard with which the appliance complies.

2. The results of a test on the output and safety controls in accordance with the national standard used by the manufacturer.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 01-139: r. and recr. (2) (a) and (b) Register June 2002 No. 558, eff. 7-1-02; CR 04-016: renum. (1) to (4) to be (2) to (5) and am. (3) (a), cr. (1) Register December 2004 No. 588, eff. 1-1-05; CR 06-120: am. (3) (b), r. (4) and (5) Register February 2008 No. 626, eff. 3-1-08; CR 10-103: am. (3) (b) 2. Register August 2011 No. 668, eff. 9-1-11; correction in (3) (a) made under s. 13.92 (4) (b) 7., Stats., Register December 2011 No. 672; CR 16-094: am. (1) to (3) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0304 Installation. This is a department informational note to be used under IMC section 304.2:

Note: See s. SPS 361.03 (3) for clarification on the application of different requirements and where the most restrictive requirements apply.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02.

SPS 364.0307 Auxiliary and secondary drain systems. The requirements in IMC section 307.2.3 are not included as part of this chapter.

History: CR 10-103: cr. Register August 2011 No. 668, eff. 9-1-11.

SPS 364.0309 Temperature control. These are department exceptions to the requirements in IMC section 309.1:

(1) ALTERNATE MINIMUMS. For those interior spaces intended for human occupancy listed in Table 364.0309, the heating system shall be capable of maintaining an indoor temperature of not less than that shown in the table at 3 feet above the floor.

**Table 364.0309
Alternate Minimum Indoor Temperature**

Occupancy Types	Minimum Indoor Temperature (degrees F)
Dry cleaners, laundries, laundry rooms	60
Educational training shops	60
Commercial kitchens	60
Health care facilities, hospitals, nursing homes, ambulatory surgery centers	Footnote a.
Factories and machine shops	60
Foundries	NMR
Sawmills	NMR
Garages at private dwellings	NMR
Automotive service and repair garages	60
Car washes, enclosed:	NMR
Self-serve	60
All other types	
Ice skating rinks (indoor)	NMR
Natoriums	76
Roller skating rinks (indoors)	60
Storage	NMR
Elevator cars	NMR
Janitor closets	NMR
Locker and dressing rooms	70
Shower rooms	70
Food processing	NMR
Printing	60

NMR = No minimum requirement

a. For indoor temperature requirements in health care facilities, use FGI Guidelines for Design and Construction of Hospitals and Outpatient Facilities, 2014.

(2) SEASONAL OCCUPANCIES. The heating requirements but not the ventilation requirements may be waived during the period of May 1 through October 15 for the following or similar occupancies: drive-in eating places, club houses, outdoor toilets, camp lodge buildings, canning factories and migrant labor camps.

(3) SPOT HEATING. Spot heating may be used to heat individual workstations in industrial buildings in lieu of heating the entire space specified in IMC section 309, provided the design temperature at the fixed workstation is at least 60° F.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 01-135: am. (1) Register June 2002 No. 558, eff. 7-1-02; CR 06-120: r. and recr. Register February 2008 No. 626, eff. 3-1-08; correction in (1) made under s. 13.92 (4) (b) 7., Stats., Register December 2011 No. 672; CR 16-094: am. (1), Table 364.0309, cr. (3) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0312 Heating and cooling load calculations. This is a department informational note to be used under IMC section 312:

Note: For design parameters in the IECC refer to ch. SPS 363 or IECC section C403.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02.

SPS 364.0313 Other requirements. These are department rules in addition to the requirements in IMC chapter 3:

(1) **BALANCING, FINAL TEST REQUIRED.** Every heating, ventilating and air conditioning system shall be balanced upon installation. The person or agency responsible for balancing of the ventilating system shall document in writing the amount of outdoor air being provided and distributed for the building occupants and any other specialty ventilation. The document shall be retained at the site and shall be made available to the department upon request.

(a) Air systems shall be balanced in a manner to minimize losses from damper throttling by first adjusting fan speed then adjusting dampers to meet design flow conditions. Balancing procedures shall be acceptable to the department. Damper throttling alone may be used for air system balancing with fan motors of 1 hp or less, or if throttling results in no greater than 1/3 hp fan horsepower draw above that required if the fan speed were adjusted.

(b) Either of the following test methods shall be used:

1. Hydronic systems shall be balanced in a manner to minimize valve throttling losses by first trimming the pump impeller or adjusting the pump speed then adjusting the valves to meet design flow conditions.

2. Valve throttling alone may be used for hydronic system balancing under any of the following conditions as specified in subd. 2. a. to d.

a. Pumps with pump motors of 10 hp or less.

b. If throttling results in no greater than 3 hp pump horsepower draw for pumps of 60 hp or less, or no greater than 5% of pump horsepower draw for pumps greater than 60 hp, above that required if the impeller were trimmed.

c. To reserve additional pump pressure capability in open circuit piping systems subject to fouling. Valve throttling pressure drop shall not exceed that expected for future fouling.

d. Where it can be shown that throttling will not increase overall building energy costs.

Note: National Environmental Balancing Bureau (NEBB) Procedural Standards, the Associated Air Balance Council (AABC) National Standards, the Sheet Metal and Air Conditioning Contractors National Association, Inc. (SMACNA), or equivalent balancing procedures are acceptable to the department.

(2) **BALANCING, PROPER WORKING CONDITION.** HVAC control systems shall be tested to assure that control elements are calibrated, adjusted and in proper working condition.

(3) **BALANCING, OPERATING AND MAINTENANCE MANUALS.** (a) The designer or installer shall provide the owner with written instructions for the operation and maintenance of the HVAC systems and equipment. An operating and maintenance manual shall be provided to the building owner or operator. The manual shall include basic data relating to the operation and maintenance of heating, ventilating and air conditioning (HVAC) systems and equipment.

(b) Required routine maintenance actions shall be clearly identified. Where applicable, HVAC controls information such as diagrams, schematics, control sequence descriptions, and maintenance and calibration information shall be included.

(4) **APPLICABILITY.** This is a department rule in addition to the requirements in IMC chapter 1:

(a) The designer or installer shall provide the owner with written instructions for the operation and maintenance of the system and equipment. An operating and maintenance manual shall be provided to the building owner or operator. The manual shall include basic data relating to the operation and maintenance of

heating, ventilating and air conditioning (HVAC) systems and equipment.

(b) Required routine maintenance actions shall be clearly identified. Where applicable, HVAC controls information such as diagrams, schematics, control sequence descriptions, and maintenance and calibration information shall be included.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 06-120: r. and recr. (3) Register February 2008 No. 626, eff. 3-1-08; CR 10-103: (4) renun. from Comm 64.0102 Register August 2011 No. 668, eff. 9-1-11.

SPS 364.0401 Ventilation. (1) VENTILATION REQUIRED. (a) These are department rules in addition to the requirements in IMC section 401.2:

1. Natural ventilation shall be in accordance with s. SPS 364.0402.

2. Mechanical ventilation shall be in accordance with IMC section 403 and as modified in ss. SPS 364.0403 (1) to (6).

3. Chemical or septic toilets and composting privies are prohibited in spaces under negative pressure. Toilet rooms with chemical or septic toilets shall be provided with natural ventilation via a window, louver or skylight with at least 2 square feet of area openable directly to the outside per septic vault or per chemical toilet. The opening shall be provided with a screen to limit the passage of insects and vermin.

(b) These are department exceptions to the requirements of IMC section 401.2:

1. Outdoor air ventilation by natural or mechanical means shall be permitted to be omitted in large volume spaces containing 5,000 or more cubic feet per occupant.

2. A toilet room that has only one water closet or urinal and no bathtub or shower may be provided with either natural ventilation via a window or louvered opening with at least 2 square feet of area openable directly to the outside or mechanical exhaust ventilation as specified in Table 364.0403.

3. A janitor closet that has only one service sink may be provided with either natural ventilation via a window or louvered opening with at least 2 square feet of area openable directly to the outside or mechanical exhaust ventilation as specified in Table 364.0403.

(2) **WHEN REQUIRED.** Substitute the following wording for the requirements of IMC section 401.3:

(a) Except as provided in par. (b), ventilation shall be provided during the periods that the room or space is occupied.

(b) Mechanical exhaust ventilation shall be provided for natoriums even when the space or building is not occupied.

(c) In addition to the criteria under s. 101.025 (1), Stats., the area that may be occupied by motorized vehicles shall be considered when establishing minimum quantities of outside air that must be supplied.

(4) **INTAKE OPENINGS.** (a) Substitute the following wording for the requirements in IMC introductory section 401.4: Air intake openings for both mechanical and gravity ventilation systems shall comply with all of the following:

(b) Substitute the following wording for the requirements in IMC section 401.4 item 2: Intake openings shall be located not less than 10 feet horizontally from any hazardous or noxious contaminant source except as specified in IMC section 401.4, item 3 and section 501.3.1.

(c) This is a department rule in addition to the requirements in IMC section 401.4: The lowest side of outside air intake required openings shall be located at least 12 inches vertically from the adjoining grade level, above adjoining roof surfaces, or above the bottom of an areaway.

(d) These are department exceptions in addition to the requirements in IMC section 401.4 and par. (c):

1. The setback distances as specified in IMC section 401.4 and par. (c) shall not apply to the combustion air intake of a direct vent appliance.

2. Where it can be demonstrated that an engineered system design will prevent the maximum concentration of contaminants brought in through the outside air intake from exceeding the maximum contaminant concentration obtainable by providing the separation distances in accordance with IMC section 401.4 and par. (c), the outdoor air intakes may be located in accordance with such engineered system design.

(e) Substitute the following wording for the wording in IMC section 401.4, item 1: Intake openings shall be located a minimum of 10 feet (3048 mm) from lot lines or buildings on the same lot. Where openings front on a street or public way, the distance shall be measured to the centerline of the street or public way.

Note: See ch. SPS 382 for plumbing vent setbacks. That rule requires plumbing vents to be 10 feet from air intakes and 10 feet horizontally from or 2 feet above roof scuttles, doors or openable windows.

Note: See NFPA standard 45, Fire Protection for Laboratories Using Chemicals, adopted under s. SPS 362.3500, for chemical fume hood exhaust location. Health care and related facilities may have additional requirements.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 01-135: r. and recr. (4) (a) (intro.), cr. (4) (a) 4. and (b) 5., CR 01-139: r. and recr. (4) (a) 3., am. (4) (b) 2. Register June 2002 No. 558, eff. 7-1-02; CR 06-120: r. and recr. (1), (2) and (4) (a), r. (3), (4) (b) 2. to 4., am. (4) (b) (intro.), 1. and (5) (intro.), renum. (4) (b) 5. to be (4) (b) 2. and am., cr. (6) Register February 2008 No. 626, eff. 3-1-08; CR 10-103: r. and recr. (1), renum. (4) (a) and (b) to be (4) (c) and (d) and am., cr. (4) (a) and (b), renum. (5) and (6) to be Comm 64.0501 (3) and (5) Register August 2011 No. 668, eff. 9-1-11 correction in (1) (a) 1., 2., (b) 2., 3. made under s. 13.92 (4) (b) 7., Stats., Register December 2011 No. 672; CR 16-094: (1) (a) 3. renum. from SPS 364.0407 and am., cr. (2) (c), am. (4) (b), cr. (4) (e) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0402 Natural ventilation. This is a department rule in addition to the requirements in IMC section 402: The use of natural ventilation shall be permitted under either of the following:

- (1) In occupancies specified in Table 364.0402.
- (2) For any occupancy, provided an engineered design indicates how the ventilation satisfies the needs of the occupancy.

**Table 364.0402
Natural Ventilation
Allowed for Specific Occupancies
Occupancy Classification**

Occupancy Classification		
<p>Correctional Facilities Cells without plumbing features Dining halls < 100 persons Guard stations Day room Booking/waiting</p> <p>Dry cleaners, laundries Coin-operated dry cleaners Coin-operated laundries Storage, pick up</p> <p>Education Auditoriums < 100 persons Media center Music/theatre/dance Day care facilities < 20 children (through age 4) Multiuse assembly < 100 persons</p> <p>Food and beverage service Bars, cocktail lounges < 100 persons Dining rooms < 100 persons Kitchens (cooking)</p> <p>Hotels, motels, resorts and dormitories Multipurpose assembly < 100 persons Bedroom/living room Conference/meeting < 100 persons Dormitory sleeping areas Gambling casinos < 100 persons Lobbies/pre-function</p>	<p>Business areas Conference rooms < 100 persons Reception areas < 100 persons Main entry lobbies < 100 persons Lecture < 100 persons</p> <p>Public spaces Places of religious worship < 100 persons Courtrooms < 100 persons Legislative chambers < 100 persons Libraries < 100 persons Museums < 100 persons</p> <p>Dwellings Garages Kitchens Living areas</p> <p>Retail stores, sales floors, and showroom floors Sales Dressing rooms Mall common areas Storage rooms</p> <p>Specialty shops Pet shops (animal areas) Supermarkets Car washes Enclosed parking garages 850 S.F. or less in area and storing 5 or fewer vehicles</p>	<p>Sports and amusement Discos/dance floors < 100 persons Bowling alleys (seating areas) < 100 persons Game arcades < 100 persons Ice arenas without combustion Places of religious worship engines < 100 persons Gym, stadium, arena (play area) Spectator areas < 100 persons Swimming pools (pool and deck area) < 100 persons Health club/aerobics room < 100 persons Health club/weight room < 100 persons</p> <p>Theaters Auditoriums < 100 persons Lobbies < 100 persons Stages, studios < 100 persons</p> <p>Transportation Platforms < 100 persons Waiting rooms < 100 persons Aircraft hangars (with single aircraft and no adjacent occupancies)</p> <p>Workrooms Meat processing Pharmacy (prep. area) Photo studios Copy, printing rooms</p>

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 06-120: am. Register February 2008 No. 626, eff. 3-1-08; CR 10-103: r. and recr. Register August 2011 No. 668, eff. 9-1-11; correction in (1) made under s. 13.92 (4) (b) 7., Stats., Register December 2011 No. 672; CR 16-094: am. Table 364.0402 Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0403 Mechanical ventilation. (1) OUTDOOR AIR REQUIRED. (a) Substitute the following wording for the exception in IMC section 403.2: Where it can be demonstrated that an

engineered ventilation system design will prevent the maximum concentration of contaminants from exceeding the maximum obtainable by providing the rate of outdoor air ventilation deter-

mined in accordance with IMC section 403.3, as modified by subs. (2) to (6), the minimum required rate of outdoor air may be reduced in accordance with such engineered system design. A ventilation system complying with IMC section 403.3 without the modifications of subs. (2) to (6) is recognized as meeting this exception.

(b) This is a department rule in addition to the requirements in IMC section 403.2: The outdoor air shall be free from contamination of any kind in proportions detrimental to the health and comfort of the general population exposed to it.

(2) **RECIRCULATION OF AIR.** Substitute the following wording for exception 3 in IMC section 403.2.1: Where mechanical exhaust is governed by Table 364.0403 footnote c., recirculation of air from such spaces is prohibited. All air supplied to such spaces shall be exhausted, including any air in excess of that required by Table 364.0403.

(3) **RECIRCULATION OF AIR.** This is a department informational note to be used under IMC section 403.2.1:

Note: The following are examples where the department will accept air transferred from: corridor to toilet room; corridor to cloak room or janitor closet; dining room to kitchen; locker room to toilet room; gymnasium to locker room; showroom to garage; and corridor to school vocational shops.

(4) **TRANSFER AIR.** Substitute the following wording for the requirements in IMC section 403.2.2: Except where recirculation from such spaces is prohibited by Table 364.0403, air transferred from occupied spaces is not prohibited from serving as makeup air for required exhaust systems in such spaces as kitchens, baths, toilet rooms, elevators and smoking lounges. The amount of transfer air and exhaust air shall be sufficient to provide the flow rates as specified in sub. (5). The required outdoor air rates specified in Table 364.0403 shall be introduced directly into such spaces or into the occupied spaces from which air is transferred or a combination of both.

(5) **VENTILATION RATE.** Substitute the following wording for the requirements and exception in IMC section 403.3:

(a) *Ventilation rate determination.* 1. Except as provided in sub. (1) (a) and s. SPS 364.0300, a mechanical ventilation system shall be designed to have the capacity to supply a minimum outdoor airflow rate of 7.5 cfm per person as determined in accordance with Table 364.0403 based on the occupancy of the space and the occupant load or other parameters stated therein. A mechanical ventilation system shall be designed to have the capacity to exhaust air as specified in Table 364.0403 except as provided in par. (c).

2. a. Except as provided in subd. 2. b. to d., the occupant load utilized for design of the ventilation system shall not be less than the number determined from the estimated maximum occupant load rate indicated in Table 364.0403.

b. The estimated maximum occupant load rate may be determined using other means with justification acceptable to the department to show that a different number of occupants is reasonable.

c. Where there is no value indicated for the net square feet per person in Table 364.0403, the actual number of occupants shall be used to determine the required amount of outside air.

d. Ventilation rates for occupancies not represented in Table 364.0403 shall be determined by an approved engineering analysis, or by using the most similar occupancy in the table.

(b) *Adjacent spaces with differing ventilation requirements.* 1. Except as provided in subd. 2., spaces with different ventilation requirements shall be provided with a complete solid separation, or the most stringent ventilation requirement shall apply to all unseparated areas.

2. The separation as specified in subd. 1. is not required where an engineered ventilation design system will prevent the con-

centration of contaminants from exceeding that obtainable by providing a physical separation.

(c) *Exceptions for certain occupancies.* 1. 'Toilet rooms.' A toilet room that has only one water closet or urinal and no bathtub or shower may be provided with either natural ventilation via a window or louvered opening with at least 2 square feet of area openable directly to the outside or mechanical exhaust ventilation as specified in Table 364.0403.

2. 'Janitor closets.' A janitor closet that has only one service sink may be provided with either natural ventilation via a window or louvered opening with at least 2 square feet of area openable directly to the outside or mechanical exhaust ventilation as specified in Table 364.0403.

3. 'Locker and shower rooms.' An adjoining locker room, shower room and toilet room shall be exhausted at the rate specified in Table 364.0403 based on the largest amount of exhaust required for any of the three rooms. A negative pressure relationship shall be maintained in the shower and toilet rooms with respect to the locker room.

5. 'Pool ventilation.' In a natatorium, the volume of supply air and exhaust air may be reduced to a minimum of 1 cfm per square foot of pool surface provided automatic humidity controls perform so as not to create accelerated building material deterioration from moisture condensation.

(d) *Common ventilation system airflow.* 1. Substitute the following wording for the requirements in IMC sections 403.1.1.1 through 403.3.1.1.2.3.4: Where multiple spaces having different ventilation rate requirements are served by a common ventilation system, the minimum amount of outdoor airflow supplied by the ventilation system shall equal the total outdoor airflow required for each space if each space is provided with minimum air changes in accordance with this paragraph.

2. a. Except as provided in subd. 3., an air change rate of 6 air changes per hour shall be provided in each space.

b. The air change air rate under this subsection shall be determined upon either the actual height of the space or 10 feet from the floor level of the space which ever is less.

c. The air movement providing the required minimum air change shall be that amount that is transferred through the air handling equipment where the return air is diluted or replaced with outside air and supplied back to the space.

3. Air change rate of less than 6 air changes per hour is permitted where mechanical cooling is provided to maintain an interior design temperature of 75 degrees F or lower. The air change rate may not be less than the alternative minimum air change rate per hour specified in Table 364.0403. Air changes are not required to be provided for spaces required to be mechanically exhausted.

4. The air change requirement for 6 air changes per hour may be omitted in any of the following applications:

a. Buildings or rooms utilizing spot heating as the only source of heat.

b. Buildings where the requirement for outside air is waived in accordance with s. SPS 364.0401 (1) (b) 1.

c. Buildings utilizing natural ventilation as specified in IMC section 402.

(6) **SYSTEM OPERATION.** Substitute the following wording for the requirements in IMC section 403.3.1.3: The minimum flow rate of outdoor air that the ventilation system must be capable of supplying during its operation may be based on the rate per person indicated in Table 364.0403 and the actual number of occupants present.

(7) **R-2, R-3, AND R-4 OCCUPANCIES.** The requirements of IMC section 403.3.2 are not included as part of chs. SPS 361 to 366.

**Table 364.0403
Ventilation Requirements**

Occupancy Classification	Estimated Maximum Occupant Load (persons per 1,000 sq. ft.)^a	Exhaust^c (cfm/net sq. ft. floor area)	Common Ventilation System Alternative – Minimum AC Rate per hour with A/C
<u>Correctional facilities</u>			
Sleeping rooms ^d	20	NR	2.0
Dining halls	100	NR	2.0
Guard stations	40	NR	1.5
<u>Dry cleaners, laundries</u>			
Coin-operated dry cleaners	8	NR	1.0
Coin-operated laundries	8	NR	1.0
Commercial dry cleaners	NA	2.0	NR
Commercial laundries	NA	2.0	NR
Storage, pick up	8	NR	1.0
Apartment laundry rooms	NA	0.5	NR
<u>Dwellings, single and multiple</u>			
Living areas	2 persons for first bedroom, plus one person for each additional bedroom	NR	1.0
Kitchens ^d	NA	100 cfm intermittent or 20 cfm continuous	NR
Toilet rooms and bathrooms ^d	NA	Mechanical exhaust capacity 50 cfm intermittent or 20 cfm continuous per room ^j	NR
Garages, separated by a solid wall for each dwelling	NA	100 cfm/vehicle	NR
Garages, common for multiple units ^c	NA	0.5	NR
<u>Education</u>			
Auditoriums	150	NR	2.0
Classrooms	50	NR	2.0
Day care facilities	30	NR	2.0
Laboratories (science)	30	NR	2.0
Music rooms	50	NR	2.0
Special education	35	NR	2.0
Training shops	30	NR	2.0
<u>Food and beverage service</u>			
Bars and cocktail lounges	100	NR	2.0
Cafeterias, fast food	100	NR	2.0
Dining rooms	70	NR	2.0
Kitchens (cooking) ^{d, e}	20	NR	1.0
<u>Health care facilities</u>			
Hospitals	See s. SPS 364.0300	See s. SPS 364.0300	See s. SPS 364.0300
Nursing homes	See s. SPS 364.0300	See s. SPS 364.0300	See s. SPS 364.0300
Outpatient surgical facilities	See s. SPS 364.0300	See s. SPS 364.0300	See s. SPS 364.0300
<u>Hotels, motels, resorts and dorms</u>			
Assembly rooms	120	NR	2.0
Bathrooms for guest rooms ^{c, d}	NA	35 cfm/room	NR
Bedrooms	footnote f	NR	1.0
Conference rooms	50	NR	2.0
Dormitory sleeping areas	20	NR	1.0
Casinos	NA	2.0	NR
Living rooms	footnote f	NR	1.0
Lobbies	30	NR	2.0
<u>Industrial/Factory</u>			

Table 364.0403 (Continued)
Ventilation Requirements

Occupancy Classification	Estimated Maximum Occupant Load (persons per 1,000 sq. ft.)^a	Exhaust^c (cfm/net sq. ft. floor area)	Common Ventilation System Alternative – Minimum AC Rate per hour with A/C
Factories and machine shops	13	NR	NR
Foundries	13	NR	NR
Sawmills	NA	NR	NR
<u>Offices</u>			
Conference rooms	50	NR	1.5
Office spaces	7	NR	1.5
Reception areas	60	NR	1.5
Telecommunication centers and data entry	60	NR	1.5
<u>Retail stores, sales floors and showroom floors</u>	8	NR	1.0
<u>Seasonal occupancies, camps and lodges</u>			
Dining and recreational areas	70	NR	1.0
Living and sleeping areas	NA	NR	1.0
Club houses	15	NR	1.0
Drive-ins	15	NR	1.0
<u>Specialty shops</u>			
Automotive service and repair garages for gasoline or diesel fueled vehicles ^{c, k, l}	NA	0.5	NR
Barber shops	25	NR	1.0
Beauty salons ^h	NA	0.5	NR
Car washes	NA	NR	NR
Clothier, furniture shops	8	NR	1.0
Florist shops	8	NR	1.0
Hardware, drugs, fabrics stores	8	NR	1.0
Nail salons ^m	NA	0.6	NR
Supermarkets	8	NR	1.0
<u>Sports and amusement</u>			
Ballrooms and discos	100	NR	2.0
Bleacher areas	363 or 18 in./person	NR	2.0
Bowling centers (seating areas)	70	NR	2.0
Game rooms	70	NR	2.0
Ice skating rinks (indoor)	5	NR	NR
Natatoriums	NA	2.0 cfm/sq. ft. pool area	NR
Playing floor (gymnasiums)	30	NR	2.0
Roller skating rinks (indoor)	30	NR	2.0
Spectator areas (non-bleacher)	150	NR	2.0
<u>Storage</u>			
Chlorine storage and handling rooms	NA	2.0	NR
Enclosed parking garages ^{l, n}	NA	0.5	NR
Warehouses ^o	NA	NR	NR
<u>Theaters</u>			
Auditoriums	150	NR	2.0
Lobbies	150	NR	2.0
Stages, studios	70	NR	2.0
Ticket booths	60	NR	2.0
<u>Transportation</u>			
Platforms	100	NR	2.0

Table 364.0403 (Continued)
Ventilation Requirements

Occupancy Classification	Estimated Maximum Occupant Load (persons per 1,000 sq. ft.) ^a	Exhaust ^c (cfm/net sq. ft. floor area)	Common Ventilation System Alternative – Minimum AC Rate per hour with A/C
Waiting rooms	100	NR	2.0
Aircraft hangars (for 2 or more aircraft or any hangar with adjacent occupancies)	NA	0.5	NR
<u>Utility and public spaces</u>			
Elevator cars	NA	1.0	NR
Janitor closets	NA	2.0 or 75 cfm/sink ^g	NR
Locker and dressing rooms ^c	NA	0.5	NR
Shower rooms (per shower head)	NA	50 cfm intermittent or 20 cfm continuous	NR
Toilet rooms ^{c, d}	NA	75 cfm/TF ^g	NR
<u>Workrooms</u>			
Bank vault	5	NR	NR
Meat processing	10	NR	NR
Pharmacy	20	NR	1.5
Photo studio	10	NR	1.0
Printing	13	footnote j	NR

NA = not applicable; NR = none required; cfm = cubic feet per minute; TF = toilet fixtures (water closets and urinals); A/C = air conditioning

a. Based upon net floor area.

b. The ventilation rate is based upon cubic feet per minute per square foot of the floor area being ventilated.

c. Mechanical exhaust is required and the recirculation of air from these spaces that would otherwise be allowed by IMC section 403.2.1 is prohibited.

d. Transfer air is permitted in accordance with IMC section 403.2.2.

e. Provide an exhaust rate of not less than 1.5 cfm/sf.

f. The minimum mechanical ventilation rate is 15 cfm/room of outside air.

g. Natural ventilation may be allowed under this section.

h. The classification of a 'beauty' salon depends on the types of services provided. Only beauty salons that routinely provide chemical processing of hair to produce texture or color changes.

i. Enclosed parking garages are parking garages that fail to meet the criteria for open garages in IBC section 406.5.2. Ventilation systems in enclosed parking garages shall comply with IMC section 502.13. A mechanical ventilation system may not be required if the room or space meets all of the following:

1. Has a floor area of 850 square feet or less.
2. Used for the storage of 5 or fewer motorized vehicles.
3. Meets the natural ventilation requirements of IMC 402 and s. SPS 364.0402.

j. Refer to IMC chapter 5 for exhaust requirements based upon the chemicals used.

k. For compressed natural gas IMC 502.16.

l. Mezzanine floor areas that are open to a service and/or repair area may not be included as floor area when determining the minimum exhaust rate from the room or space.

m. For nail salons, the required exhaust shall include ventilation tables or other systems that capture the contaminants and odors. The exhaust system shall be capable of exhausting the greater of 50 cfm per station or 0.6 cfm per square foot of work area. The exhaust inlet shall be located in the work area.

n. The requirements for enclosed parking garages shall apply to all buildings, or rooms, spaces, or parts of buildings, into which motor vehicles are being driven for loading or unloading, or that are stored.

o. Warehouses include indoor drive-through self-service storage facilities in which a customer may temporarily park a motorized vehicle for purposes of loading and unloading materials, provided the motor is not running.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 01-135: renum. (3) to be (3) (b), cr. (3) (a), (4) (a) 6. and (5) (d), am. (5) (a), (b) 1. a., (c) 1. and (6) Table; CR 01-139: renum. (3) to (6) to be (4), (6), (8) and (9), cr. (3), (5) and (7), am. (6) Table, r. and recr. (6) Register June 2002 No. 558, eff. 7-1-02; CR 04-016: am. Table 64.0403 Register December 2004 No. 588, eff. 1-1-05; CR 06-120: r. (1), (4) (a), (6) (a) 3., 6. and (d), am. (2) (a) and (3), renum. (4) (b) to be (4), r. and recr. (6) (intro.), (a) 1., (8) and Table 64.0403 Register February 2008 No. 626, eff. 3-1-08; CR 10-103: r. (6) (c) 4., (9), r. and recr. Table 64.0403, renum. (2) to (7), (8) to (1) to (6), (5) (d) and am. Register August 2011 No. 668, eff. 9-1-11; correction in (2), (4), (5) (a) 1., 2. a., c., d., (c) 1., 2., 3., (d) 2. d., (6), Table 346.0403 made under s. 13.92 (4) (b) 7., Stats., Register December 2011 No. 672; CR 16-094: am. (5) (d) 1., renum. (5) (d) 2. d. to (d) 3. and am., cr. (5) (d) 4., am. (6), cr. (7), am. Table 364.0403 Register April 2018 No. 748, eff. 5-1-18; correction in (4), (5) (d) 2. a. made under s. 13.92 (4) (b) 7., Stats., Register April 2018 No. 748.

SPS 364.0404 Enclosed parking garages. Substitute the following wording for the requirements in IMC sections 404.1 and 404.2:

(1) Mechanical ventilation systems for enclosed parking garages shall be permitted to operate intermittently by one of the following methods:

(a) The system shall be arranged to operate continuously at a minimum exhaust rate of 0.05 cfm/sf. Subsequently, the system shall operate at a minimum of 0.75 cfm/sf automatically upon detection of vehicle operation, the presence of occupants, or by a combination of occupancy sensors and carbon monoxide and nitrogen dioxide sensors as appropriate for the room or space. The

system shall also be designed so to address the requirements listed in s. SPS 364.0404 (2) and (3).

(b) The system shall be arranged to operate intermittently for a total of at least 5 hours in each 24-hour period at a minimum rate of 0.75 cfm/sf and shall also include the installation of carbon monoxide and nitrogen dioxide sensors as appropriate for the room or space. The system shall also be designed so to address the requirements listed in s. SPS 364.0404 (2) and (3).

(2) (a) The system shall be arranged to operate automatically upon detection of carbon monoxide at a level of 35 parts per million by automatic detection devices.

(b) If diesel-fueled vehicles are stored, the system shall be arranged to operate automatically upon detection of nitrogen dioxide at a level of one part of per million by automatic detection devices.

(3) The system shall maintain the garage at negative or neutral pressure relative to other spaces.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 01-139: r. and recr. (1) Register June 2002 No. 558, eff. 7-1-02; CR 06-120: r. and recr. Register February 2008 No. 626, eff. 3-1-08; CR 10-103: am. (1) and (2) (c) Register August 2011 No. 668, eff. 9-1-11; CR 16-094: r. and recr. Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0501 General. (1) Substitute the following wording for the requirements in IMC section 501.1: This chapter shall govern the design, construction and installation of mechanical exhaust systems, including exhaust systems serving clothes dryers and cooking appliances; environmental air exhaust systems; hazardous exhaust systems; dust, stock and refuse conveyor systems; subslab soil exhaust systems; smoke control systems; energy recovery ventilation systems and other systems specified in IMC Section 502.

(2) This is a department exception to the requirements in IMC section 501.3: A mechanically exhausted room or space that is within a dwelling unit which is served by an independent heating, ventilating and air conditioning system is not required to be maintained with negative or neutral pressure.

(3) These are department rules in addition to the requirements in IMC section 501.2.1.

(a) Gravity ventilation ducts shall extend not less than 2 feet above the highest portion of the building within a 10-foot radius of the duct and shall be provided with a siphon roof ventilator.

(b) Where barometric relief vents are installed on the roof, the discharge openings shall be no less than 2 feet above the roof surface where the vent pierces the roof.

(5) Substitute the following wording for the requirements in IMC section 401.6: Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be injurious to health shall be provided with an exhaust system in accordance with IMC chapter 5 or a means of collection and removal of the contaminants. Such exhaust shall discharge directly to an approved location at the exterior of the building.

(6) These are department rules in addition to IMC section 501.3.2: The bottom of an exhaust outlet shall be located at least 12 inches vertically from the adjoining grade level and bottom of an areaway. Additional clearance may be required so as to address local weather conditions and surrounding land contour.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 06-120: am. Register February 2008 No. 626, eff. 3-1-08; CR 10-103: renun. to be (2), cr. (1), (3), (5) renun. from Comm 64.0401 (5), (6) and am. Register August 2011 No. 668, eff. 9-1-11; corrections in (3) and (5) made under s. 13.92 (4) (b) 2., Stats., Register August 2011 No. 668; CR 16-094: cr. (6) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0502 Required systems. (1) Substitute the following wording for the requirements in IMC section 502.1: An exhaust system shall be provided, maintained and operated as specifically required by this section and for all occupied areas where machines, vats, tanks, furnaces, forges, salamanders and other appliances, equipment and processes in such areas produce or throw off dust particles sufficiently light to float in the air or which emit heat, odors, fumes, spray, gas or smoke, in such quantities to be injurious to health or safety.

(2) This is a department exception in addition to the exceptions in section IMC 502.14: The source capture system is not required when the motor vehicle exhaust system is connected directly to a noncombustible hose that is not more than 10 feet long and discharges directly to the exterior of the building.

Note: Under s. SPS 361.03 (14) (a), IFC section 2311.7 exempts a natural-gas motor-vehicle repair garage from the requirements of IMC section 502.16 if no work

is performed on the fuel system in the vehicles, and the work is also limited to exchanging parts and maintenance that does not include any open flame or welding.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 10-103: renun. to be (1), cr. (2), Register August 2011 No. 668, eff. 9-1-11.

SPS 364.0505 Domestic kitchen exhaust equipment. The requirements in IMC section 505.4 are not included as part of chs. SPS 361 to 366.

History: CR 16-094: cr. Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0506 Commercial kitchen grease ducts and exhaust equipment. (2) JOINTS, SEAMS AND PENETRATIONS OF GREASE DUCTS. (a) This is a department alternative to the requirements, but not the exceptions, in IMC section 506.3.2: Joints, seams and penetrations of grease ducts may be made with any other means that provide a liquid-tight seal at 1500°F and that are listed and labeled for the application.

(b) This is a department rule in addition to the requirements in IMC section 506.3.2.: Duct joints may also be flanged joints.

(c) The requirements of IMC section 506.3.2.5 are not included as part of this chapter.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 06-120: r. (1) and (2) (c), am. (2) (title) and (a), r. and recr. (2) (b), cr. (2) (bm) Register February 2008 No. 626, eff. 3-1-08; CR 10-103: renun. (2) (bm) to be (2) (c) and am. Register August 2011 No. 668, eff. 9-1-11.

SPS 364.0507 Commercial kitchen hoods.

(1) CAPACITY OF HOODS. Substitute the following wording for the introductory paragraph in IMC section 507.5: Commercial food service hoods shall exhaust a minimum net quantity of air determined either through engineering analysis or in accordance with this subsection and IMC sections 507.5.1 through 507.5.4. The net quantity of exhaust air shall be calculated by subtracting any airflow supplied directly to a hood cavity from the total exhaust flow rate of a hood. Where any combination of heavy-duty, medium-duty, and light-duty cooking appliances are utilized under a single hood, the exhaust rate required by IMC sections 507.5.1 through 507.5.4 for the heaviest duty appliance covered by the hood shall be used for the entire hood.

(2) DISHWASHING APPLIANCES. The requirements of IMC section 507.5.5 are not included as part of this chapter.

(3) MULTIPLE HOODS UTILIZING A SINGLE EXHAUST SYSTEM. The requirements in IMC section 507.1.1.1 are not included as part of chs. SPS 361 to 366.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 01-139: am. Register June 2002 No. 558, eff. 7-1-02; CR 04-016: renun. to be (3) and am., cr. (1) and (2) Register December 2004 No. 588, eff. 1-1-05; CR 06-120: r. and recr. Register February 2008 No. 626, eff. 3-1-08; CR 16-094: am. (1), (2), cr. (3) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0513 Smoke control systems. Substitute the following wording for the requirements in IMC section 513.3: In addition to the inspection and test requirements which buildings, structures and parts thereof are required to undergo, smoke control systems subject to the provisions of section 909 of the *International Building Code* shall undergo inspections and tests sufficient to verify the proper commissioning of the smoke control design in its final installed condition. The design submission accompanying the construction documents shall clearly detail procedures and methods to be used and the items subject to such inspections and tests. Such commissioning shall be in accordance with generally accepted engineering practice and, where possible, based on published standards for the particular testing involved.

History: CR 04-016: cr. Register December 2004 No. 588, eff. 1-1-05.

SPS 364.0514 Energy recovery ventilation systems. This is a department exception to the prohibitions in IMC section 514.2: An engineered energy recovery ventilation system design may be used in the systems specified in IMC section 514.2 provided that corrosion, cross-contamination and fouling are addressed by the engineered system.

History: CR 06-120: cr. Register February 2008 No. 626, eff. 3-1-08; CR 10-103: am. Register August 2011 No. 668, eff. 9-1-11.

SPS 364.0601 General. Substitute the following wording for the requirements in IMC section 601.2 Exception 1: Use of a corridor as a source of makeup air for exhaust systems in rooms that open directly onto such corridors shall be permitted provided that each such corridor is directly supplied with air at a rate greater than the rate of makeup air taken from the corridor.

History: CR 06-120: cr. Register February 2008 No. 626, eff. 3-1-08; CR 10-103: am. Register August 2011 No. 668, eff. 9-1-11.

SPS 364.0602 Plenums. (1) This is a department rule in addition to the requirements in IMC section 602.2: Plenum enclosures shall be constructed of materials permitted for the type of construction classification of the building.

(2) Substitute the following wording for the requirements, but not the exceptions, in IMC section 602.2.1: Except as required by IMC sections 602.2.1.1 through 602.2.1.6, materials within plenums shall be noncombustible or shall have a flame spread index of not more than 25 and a smoke-developed index of not more than 50 when tested in accordance with ASTM E84, CAN/ULC S102.2 or UL 723.

History: CR 06-120: cr. Register February 2008 No. 626, eff. 3-1-08; CR 10-103: am. Register August 2011 No. 668, eff. 9-1-11; CR 16-094: renum. 364.062 to 364.062 (2) and am., cr. (1) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0606 Smoke detection system control.

(1) This is a department informational note to be used under IMC section 606.2.1: Note: For DHS licensed healthcare facilities as specified in chs. DHS 124, 131, 132, and 134, also refer to NFPA standard 90A section 4-4.2A for air handling units between 2,000 cfm and 15,000 cfm.

(2) This is a department informational note to be used under IMC section 606.4: Note: For DHS licensed healthcare facilities as specified in chs. DHS 124, 131, 132, and 134, also refer to NFPA standard 90A section 4-3.2 for smoke dampers isolating air handling units.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02.

SPS 364.0607 Ducts and air-transfer openings.

(1m) SMOKE DAMPER ACTUATION. This is an additional method in addition to the methods listed in IMC section 607.3.3.2: Method 6: Where a single listed duct smoke detector is installed inside the duct or outside the duct with sampling tubes protruding into the duct in the supply air ductwork downstream of the air handling equipment, including air filters, and ahead of any branch ductwork and return air duct smoke detectors are installed inside the duct or outside the duct with sampling tubes protruding into the duct within 5 feet (1524 mm) of each return air smoke damper, all supply and return smoke dampers shall be closed when any of the duct smoke detectors in the supply or return air ducts are in alarm. Other than in mechanical smoke control systems, dampers shall be closed upon fan shutdown when local smoke detectors require a minimum velocity to operate.

(2m) DUCT SMOKE DAMPERS. This is a department exception to the requirements in IMC section 607.5.5: Smoke dampers are not required in ducts that are used in the exhaust portion of laboratory ventilating systems that are designed and installed in accordance with NFPA 45.

(3m) PENETRATIONS OF SHAFT ENCLOSURES. This is a department exception to the requirements in IMC section 607.5.5: Smoke dampers are not required in ducts that are used in the exhaust portion of laboratory ventilating systems which are designed and installed in accordance with NFPA 45.

(4m) SMOKE DAMPERS IN HEALTH CARE FACILITIES. This is a department exception to the requirements in IMC section 607.5.4: Smoke dampers are not required in Group I-2 duct penetrations of smoke barriers in fully ducted HVAC systems.

History: CR 04-016: cr. Register December 2004 No. 588, eff. 1-1-05; CR 06-120: r. and recr. Register February 2008 No. 626, eff. 3-1-08; CR 16-094: renum. (1), (2) to (3m), (4m), cr. (1m), (2m) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0701 Combustible air. Barometric dampers may not be used for combustion air as allowed by IFC section 304.3 and NFPA 54-2015 section 9.3.1.4.

History: CR 16-094: cr. Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0801 Chimneys and vents. (1) This is a department informational note to be used under IMC chapter 8: Note: For DHS licensed healthcare facilities as specified in chs. DHS 124, 132, and 134, also refer to NFPA 211 as adopted in these chapters.

(2) This is a department rule in addition to the requirements in IMC section 801.2: Portable or permanently installed, fuel-fired, unvented heating appliances may not be installed except during construction or demolition of a building if the appliances are provided in accordance with ch. SPS 314.

Note: See s. SPS 365.0621 for use of portable or permanently installed, fuel-fired, unvented heating appliances.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 04-016: am. (2) Register December 2004 No. 588, eff. 1-1-05; CR 06-120: am. (2), cr. (3) Register February 2008 No. 626, eff. 3-1-08; CR 10-103: r. (3) Register August 2011 No. 668, eff. 9-1-11; correction in (2) made under s. 13.92 (4) (b) 7., Stats., Register December 2011 No. 672; CR 16-094: am. (2) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0802 Door swing. The requirements in IMC section 802.9 are not included as part of chs. SPS 361 to 366.

History: CR 16-094: cr. Register April 2018 No. 748, eff. 5-1-18.

SPS 364.0918 Forced-air warm-air furnaces.

(1) This is a department rule in addition to the requirements in IMC section 918.6: The outside air intake openings shall be located at least 12 inches vertical from the adjoining grade level.

(2) Substitute the following wording for the requirements in IMC section 918.6 item 2: Where located less than 10 feet above the surface of any abutting public way or driveway, or at grade level by a sidewalk, street, alley or driveway.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 10-103: r. (2), renum. (3) to be (2) Register August 2011 No. 668, eff. 9-1-11.

SPS 364.1001 Boilers, water heaters and pressure vessels. Substitute the following wording for the requirements and exceptions in IMC chapter 10:

(1) The provisions of ch. SPS 341 shall govern the installation, alteration and repair of boilers and pressure vessels. The provisions of chs. SPS 381 to 386 shall govern the installation, alteration and repair of water heaters.

(2) Water heaters utilized both to supply potable hot water and provide hot water for space-heating applications shall be listed and labeled by the manufacturer and shall be installed in accordance with the manufacturer's installation instructions and applicable provisions in chs. SPS 381 to 386.

(3) Water heaters utilized for both potable water heating and space-heating applications shall be sized to prevent the space-heating load from diminishing the required water-heating capacity.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 06-120: r. (4) Register February 2008 No. 626, eff. 3-1-08; correction in (1), (2) made under s. 13.92 (4) (b) 7., Stats., Register December 2011 No. 672.

SPS 364.1101 Refrigeration. Substitute the following wording for the requirements and exceptions in IMC chapter 11: Mechanical refrigerating systems installed in public buildings and places of employment shall comply with ch. SPS 345.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; correction made under s. 13.92 (4) (b) 7., Stats., Register December 2011 No. 672.

SPS 364.1500 Referenced standards. This is a department rule in addition to the requirements in IMC chapter 15: The following standards are incorporated by reference into chs. SPS 361 to 366:

(1m) FGI Guidelines for Design and Construction of Hospitals and Outpatient Facilities, 2014.

(2m) FGI Guidelines for Design and Construction of Residential Health, Care, and Support Facilities, 2014.

Note: FGI guidelines may be purchased at fgiguidelines.org or AHA Services Inc. P.O. Box 933283, Atlanta, GA, 31193-3283.

(3) NFPA 45-2015, Standard on Fire Protection for Laboratories Using Chemicals.

Note: NFPA standards may be viewed online free of charge at NFPA.org or purchased from the National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

Note: Copies of the standards adopted under this section are on file in the offices

of the department and the legislative reference bureau.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02; CR 01-139: am. Register June 2002 No. 558, eff. 7-1-02; correction in (1) made under s. 13.93 (2m) (b) 7., Stats., Register April 2003 No. 568; CR 04-016: r. and recr. (2) Register December 2004 No. 588, eff. 1-1-05; CR 06-120: r. (1), am. (2) (a), cr. (2) (c) Register February 2008 No. 626, eff. 3-1-08; CR 10-103: am. (2) (a) Register August 2011 No. 668, eff. 9-1-11; CR 16-094: renum. (2) (intro.), (a) to 364.1500 (intro.), (1m) and am., r. (2) (b), (c), cr. (2m), (3) Register April 2018 No. 748, eff. 5-1-18.

SPS 364.1600 Appendices. IMC Appendices A and B are not included as part of this chapter.

History: CR 00-179: cr. Register December 2001 No. 552, eff. 7-1-02.