IND 17

#### INDUSTRIAL COMMISSION

OF

## WISCONSIN

R. G. Knutson Chairman

Manufacture and an Article and Article and

8

A. W. Enright Commissioner

John H. Rouse Commissioner

Helen E. Gill, Secretary

Roger Ostrem Director, Division of Industrial Safety and Buildings

John E. Wise Electrical Engineer

د. المراجع المراجع المراجع معرف المراجع ا المراجع المراجع

and the second second second

DISCUSSION SCHOOL LIGHTING CODE

adopter Dec 28-1956

Issued by

Industrial Commission of Wisconsin Madison, Wisconsin

1957

#### AUTHORITY

The Wisconsin School Lighting Code has been adopted by the Industrial Commission in discharge of its duties under Section 101.01 to 101.28, inclusive, of the Statutes of Wisconsin.

#### HISTORY

The Wisconsin School Lighting Code first issued by the Industrial Commission became effective October 6, 1921. The code was revised in 1943 and became effective February 7, 1944.

In 1950, the supply of copies of the code was used up. Discussion of the code indicated that the advisory committee should be reorganized. In June, 1954, the interested organizations were contacted. Later, each organization was asked to nominate representatives to serve on a new advisory committee. The personnel of this advisory committee is as follows:

A. L. Buechner, Madison, Representing the Department of Public Instruction (Chairman).

Joseph G. Durrant, Boscobel, Representing the American Institute of Architects.

Dr. C. W. Aageson, Madison, Representing the State Medical Society of Wisconsin.

C. N. Laupp, Milwaukee, Representing the Illuminating Engineering Society.

H. G. Thayer, Madison, Representing the State Board of Vocational and Adult Education.

R. G. Hein, Waukesha, Representing the Wisconsin Association of School Administrators.

Miss Marie Kennedy, Shell Lake, Representing the Wisconsin Association of County Superintendents.

E. G. McKean, Tomah, Representing the Wisconsin Education Association.

John E. Wise, Madison, Electrical Engineer, Representing the Industrial Commission (Secretary).

ADMINISTRATION

The Wisconsin School Lighting Code has been enforced by the Industrial Commission and the Department of Public Instruction with the cooperation of municipal and other local officials who, by law, are required to enforce all orders which are germane to their respective duties (Wisconsin Statutes, Section 101.28)

## APPEAL

Any person who considers any part of the Wisconsin School Lighting Code or any official's interpretation of this code to be unreasonable may appeal to the Industrial Commission to interpret, modify or suspend same. (Wisconsin Statutes, Section 101.15 to 101.17, inc.)

#### CHAPTER 17

## WISCONSIN SCHOOL LIGHTING CODE

Ind 17.01 <u>APPLICATION AND SCOPE</u>. This code sets forth the minimum requirements for the daylighting and electric lighting of school buildings including public, perochial and private schools. Unless specifically stated to the contrary, all sections of this code apply to new construction, to reconstruction of and additions to existing buildings, and to changes in electric lighting installations. Existing electric lighting and daylighting installations shall be made to comply with the terms of this code as far as may be directed by the Industrial Commission or other state departments having jurisdiction and within the time determined by such departments.

Ind 17.02 DEFINITIONS.

(1) <u>BILATERAL SYSTEM</u>. The daylight illumination of school rooms from more than one side.

(2) <u>CANDLE - CANDLE POWER</u>. The unit of luminous intensity maintained by the United States Bureau of Standards. It is approximately equal to the intensity of light emitted in a horizontal direction by a standard candle. Thus a lamp is said to have a light intensity of 100 candle power in the direction of some given object, when it gives 100 times as much light to this object as would be given to it by a standard candle.

(3) <u>CLERESTORY</u>. That part of a building which rises clear of the roofs of the other parts and whose walls contain windows for daylighting the interior.

(4) <u>DISTRIBUTION CURVE</u>. A photometric analysis of the distribution of light from a luminaire. It indicates the candle power distribution in all directions as well as the lumen output in various zones. It also indicates the efficiency of the luminaire. Brightness measurements of the luminaire at various angles is usually included on all curves furnished by acceptable laboratories which are satisfactory to the Wisconsin Industrial Commission.

(5) FOOT-CANDLE. The unit of illumination when the foot is the unit of length. It is the illumination on a surface one square foot in area on which is uniformly distributed a flux of one lumen. It equals one lumen per square foot.

(6) FOOT LAMBERT. The unit of photometric brightness that is defined as being one lumen per square foot emitted or reflected from a surface. The measurement of brightness of a surface in foot lamberts is equal to the illumination of the surface in foot-candles multiplied by the reflection factor of the surface.

Note: (One candle per square inch equals 452 foot lamberts.)

(7) GLARE. High brightness ratios in the field of vision,

(8) <u>ILLUMINATION AT THE WORK</u>. The illumination of or at the important plane or planes of the actual visual task.

Note: (In average classrooms the work plane is normally 30" above the floor.) (9) LAMP. An electric light source exclusive of any other parts constituting a luminaire.

(10) <u>LIGHT METER</u>. An instrument used in measuring the illumination on a surface. Most accurate readings are obtained from a light meter having both cosine and color correction accessories.

(11) <u>LUMEN</u>. The unit of luminous flux which equals the flux emitted through a unit solid angle (one steridian) from a uniform point source of one candle. The term lumen is used to define the total light output of an electric light source.

(12) <u>LUMINATRE</u>. A complete lighting unit including lamp, globe, reflector, refractor, housing or louvers, and such support as is included with the busing.

(13) <u>LUMINOUS CEILING</u>. A lighting system having practically wall to wall luminous elements made up of louvers, plastic or glass diffusers above which light sources are installed.

-<u>2</u>-

(14) <u>REFLECTION FACTOR</u>. The ratio of total luminous flux reflected by a surface to the luminous flux incident upon it.

(15) <u>SHIELDING</u>. Refers to those portions of a luminaire which serve to screen out the light source and minimize glare from normal angles of vision.

(16) <u>SUPPLEMENTARY LIGHTING</u>. The lighting provided by a special type of luminaire usually located at or near eye level and intended to illuminate a limited area.

(17) TOP LIGHTING UNIT. A daylighting device mounted in the ceiling.

(18) <u>UNILATERAL SYSTEM</u>. The daylight illumination of school rooms from one side only.

Ind 17.03 ELECTRIC LIGHTING.

(1) <u>GENERAL REQUIREMENTS</u>. All rooms and spaces of school buildings shall be equipped with means for supplying electric illumination in the quantity required for the purpose to which each room or space is devoted.

Ind 17.04 <u>CHARACTER OF LIGHTING TO BE SUPPLIED</u>. (1) The principal source of electric illumination of all rooms and spaces of school buildings shall be from overhead lighting systems. When a combination of overhead and supplementary lighting is employed, the illumination at the work received from the overhead lighting, shall in no case be less than the intensities set forth in section Ind 17.05.

(2) Where supplementary lighting is used in combination with overhead lighting, particular care shall be exercised to eliminate glare at other points in the room. Adequate shielding and careful adjustment of the direction shall be provided to minimize both direct and reflected glare.

Ind 17.05 <u>ILLUMINATION AT THE WORK</u>. Electric illumination at the point of work in rooms and spaces of school buildings shall be supplied and maintained

-3-

in accordance with the minimum values shown in the following table:

| Room or space to be illuminated   | Minimum maintained illumination at the work, foot-candles |
|---|---|
| (1) Classrooms - all spaces used for study or<br>instructions excepting (3) & (4                                | 4). 30 f.c.   |
| (2) Study halls, lecture rooms, offices, laborat<br>and libraries.  | tories, 30 f.c.   |
| (3) Sight saving classrooms.  | 50 f.c.   |
| (4) Drafting, typing and sewing rooms.  | 50 f.c.   |
| (5) Gymnasiums and natatoriums. It is recommend<br>consideration be given to underwater lightin<br>natatoriums. | ded that<br>ng for<br>25 f.c.                             |
| (6) Auditoriums (not for study), cafeterias, loc<br>wash rooms, corridors, containing lockers ar                | cker rooms,<br>nd stairways. 10 f.c.                      |
| (7) Other corridors and store rooms.  | 5 f.c.  |
| (8) Shops - vocational training and industrial a  | arts  |
| (a) Bench and machine areas<br>(b) General areas  | 50 f.c.<br>30 f.c.  |
| Note: The values are minimum, not average.  |   |

Where it is desired to see objects in their daylight hues, as for example, art work, the use of electric light having an approximate daylight spectrum is suggested; increased illumination is usually desirable. In planning electric lighting, allowance of at least 30 per cent should be made for depreciation from dirt and other causes.

Ind 17.06 <u>SHIELDING OF LAMPS</u>. No exposed lamps or tubes having a brightness greater than 1200 foot lamberts shall be installed in rooms used for study or vocational training purposes.

All sources having brightness in excess of 1200 foot lamberts shall be provided with suitable shielding either as a component of the luminaire or as a structural element, so that occupants will be protected from direct glare. Where fluorescent lamps are used, the minimum shielding shall be  $25^{\circ}$  lengthwise and  $35^{\circ}$  crosswise of the source measured below the horizontal line. Surface brightness

- Lym

of the shielding elements, if of the diffusing type, shall not exceed 1200 foot lamberts.

Ind 17.07 <u>DISTRIBUTION OF LIGHT</u>. Luminaires or luminous ceilings shall be so installed in regard to mounting height, location, and spacing as to provide uniform distribution of illumination at the work.

Note: Section Ind 17.07 does not apply to toilet rooms, cloak rooms, store rooms, boiler rooms and other spaces devoted to similar purposes.

Ind 17.08 <u>DIFFUSION OF LIGHT</u>. Luminaires shall be so installed in regard to mounting height, location and spacing as to avoid sharply defined and deep shadows from overhanging structural parts or persons in normal working positions.

Note: Section Ind 17.08 does not apply to toilet rooms, cloak rooms, store rooms, boiler rooms and other spaces devoted to similar purposes.

Note: Deep shadows interfere with work in the shaded area and are a strain on the eyes. In general, some shadows may be present, in fact, they aid in observing objects in three dimensions, but they should be soft and luminous.

Ind 17.09 EMERGENCY LIGHTING.

(1) <u>EXIT. STAIR. AND CORRIDORS</u>. The lighting in all stairways and exits and in the passageways leading thereto shall be connected independently of the room lighting. Such lighting and exit lights shall comply with the terms of the Wisconsin State Building Code and the Wisconsin State Electrical Code and shall be so supplied as not to be subject to failure because of the failure of the room lighting from internal causes.

(2) <u>NATATORIUMS</u>. In all natatoriums the lighting shall be connected with the emergency lighting.

Ind 17.10 DAYLIGHT.

(1) <u>MHERE REQUIRED</u>. All rooms and spaces of school buildings used for instruction and study purposes shall be provided with at least a minimum vision

-5-

area or windows except gymnasiums, auditoriums, cafeterias, lunch rooms, music rooms, vocational shops, and similar areas.

(2) <u>VISION AREA OR WINDOWS</u>. The minimum vision area or windows shall be not less than  $3^{\circ}0^{\circ}$  in height with the window head at least  $5^{\circ}8^{\circ}$  and the sill not more than  $3^{\circ}0^{\circ}$  above the floor. The cumulative length of the vision area shall be not less than 2/3 the length of the outside wall containing the vision area, windows, or the equivalent.

(3) <u>GLASS BLOCK CONSTRUCTION</u>. (a) Glass block construction for all spaces to which this code applies, may be used under the restrictions of the Wisconsin State Building Code and those imposed by this code in so far as they apply.

(b) Glass block wall panels exposed to direct sun rays and above the 5 foot level shall be of a type capable of directing the light rays horizontally or upward.

(4) <u>BRIGHTNESS CONTROL</u>. In class or study rooms, all windows, skylights, clerestories, top lights and other openings containing clear glass or equivalent translucent material which is exposed to the direct or reflected (as from snow) rays of the sun shall be provided with an effective means of brightness control. In-shop-areas-used-strictly-for shop-purposes the industrial type fluorescent incendescent-unit may be used where severe maintenance problems would result with-the-use-of-shielded equipment. Opaque shades shall be used only where it is necessary to darken the room for visual instruction.

Ind 17.11 <u>WINDOWS IN FRONT WALL PROHIBITED.</u> Windows shall not be located in the front wall of classrooms, recitation rooms and study halls.

Note: By front wall is meant the wall pupils face directly when in their seats.

Ind 17.12 LOCATION OF CHALKBOARDS AND BULLETIN BOARDS. Chalkboards and bulletin boards shall not be located in the same wall with windows. Chalkboards

entre

shall not be located within 6 feet of any window.

Ind 17.13 FINISH OF WALLS AND CEILINGS.

(1) <u>CEILINGS</u>. Geilings of all instruction and study spaces shall be finished with a matte (dull) or semi-matte surface having an initial coefficient of reflection (see definition 14) of at least 0.75.

(2) <u>WALLS OF ROOMS</u>. Walls of all instruction and study spaces, from ceiling down to top of chalkboard, or to a height of 2'8" above the floor, where chalkboards are not used, shall be finished with a matte (dull) or semi-matte surface having an initial reflection factor of not less than 0.45 nor more than 0.60; below this level a darker finish may be used.

(3) TRIM. Trim of all instruction and study spaces shall be finished in a matte or semi-matte surface.

Note: Finishes, such as spar varnish, may be rubbed to a dull surface.

(4) <u>WALLS OF LIGHT COURTS</u>. Walls of light courts shall be finished with a surface having a high initial coefficient of reflection (0.60 to 0.70), but care must be taken to avoid glare.

(5) <u>REFLECTION FACTOR</u>. The following table presents figures which are the result of a considerable number of tests of different authorities, and are representative average values of the coefficient of reflection for various colors. Since it is not possible to accurately describe colors verbally, a range in values is given for each color.

-7÷

Color

## Coefficient of Reflection

| White, new               | 0.75 to 0.85 |
|--------------------------|--------------|
| White, old               | 0.70 to 0.77 |
| Cream                    | 0.66 to 0.76 |
| Buff                     | 0.44 to 0.59 |
| Ivory                    | 0.66 to 0.76 |
| Gray                     | 0.15 to 0.67 |
| Light Green              | 0.43 to 0.67 |
| Dark Green               | 0.10 to 0.22 |
| Light Blue               | 0.31 to 0.57 |
| Pink                     | 0.32 to 0.57 |
| Dark Red                 | 0.12 to 0.27 |
| Yellow                   | 0.55 to 0.70 |
| Dark Tan                 | 0.27 to 0.41 |
| Natural wood brown stain | 0.15 to 0.26 |
| Light wood varnish       | 0.36 to 0.44 |
|                          |              |

## A DISCUSSION OF SCHOOL LIGHTING GOALS

Research results indicate that optimum brightness-difference conditions for visual efficiency exist when the task and surrounding areas are of a uniform brightness. This condition is not feasible in a schoolroom because of the physical limitations which cannot be overcome. An environment having absolute conditions of brightness-balance, therefore, is not possible in a schoolroom; hence unity of brightness cannot be considered as a practical goal. It is desirable, however, to reduce brightness-differences to a reasonable minimum by eliminating the sources of excessively high brightness and by increasing the brightness of the dark areas within the total visual environment.

Where critical seeing tasks are being performed, desirable brightness-difference goals for the total visual environment are as follows:

- Goal A A foot-lambert brightness of any surface viewed from any normal standing or sitting position in the schoolroom should not exceed 10 times the foot-lambert brightness of the poorest lighted task in the room.
- Goal B The foot-lambert brightness of any surface viewed from any normal standing or sitting position in the schoolroom should not be less than onethird the foot-lambert brightness of the poorest lighted task in the room.
- Goal C The foot-lambert brightness of any surface immediately adjacent to the task should not exceed 3 times the task brightness.
- Goal D Brightness-difference between adjacent surfaces should be reduced to a minimum.
- Goal E The brightness goals stated above assume a lighting system that provides from 20 to 40 foot-candles on the poorest lighted task. As footcandle levels are increased sources of high brightness should be controlled to approach more nearly the brightness of the task. The extent of the area of the surface producing brightness has a measurable effect upon visual comfort. Generally, small areas of either extremes of brightness are less noticeable than are large areas of the same brightness.
- Goal F Light distribution from any light source should be of such a nature that direct and specular glare are eliminated for the observer to the greatest possible degree.
- Goal G These objectives or goals should be achieved without the loss of a cheerful, friendly and esthetically pleasing classroom environment and with the need in mind for a balanced and acceptable thermal and auditory environment.

The term task, as used in the foregoing definitions of goals, is interpreted to include any visual task which may be encountered in a schoolroom. For example, as "task" might be a book on the student's desk, the written symbols on the chalkboard, demonstration or experimental apparatus in a laboratory, an art assignment on an easel or exhibit materials on a tackboard, a motion picture or a lantern slide. On the basis of this concept, it is apparent that the tasks may be in either a horizontal or a vertical plane and may require the pupil to face any direction. Visual tasks in schoolrooms range in brightness-difference from reading black symbols on white paper to sewing with black thread on black cloth. Other factors remaining constant, visual comfort and efficiency increase with the increase in brightness-difference within the task.

-9-

= = = = = =

The committee held two meetings, July 10 and August 21, 1956.

Two public hearings were held to give interested parties an opportunity to be heard. They were held in the following cities:

-2-

Milwaukee - July 30, 1956 Madison - July 31, 1956

#### Jurisdiction of the Industrial Commission

Liquefied petroleum gases must be used and stored in a manner which complies with the laws of the state enacted for the safety of employees and frequenters in places of employment and public buildings and with orders of the industrial commission, adopted and published in conformity with Sections 101.01 to 101.28, inclusive, of the statutes.

#### Administration

The General Orders on Liquefied Petroleum Gases are enforced by the industrial commission of Wisconsin in cooperation with municipal and other local officials, who are required by law to enforce all orders of the commission which are germane to their respective duties (Wisconsin Statutes 101.28) and in cooperation with inspectors and insurance agencies.

## Petition

Section 101.15 Wisconsin Statutes. Petition and Hearing on Reasonableness of Orders. (1) Any employer or other person interested either because of ownership in or occupation of any property affected by any such order, or otherwise, may petition for a hearing on the reasonableness of any order of the commission in the manner provided in Sections 101.01 to 101.29, inclusive.

#### Penalties

Section 101.105 (5) Wisconsin Statutes provides that: "Any person, firm, association or corporation violating any of the provisions of this section, or any standard, rule or regulation adopted by the industrial commission pursuant to the provisions of this section, or issuing a false statement under subsection (4), shall be deemed guilty of a misdemeanor, and upon conviction thereof, shall be punished by a fine of not less than \$25 nor more than \$100, or by imprisonment in the county jail not less than 30 days nor more than 6 months."

# CHAPTER 17

Augest A

PROPOSED REVISION of the WISCONSIN SCHOOL LIGHTING CODE

Ind 17.01 <u>APPLICATION AND SCOPE</u>. This code sets forth the minimum requirements for the day lighting and electric lighting of school buildings including public, parochial and private schools. Unless specifically stated to the contrary, all sections of this code apply to new construction, to reconstruction of and additions to existing buildings, and to changes in electric lighting installations. E electric lighting Substandard existing/installations including daylighting as well as electric comply lighting, shall be brought to conformity with the terms of this code as far as may be directed by the Industrial Commission or other state departments having jurisdiction and within the time determined by such departments. Hill 17.02 <u>DEFINITIONS</u>.

more than one source. approximately uniformly spaced windows with exterior side walls to the left and

#### rear of pupils only.

(2) <u>CANDLE</u>. The unit of luminous intensity maintained by the United States Bureau of Standards. It is approximately equal to the intensity of light emitted in a horizontal direction by a standard candle. Thus a lamp is said to have a light intensity of 100 candle power in the direction of some given object, when it gives 100 times as much light to this object as would be given to it by a standard candle.

(3) <u>CLERESTORY</u>. That part of a building which rises clear of the roofs of the other parts and whose walls contain windows for daylighting the interior.

(4) <u>DISTRIBUTION CURVE</u>. A photometric analysis of the distribution of light from a luminaire. It indicates the candle power distribution in all directions as well as the lumen output in various zones which indicates the efficiency of the luminaire. Brightness measurements of the luminaire at various angles is usually included on all curves furnished by acceptable laboratories which are satisfactory to the Wisconsin Industrial Commission.

Note: A careful analysis of the photometric data enables the engineer or architect to determine the suitability of a particular fixture for a given work area.

(5) <u>FOOT-CANDLE</u>. The unit of illumination when the foot is the unit of length. It is the illumination on a surface one square foot in area on which is uniformly distributed a flux of one lumen. It equals one lumen per square foot.

Note: The candle power refers to strength or intensity of light emitted from the light source, whereas the foot-candle refers to the density of illumination which reaches the object illuminated.

(6) <u>FOOT LAMBERT</u>. The unit of photometric brightness that is defined as being one lumen per square foot emitted or reflected from a surface. The measurement of brightness of a surface in foot lamberts is equal to the illumination of the surface in foot-candles multiplied by the reflection factor of the surface.

Note: One candle per square inch equals 452 foot lamberts.

(7) <u>GIARE</u>. High brightness ratios in the field of vision.

(8) <u>ILLUMINATION AT THE WORK</u>. The illumination of or at the important plane or planes of the actual visual task.

Note: In average classrooms the work plane is normally 30" above the floor. (9) <u>LAMP</u>. An electric light source exclusive of any other parts constituting a luminaire.

(10) <u>LIGHT METER.</u> An instrument used in measuring the intensity of light impinging on a surface. Most accurate readings are obtained from a light meter having both cosine and color correction accessories.

(11) <u>LUMEN</u>. The unit of luminous flux which equals the flux emitted through a

unit solid angle (one steridian) from a uniform point source of one candle. The term lumen is used to define the total light output of an electric light source.

-3-

(12) <u>LUMINAIRE</u>. A complete lighting unit including lamp, globe, reflector, refractor, housing or louvers, and such support as is included with the housing.

(13) <u>LUMINOUS CEILING</u>. A lighting system having practically wall to wall luminous elements made up of louvers, plastic or glass diffusers above which light sources are installed.

(14) <u>REFLECTION FACTOR</u>. The ratio of total luminous flux reflected by a surface to the luminous flux incident upon it.

(15) <u>SHIELDING</u>. Refers to those portions of a luminaire which serve to and minimize glare screen out the light source from normal angles of vision.

(16) <u>SUPPLEMENTARY LIGHTING</u>. The lighting provided by a special type of luminaire usually located at or near eye level and intended to illuminate a limited area.

(17) <u>TOP LIGHTING UNIT</u>. A daylighting device mounted in the ceiling.
(18) <u>UNILATERAL SYSTEM</u>. The daylight illumination of school rooms from one source only.

Ind 17.03 <u>ELECTRIC LIGHTING.</u> (1) GENERAL REQUIREMENTS. All rooms and spaces of school buildings shall be equipped with means for supplying electric illumination in the quantity required for the purpose to which each room or space is devoted. Ind 17.04 <u>CHARACTER OF LIGHTING TO BE SUPPLIED</u>. (1) The principal source of electric illumination of all rooms and spaces of school buildings shall be from overhead lighting systems. When a combination of overhead and supplementary lighting is employed, (see definitions 8 and 16) the illumination at the work received from the overhead lighting, shall in no case be less than the amounts 05. set forth in section Ind 17.12.

(2) Where supplementary lighting is used in combination with overhead lighting, particular care shall be exercised to eliminate glare at other points in the room. Adequate shielding and careful adjustment of the direction shall be minimize provided to eliminate both direct and reflected glare.

Ind 17.05 <u>ILLUMINATION AT THE WORK</u>. Electric illumination at the point of work in rooms and spaces of school buildings shall be supplied and <u>maintained</u> with intensities in accordance with the minimum values shown in the following table:

| Room | or space to be illuminated   | Minimum <u>maintaine</u><br>of illumination a<br>foot-candles | d intensity<br>t the work, |
|------|--|---|----------------------------|
| (1)  | Classrooms All spaces used for study or<br>instructions excepting (3) & (4)                    | ).  | 30 f.c.                    |
| (2)  | Study halls, lecture rooms, offices, laborate  | ories,  | 30 f.c.                    |
| (3)  | Sight saving classrooms.   |   | 50 f.c.                    |
| (4)  | Drafting, typing and sewing rooms.   |   | 50 f.c.<br>25              |
| (5)  | Reception areas, gymnasiums, and natatoriums.<br>It is recommended that consideration be given | n to underwater   | 20 f.c.                    |
|      | lighting for natatoriums.  |   |                            |
| (6)  | Auditoriums (not for study), cafeterias, log   | ker rooms,  |                            |
|      | wash rooms, corridors, containing lockers an   | d stairways.  | 10 f.c.                    |
| (7)  | Other corridors and store rooms.   |   | 5 f.c.                     |
| (8)  | Shops & Vocational training and industrial a   | rts 🗋   |                            |
|      | (a) Bench and machine areas.<br>(b) General areas  |   | 50 f.c.<br>30 f.c.         |

-4-

Note: The values are minimum (not average) permissible intensities. Where it is desired to see objects in their daylight hues, as for example, art work, the use of electric light having an approximate daylight spectrum is suggested; increased intensity of illumination is usually desirable.

In planning electric lighting, allowance of at least 30 per cent should be made for depreciation from dirt and other causes.

Ind 17.06 SHIELDING OF LAMPS. No exposed lamps shall be installed in any areas identified in section Ind 17.05 (1) (2) (3) (4).

Ind 17.07 DISTRIBUTION OF LIGHT. Luminaires or luminous ceilings

shall be so installed in regard to mounting height .

location, and spacing as to provide uniform distribution of illumination at

the work.

Note: Section Ind 17.07 does not apply to toilet rooms, cloak rooms, store rooms, boiler rooms and other spaces devoted to similar purposes.

Ind 17.08 <u>DIFFUSION OF LIGHT</u>, Luminaires

structed shall be so installed in regard to mounting height, location and

spacing as to avoid sharply defined and deep shadows from overhanging structural

parts or persons in normal working positions.

Note: ( Exception: Section Ind 17.08 does not apply to toilet rooms, cloak rooms, store rooms, boiler rooms and other spaces devoted to similar purposes.

Deep shadows interfere with work in the shaded area and are a strain on the eyes. In general, some shadows may be present, in fact, they aid in observing objects in three dimensions, but they should be soft and luminous.

Ind 17.09 EMERGENCY LIGHTING.

(1) EXIT, STAIR, AND CORRIDORS. In school buildings hereafter constructed, the lighting to be provided in all stairways and exits and in the passageways leading thereto shall be connected independently of the room lighting. Such lighting and exit lights shall comply with the terms of the Wisconsin State

## State Electrical

-6-

Building Code and the Wisconsin/Electric Code and shall be so supplied as not to be subject to failure because of the failure of the room lighting from internal causes.

(2) <u>NATATORIUMS</u>. In all natatoriums hereafter constructed the lighting shall be connected with the emergency lighting.

Ind 17.10 NATURAL LIGHTING.

(1) <u>WHERE REQUIRED</u>. All rooms and spaces of school buildings used for instruction and study purposes shall be provided with at least a minimum vision area <u>strip</u> or windows except gymnasiums, auditoriums, cafeterias, lunch rooms, music vocational shops, rooms, and similar areas.

(2) <u>VISION STRIP OR WINDOWS</u>. The minimum vision strip or windows shall be not less than 3'0" in height with the window head at least 5'8" <del>above the</del> 3'0" <del>floor,</del> and the sill not more than <del>3'</del>, <del>but not less than 2'8"</del> above the floor. cumulative vision The length of the strip shall be not less than 2/3 the length of the outside wall containing the vision strip, or windows, or the equivalent.

(a)

(3) <u>GLASS BLOCK CONSTRUCTION</u>. (3) Glass block construction for all spaces to which this code applies, may be used under the restrictions of the State Wisconsin Building Code and those imposed by this code in so far as they apply to windows.

(2) Glass block used in panels exposed to direct sun rays and above five foot level shall be of a type capable of directing the light rays horizontally or upward.

(4) <u>BRIGHTNESS LIMIT</u>. Under operating conditions the foot lambert brightness of any surface viewed from any normal standing or sitting position shall not exceed 20 times the foot lambert brightness of the poorest lighted task in the room.

(#) <u>BRIGHTNESS CONTROL</u>. In class or study rooms, all windows, skylights, clerestories, top lights and other openings containing glass or equivalent translucent transparent material which is exposed to the direct or performed (as a rays of the sun shall be provided with an effective means of brightness control, such as, roller type shades, blinds, drapes, louvers, outriggers or similar means. Opaque shades shall be used only where it is necessary to darken the room for visual instruction.

Ind 17.12 WINDOWS IN FRONT WALL PROHIBITED. Windows shall not be located in the front wall of classrooms, recitation rooms and study halls.

Note: By front wall is meant the wall pupils face directly when in their seats.

Ind 17.1 LOCATION OF CHALKBOARDS AND BULLETIN BOARDS. Chalkboards and bulletin boards shall not be located in the same wall with windows. Chalkboards shall not be located within six feet of any window.

Ind 17.14 FINISH OF WALLS AND CEILINGS.

(1) <u>CEILINGS</u>. Ceilings of all instruction and study spaces shall be finished with a matte (dull) or semi-matte surface having an initial coefficient of reflection (See definition 14) of at least 0.75.

A Exception: Toilet rooms, gymnasiums, laboratories and other areas used mainly for experimenting in light, radiation and illumination are exempted from this requirement.

(2) <u>WALLS OF ROOMS</u>. Walls of all instruction and study spaces, from ceiling down to top of chalkboard, or to a height of 2'8" above the floor, where chalkboards are not used, shall be finished with a matte (dull) or semi-matte surface having an initial reflection factor of not less than 0.45 nor more than 0.60; below this level a darker finish may be used.

6

(3) TRIM. Trim of all instruction and study spaces shall be finished in a matte or semi-matte surface.

Note: Finishes, such as spar varnish, may be rubbed to a dull surface.

(4) <u>WALLS OF LIGHT COURTS</u>. Walls of light courts shall be finished with a surface having a high initial coefficient of reflection (0.60 to 0.70), but care must be taken to avoid glare.

) Exception: Toilet rooms, and laboratories for experimenting in light, radiation and illumination are exempted from these requirements.

Note: The following table presents figures which are the result of a considerable number of tests by different authorities, and are representative average values of the coefficient of reflection for various colors. Since it is not possible to accurately describe colors verbally, a range in values is given for each color.

### Color

#### Coefficient of Reflection

| White, new               | 0.75 | to | 0.85 |
|--------------------------|------|----|------|
| White, old               | 0.70 | to | 0.77 |
| Cream                    | 0.66 | to | 0.76 |
| Buff                     | 0.44 | to | 0.59 |
| Ivory                    | 0.66 | to | 0.76 |
| Gray                     | 0.15 | to | 0.67 |
| Light Green              | 0.43 | to | 0.67 |
| Dark Green               | 0.10 | to | 0.22 |
| Light Blue               | 0.31 | to | 0.57 |
| Pink                     | 0.32 | to | 0.57 |
| Dark Red                 | 0.12 | to | 0.27 |
| Yellow                   | 0.55 | to | 0.70 |
| Dark Tan                 | 0.27 | to | 0.41 |
| Natural wood brown stain | 0.15 | to | 0.26 |
| Light wood varnish       | 0.36 | to | 0.44 |
|                          |      |    | • •  |

#### \_ \_ \_ \_ \_ \_ \_ \_ \_

Mate:

#### A DISCUSSION OF SCHOOL LIGHTING GOALS

Research results indicate that optimum brightness-difference conditions for visual efficiency exist when the task and surrounding areas are of a uniform brightness. This condition is not feasible in a schoolroom because of the physical limitations which cannot be overcome. An environment having absolute conditions of brightness-balance, therefore, is not possible in a schoolroom; hence unity of brightness cannot be considered as a practical goal. It is desirable, however, to reduce brightness-differences to a reasonable minimum by eliminating the sources of excessively high brightness and by increasing the brightness of the dark areas with-

in the total visual environment.

Where critical seeing tasks are being performed, desirable brightness-difference goals for the total visual environment are as follows:

- Goal A A foot-lambert brightness of any surface viewed from any normal standing or sitting position in the schoolroom should not exceed 10 times the foot-lambert brightness of the poorest lighted task in the room.
- Goal B The foot-lambert brightness of any surface viewed from any normal standing or sitting position in the schoolroom should not be less than onethird the foot-lambert brightness of the poorest lighted task in the room.
- Goal C The foot-lambert brightness of any surface immediately adjacent to the task should not exceed 3 times the task brightness.
- Goal D Brightness-difference between adjacent surfaces should be reduced to a minimum.
- Goal E The brightness goals stated above assume a lighting system that provides from 20 to 40 foot-candles on the poorest lighted task. As footcandle levels are increased sources of high brightness should be controlled to approach more nearly the brightness of the task. The extent of the area of the surface producing brightness has a measurable effect upon visual comfort. Generally, small areas of either extremes of brightness are less noticeable than are large areas of the same brightness.
- Goal F Light distribution from any light source should be of such a nature that direct and specular glare are eliminated for the observer to the greatest possible degree.
- Goal G These objectives or goals should be achieved without the loss of a cheerful, friendly and esthetically pleasing classroom environment and with the need in mind for a balanced and acceptable thermal and abditory environment.

The term" task", as used in the foregoing definitions of goals, is interpreted to include any visual task which may be encountered in a schoolroom. For example, as "task" might be a book on the student's desk, the written symbols on the chalkboard, demonstration or experimental apparatus in a laboratory, an art assignment on an easel or exhibit materials on a tackboard, a motion picture or a lantern slide. On the basis of this concept, it is apparent that the tasks may be in either a horizontal or a vertical plane and may require the pupil to face any direction. Visual tasks in schoolrooms range in brightness-difference from reading black symbols on white paper to sewing with black thread on black cloth. Other factors remaining constant, visual comfort and efficiency increase with the increase in brightness-difference within the task.

--9--

=====