

Filed Dec 20, 1960
" Cull

Ind 17

STATE OF WISCONSIN)
DEPT. OF INDUSTRIAL COMMISSION) SS.

TO ALL TO WHOM THESE PRESENTS SHALL COME, GREETINGS:

I, Helen E. Gill, Secretary of the Industrial Commission, and custodian of the official records of said commission, do hereby certify that the attached amendments regarding Wisconsin Administrative Code Chapter 17, School Lighting, were duly amended and adopted by this commission on December 16, 1960.

I further certify that said copy has been compared by me with the original on file in this commission and that the same is a true copy thereof, and of the whole of such original.

IN TESTIMONY WHEREOF, I have here-
unto set my hand and affixed the
official seal of the department
at the Capitol, in the city of
Madison, this 19th day of
December, A. D., 1960.


Secretary

Pursuant to authority vested in the Industrial Commission by Sections 101.01 - 101.29 Wisconsin Statutes, the Industrial Commission on December 16, 1960 voted to amend Sections (1) and (2) of Order Ind 17.10 Daylight, School Lighting Code.

The order as amended reads as follows:

Ind 17.10 Daylight. (1) Where Required. All classrooms and spaces in school buildings used for instruction and study purposes shall be provided with side wall clear glass vision panels or windows except gymnasiums, auditoriums, cafeterias, lunch rooms, libraries, science rooms, audio-visual rooms, homemaking rooms, art rooms, music rooms, vocational shops and similar areas.

(2) Vision Area or Windows. The vision area or windows in each classroom shall have a total area of not less than 40 square feet. The sill height shall not exceed 3'6" above the floor and the horizontal width of the vision area shall not be less than 5 feet. A minimum of 10 square feet of the glass area, with the least dimension not less than 2 feet shall be arranged to open.


(3) Glass Block Construction. (a) Glass block construction for all spaces to which this code applies, may be used under the restrictions of the Wisconsin state building code and those imposed by this code in so far as they apply.

(b) Glass block wall panels exposed to direct sun rays and above the 5 foot level shall be of a type capable of directing the light rays horizontally or upward.

(4) Brightness Control. In class or study rooms, all windows, skylights, clerestories, top lights and other openings containing clear glass or equivalent translucent material which is exposed to the direct or reflected (as from snow) rays of the sun shall be provided with an effective means of brightness control. Opaque shades shall be used only where it is necessary to darken the room for visual instruction.

The amendments shall take effect on February 1, 1961 as provided by Section 227.

INDUSTRIAL COMMISSION OF WISCONSIN

A handwritten signature in cursive script, appearing to read "Helen E. Gill", written over a horizontal line.

Secretary

December 19, 1960