

Chapter E 510

HAZARDOUS LOCATIONS; SPECIFIC

E 510.01 Scope

E 510.02 General

E 510.01 Scope. The provisions of chapters E 511 to E 517 inclusive shall apply to occupancies or parts of occupancies which are or may be hazardous because of atmospheric concentrations of hazardous gases or vapors, or because of deposits or accumulations of materials which may be readily ignitable. It is the intent to assist the administrative authority in the classification of areas with respect to hazardous conditions which may or may not require construction and equipment conforming to chapters E 501 to E 503 inclusive, and to set forth such additional special requirements as are applicable to the specific occupancy.

History: Cr. Register, April, 1964, No. 100, eff. 5-1-64.

E 510.02 General. The general rules of this code shall apply to the installation of electrical wiring and equipment in occupancies within the scope of chapters E 511 to E 517 inclusive, except as such rules are modified in those chapters. Where unusual conditions exist in a specific occupancy, the administrative authority shall judge with respect to the application of specific rules.

Note: It is recommended that the administrative authority be familiar with National Fire Protection Association standards applying to occupancies included within the scope of chapters E 511 to E 517 inclusive.

History: Cr. Register, April, 1964, No. 100, eff. 5-1-64.