



State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

NR III, RD II

Filed March 15, 1971

8:45 am

L. P. Voigt
Secretary

BOX 450
MADISON, WISCONSIN 53701

STATE OF WISCONSIN)
)
DEPARTMENT OF NATURAL RESOURCES) ss.


Greetings:

I, L. P. Voigt, Secretary of the Department of Natural Resources, hereby certify that the renumbering and amending of the rules and regulations of the Department of Resource Development (RD) in the Wisconsin Administrative Code to Natural Resources (NR) designation are renumberings and amendments designed solely to bring the language of the existing rules into conformity with subsequent statutory changes which created the Department of Natural Resources (Chapter 75, Laws of 1969 and Wis. Stat. 15.34) and reorganized the state structure (Chapter 276, Laws of 1969).

I further certify that said copy has been compared by me with the original on file in this department and that the same is a true copy thereof, and of the whole of such original.

DEPARTMENT SEAL

In testimony whereof, I have hereunto set my hand and affixed the official seal of the Department at the Pyare Square Building in the City of Madison, this 12th day of March, A.D., 1971.



L. P. Voigt
Secretary

ORDER OF THE DEPARTMENT OF NATURAL RESOURCES
ADOPTING, AMENDING OR REPEALING RULES

Pursuant to authority vested in the Department of Natural Resources by 227.02 (2) (b), Wis. Stats., the Department of Natural Resources hereby repeals, amends and adopts rules as follows:

SECTION 1. Chapter RD 11 is renumbered to Chapter NR 111.

SECTION 2. RD 11.01 is renumbered to NR 111.01.

SECTION 3. NR 111.01 (6) (a), (b) and (c) are amended to read:

(a) An existing intake or by-pass may be maintained providing a section of the pipe is removed to be re-inserted only in case of emergency and immediately issuing notice to consumers to boil all water used and notifying the ~~board~~ department by wire.

(b) In new supplies, auxiliary intakes or by-passes may be permitted by special approval of the ~~board~~ department if satisfactory reasons are set forth as to the necessity therefor, and installation made in accordance with (a) above.

(c) An existing cross connection for fire protection purposes only which was originally installed before January, 1924 may be continued if protected by approved types of double check and gate valves equipped with suitable gauges and drains for testing, as shown in Fig. 1, and on condition that monthly inspections of such equipment are made and reported upon by the owner of the public supply on or before the tenth day of each month. The ~~board~~ department reserves the right to require elimination of any cross connection if inspections are not regularly made and reported upon, or if the connection is found faulty. All cross connections other than those used only for fire protection purposes shall be eliminated. New cross connections are prohibited. Permission to maintain any existing cross connection for fire protection purposes must ~~be~~ have been obtained from the ~~board~~ state on or before January 1, 1930.


SECTION 4. RD 11.02 is renumbered to NR 111.02.

The rules, amendments and repeals contained herein shall take effect on publication.

Dated at Madison, Wisconsin, this 12th day of March, 1971

DEPARTMENT OF NATURAL RESOURCES
By

(DEPARTMENT SEAL)



L. P. Voigt
Secretary