

Chapter Ind 55

THEATERS AND ASSEMBLY HALLS

Ind 55.001	Theaters	Ind 55.35	Automatic sprinklers
Ind 55.01	Assembly halls	Ind 55.39	Use of "safety-base" film
Ind 55.02	Class of construction	Ind 55.40	Motion picture machine booths, general
Ind 55.03	Height above grade	Ind 55.41	Construction of booth
Ind 55.04	Exposure and courts	Ind 55.42	Doors
Ind 55.05	Separation from other occupancies	Ind 55.43	Openings
Ind 55.06	Capacity	Ind 55.44	Ventilation of booths
Ind 55.07	Number and location of exits	Ind 55.45	Relief outlets
Ind 55.08	Type of exits	Ind 55.46	Electric wiring
Ind 55.09	Stairways	Ind 55.47	Motion picture machine
Ind 55.10	Exit doorways and doors	Ind 55.48	Fire protection in booth; care and use of film
Ind 55.11	Exit lights	Ind 55.49	Portable booths
Ind 55.12	Required exit width	Ind 55.50	Maintenance
Ind 55.13	Seating	Ind 55.51	Grandstands
Ind 55.14	Width of aisles	Ind 55.52	Exits
Ind 55.15	Lobbies and foyers	Ind 55.53	Aisles and passageways
Ind 55.16	Inclines and aisle steps	Ind 55.54	Seating
Ind 55.17	Obstruction	Ind 55.55	Guard rails
Ind 55.18	Mirrors and false openings	Ind 55.56	Portable grandstands or bleachers
Ind 55.19	Decorations	Ind 55.57	Inspection
Ind 55.20	Elevator and vent shafts	Ind 55.58	Tents
Ind 55.21	Stage separation	Ind 55.59	Structural requirements
Ind 55.22	Proscenium wall	Ind 55.60	Flame resistance
Ind 55.23	Proscenium curtain	Ind 55.61	Fire hazards
Ind 55.24	Automatic smoke outlet	Ind 55.62	Exits
Ind 55.25	Stage vestibules	Ind 55.63	Electrical installations
Ind 55.26	Footlight trough	Ind 55.64	Fire extinguishing equipment
Ind 55.27	Fireproof paint	Ind 55.65	Illumination: exit lights and signs
Ind 55.28	Stage accessory rooms	Ind 55.66	Boiler and furnace room
Ind 55.29	Boiler and furnace rooms	Ind 55.67	Toilet facilities
Ind 55.30	Lights and lighting	Ind 55.68	Outdoor theaters
Ind 55.32	Sanitary facilities		
Ind 55.33	Standpipes		
Ind 55.34	Fire extinguishers		

Ind 55.001 Theaters. In the theater classification, are included all buildings or parts of buildings, containing an assembly hall, having a stage which may be equipped with curtains or permanent or movable scenery, or which is otherwise adaptable to the showing of plays, operas, motion pictures or similar forms of entertainment.

Ind 55.01 Assembly halls. (1) In the assembly hall classification are included all buildings, or parts of buildings, other than theaters, which will accommodate more than 100 persons for entertainment, recreation, worship or dining purposes.

Note: For assembly areas in connection with schools and other places of instruction, refer to Wis. Adm. Code chapter Ind 56.

(a) Every assembly hall which will accommodate not more than 100 persons shall conform to the requirements of Wis. Adm. Code chapter Ind 54, covering factories, office and mercantile buildings.

History: 1-2-56; am. (1) (intro. par.), Register, March, 1972, No. 195, eff. 4-1-72.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

Ind 55.02 Class of construction. (1) The capacities of buildings or parts of buildings in this classification for the various types of construction shall not exceed, and shall comply with, the following requirements:

MAXIMUM CAPACITIES

<i>Type of Construction</i>	<i>With Stage</i>	<i>Without Stage</i>
Type No. 1 and No. 2.....	No limit	No limit
Type No. 3 and No. 4.....	750	1,500
Type No. 5 and No. 6.....	500	1,000
Type No. 7 and No. 8.....	300	750

(a) Exception. For unlimited capacity, the fire protection of structural steel supporting the roof may be omitted for one-story buildings meeting type No. 1, 2 and 3 construction provided the building has no ground or basement floors. Heavy timber columns and roof framing may be substituted for structural steel framing. The roof decking shall be of noncombustible construction meeting the fire-resistive ratings of Table 51.03-A.

(2) Type No. 7 and No. 8 construction. (See Ind 51.03.) Where buildings of these classifications are erected of Type No. 7 or No. 8 construction, the following restrictions shall apply:

(a) Not more than one story in height without a balcony, and with no ground floor or basement except a heating and fuel room enclosed with fire-resistive construction as specified in section Ind 55.29, with all interior openings protected with self-closing fire-resistive doors as specified in section Ind 51.047.

(b) Located at least 20 feet from any other building or adjoining property line.

(c) Is not built in connection with a building used for any other purpose.

(d) Is provided with foundation walls and piers of masonry construction.

(e) Where motion picture booths are required, they shall be enclosed with 2-hour fire-resistive construction.

Exception: In places of worship, a full basement and a balcony seating not more than 30 persons may be provided.

(3) Balconies accommodating more than 100. In any theater or assembly hall, balconies which accommodate more than 100 persons shall be of Type No. 1 or No. 2 construction as specified in section Ind 51.03.

History: 1-2-56; (1); (1) (a); (2); (2) (a); (2) (b); (2) (c); (2) (d); (2) (e); (2) (f); (3); am. Register, June, 1956; No. 6, eff. 7-1-56; am. (1) (a), Register, August, 1957, No. 20, eff. 9-1-57; am. Register, January, 1961, No. 61, eff. 2-1-61; am. (2) (a), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (2) (a) eff. 8-1-71 and exp. 1-1-72; cr. (2) (a) eff. 1-1-72, Register, July, 1971, No. 187; r. and recr. (1), am. (2) intro. par., and (3), Register, June, 1972, No. 198, eff. 1-1-73; cr. (1) (a), Register, September, 1973, No. 213, eff. 10-1-73; am. (2) (a), Register, May, 1974, No. 221, eff. 6-1-74; am. (1) (a), Register, July, 1974, No. 223, eff. 8-1-74.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

DEPT. OF INDUSTRY, LABOR & HUMAN RELATIONS 155
Theaters, assembly halls

Ind 55.03 Height above grade. (1) THEATERS. The height of the sills of the principal entrance doors to any theater, as defined in section Ind 55.001, shall be not more than 18 inches above the outside grade at that point. The floor level at the highest row of seats on the main floor shall not be more than 6 feet above the outside grade at the main entrance; the floor level at the lowest row of seats on the main floor shall be not more than 6 feet below, or above, the grade at the nearest exit.

(2) ASSEMBLY HALLS AND ROOF GARDENS ABOVE FIRST STORY. Where assembly halls are provided above the first story, the following limitation of occupancy, type of construction and exit facilities shall apply:

Type of Construction	Maximum No. of Occupants	Height Above Grade
Type No. 1 and No. 2	No limit	See Ind 51.03†
Type No. 3 thru No. 6	400	2nd story
Type No. 3 thru No. 6	200	3rd and 4th story

†One smokeproof stair tower from the level of the assembly hall leading directly to the exterior at street grade shall be provided for every 750 persons capacity, or fraction thereof. These stairways shall be at least 44 inches wide and shall be in addition to other required stairways in the building.

(3) BASEMENT ASSEMBLY HALL. An assembly hall may be placed in the basement of a Type No. 1 or No. 2 building if the capacity does not exceed 2,500 persons, or in the basement of a building of Type No. 3 through No. 6 construction if the capacity does not exceed 400 persons.

History: 1-2-56; r. and recr. Register, September, 1959, No. 45, eff. 10-1-59; am. (2) and (3), Register, June, 1972, No. 198, eff. 1-1-73; am. (2), Register, September, 1973, No. 213, eff. 10-1-73.

Ind 55.04 Exposure and courts. (1) Every theater or assembly hall which accommodates more than 600 persons shall have at least 3 walls abutting on streets, alleys, or open courts.

(2) The wall containing the main entrance to any theater or assembly hall shall abut on a street. The lobby or passageway leading from the main entrance doors to the foyer or auditorium shall be direct and unobstructed and of a minimum width equal to the sum of the widths of the main entrance doors. There shall be no openings from other occupancies to such a corridor or passageway.

(3) The width of every exit court shall be at least 6 feet for an occupancy not exceeding 500 persons, and shall be increased at the rate of one foot per each 500 persons additional. Every such court shall lead to a public thoroughfare, either directly, or through a passageway of equal width, not less than 8 feet high enclosed with unpierced 4-hour fire-resistive walls, ceiling and floor as specified in section Ind 51.04. The floor and ceiling shall be designed for a live load of not less than 150 pounds per square foot. No such court, or passageway shall be used for storage or any other purpose whatsoever.

History: 1-2-56; am. (3), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (3) eff. 8-1-71 and exp. 1-1-72; cr. (3) eff. 1-1-72, Register, July, 1971, No. 187.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

Ind 55.05 Separation from other occupancies. (1) Every theater and assembly hall shall be separated from any other occupancy by an absolute occupancy separation as specified in section Ind 51.08, except that a special occupancy separation as specified in section Ind 51.08 may be used between an assembly hall accommodating not more than 750 persons and any other non-hazardous occupancy. Where a special occupancy separation is permitted in this section, a single fire-resistive door may be used for the protection of openings.

(2) For assembly halls of unlimited capacity located on upper floors of Type No. 1 and No. 2 buildings which are served by elevators, the elevator openings may be permitted under the requirements for special occupancy separation specified in section Ind 51.08, but otherwise absolute occupancy separation is required.

(3) Where a garage which is more than 500 square feet in area, chemical laboratory or other occupancy where flammable or explosive liquids or gases are used or stored is built in connection with a building used for a theater or assembly hall, it shall be separated therefrom by means of 4-hour fire-resistive walls and unpierced 4-hour fire-resistive floors above and below as specified in section Ind 51.04. All openings in the wall to adjoining parts of the building shall be protected by means of self-closing fire-resistive doors as specified in section Ind 51.047.

History: 1-2-56; am. Register, January, 1961, No. 61, eff. 2-1-61; am. (3), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (3) eff. 8-1-71 and exp. 1-1-72; cr. (3) eff. 1-1-72, Register, July, 1971, No. 187; am. (2), Register, June, 1972, No. 198, eff. 1-1-73.

Ind 55.06 Capacity. (1) The following table includes various types of occupancy within the scope of this section, together with the method to be used in determining the capacity.

(2) No greater number of persons than the number thus established shall be permitted in any theater or assembly hall.

Use or Occupancy	Basis of Capacity
(a) Arenas and field houses	4 sq. ft. per person. Use seated areas only.
(b) Assembly halls, with stage	7 sq. ft. per person.
(c) Banquet halls	10 sq. ft. per person.
(d) Churches (auditoriums)	7 sq. ft. per person.
(e) Churches (dining rooms)	10 sq. ft. per person.
(f) Dance halls	10 sq. ft. per person.
(g) Dining rooms	10 sq. ft. per person.
(h) Gymnasiums	6 sq. ft. per person for seated space. 15 sq. ft. per person for unseated space.
(i) Lecture halls	7 sq. ft. per person.
(j) Lodge halls	6 sq. ft. per person for seated space. 15 sq. ft. per person for unseated space.
(k) Skating rinks	15 sq. ft. per person.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

DEPT. OF INDUSTRY, LABOR & HUMAN RELATIONS 157

Theaters, assembly halls

(l) Theaters..... 7 sq. ft. per person.

(m) Theater lobbies..... 7 sq. ft. per person.

(3) The capacity of theaters and theater lobbies must be combined to determine the theater capacity.

(4) (a) Every theater or assembly hall having movable seats shall display a sign stating the maximum number of persons permitted by code.

1. The sign shall be placed in a conspicuous place at the main entrance to each theater or assembly hall.

2. The sign shall have the following wording: "Limit (Number) Persons." The maximum number of persons shall be determined by the capacity as permitted by subsection (2) and section Ind 55.12. The lettering shall be white on a dark background. The letters shall be not less than 1½ inches in height and the number shall be not less than 3 inches in height.

History: 1-2-56; cr. (4) (a), Register, July, 1966, No. 127, eff. 8-1-66; r. (2) (k), renum. (2) (l) (m) (n) to be (k) (l) and (m), Register, September, 1973, No. 213, eff. 10-1-73.

Ind 55.07 Number and location of exits. (1) Every floor and balcony of a theater and assembly hall shall be provided with not less than 2 exits, placed as far apart as practicable and so located that if any exit is blocked, some other exit will still be available from every part.

Exception: In places of worship, only one exit will be required from a balcony seating not more than 30 persons.

(2) Where more than 600 persons are accommodated, there shall be at least 3 exits and where more than 1,000 persons are accommodated, there shall be at least 4 exits.

(3) Exits shall be distributed on all sides which adjoin streets, alleys or open courts.

Ind 55.08 Type of exits. (1) The required exits from any part of a theater or assembly hall shall be exit doorways, stairways or ramps.

(2) All exits to grade from a higher or lower level shall be stairways or approved ramps. In all theaters and in assembly halls having a capacity of more than 400 persons, where the exit rise is not more than 3 feet approved ramps shall be used. By approved ramp is meant an incline located inside the building and having a slope of not more than one foot of rise in 8 feet.

(3) Stairway exits shall be interior stairways, or smokeproof towers as specified in section Ind 51.17; except that "B" type fire escapes may be used as exits from balconies for not more than one-half the required exit width, if located against blank walls.

Ind 55.09 Stairways. (1) Every stairway in a theater or assembly hall shall be enclosed as specified in sections Ind 51.17 and 51.18 with the following exceptions:

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

(a) Stairways from the main floor to the first balcony need not be enclosed.

(b) Stairways from the basement to the first floor of a single story place of worship need not be enclosed if they lead directly to the exits.

(2) A room may be placed under a stairway platform landing of 2-hour fire-resistive construction or better provided such room does not have combustible materials or hazardous equipment stored or operated therein. The partitions shall be constructed of noncombustible materials. All openings shall be protected with 20-minute fire door assemblies, or equivalent.

(3) Stairways and steps which have more than 3 risers shall have handrails on both sides.

(4) Every stairway used by the public in a theater or assembly hall shall have a uniform rise of not more than 7½ inches and a uniform tread of not less than 10 inches, measuring from tread to tread and from riser to riser. No winders shall be used and there shall be not less than 3 nor more than 16 risers in any run.

Note. See section Ind 51.16 for general stairway requirements.

History: 1-2-56; am. Register, January, 1961, No. 61, eff. 2-1-61; r. and recr. Register, February, 1968, No. 146, eff. 3-1-68; am. (4), Register, February, 1971, No. 182, eff. 7-1-71; am. (2), Register, December, 1974, No. 228, eff. 1-1-75.

Ind 55.10 Exit doorways and doors. (1) Every required single exit doorway shall contain a standard exit door as specified in section Ind 51.15. For double doors, with or without mullions, the width of each door may be reduced to 2 feet 6 inches.

(2) No single door or leaf of a double door, shall be more than 3 feet 6 inches wide, and no 2 doors shall be hinged together.

(3) No rolling, sliding or revolving door shall be counted as an exit from any theater or assembly hall, nor shall any such door be permitted where it would be liable to be used by the public as an exit.

(4) Sills at all exit doorways shall be level and flush with adjacent inside floors and ramps. Where an aisle or passageway leads to an exit from either side of the exit doorway there shall be a level floor space at the doorway subtending the width of the aisle and the doorway.

Ind 55.11 Exit lights. (1) In every theater and assembly hall, except church auditoriums, exit lights shall be provided immediately over all exit doorways, and in such other places as may be necessary to direct the occupants to exit doorways and to a street, alley or exit court. The installation of such exit lights shall comply in all respects with the provisions of the Wisconsin state electrical code.

(2) Every light over an exit doorway shall be a red illuminated sign bearing the word EXIT or OUT in plain letters not less than 5 inches in height.

(3) All exit lights shall remain lighted during each occupancy and until the occupants have left the building.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

Ind 55.12 Required exit width. (1) The total required exit width from a building level shall be in accordance with the requirements of subsections Ind 51.15 (6) and Ind 51.16 (3).

(2) In theaters, the width of the front entrance shall be not less than $\frac{1}{3}$ of the total required exit width.

History: 1-2-56; am. (1), Register, June, 1972, No. 198, eff. 1-1-73; am. (1), Register, December, 1974, No. 228, eff. 1-1-75.

Ind 55.13 Seating. (1) All seats, chairs and benches shall be placed not less than 32 inches back to back measured horizontally, except that for grandstands and bleachers without back rests this dimension may be reduced to 22 inches. For benches without arms, grandstands, and bleacher seats, the seating capacity shall be established by allowing one sitting or seat to each 18 inches of length. (See section Ind 55.54).

(2) All seats, chairs, and benches, except chairs in boxes or loggias, shall be securely fastened to the floor; or if the floor is level, the seats or chairs may be fastened together in groups of 3 or more. Loose chairs or seats shall not be used unless a special permit is secured from the department of industry, labor and human relations.

(3) There shall not be more than 12 seats in a row between aisles, nor more than 6 seats in a row which has an aisle on one side only except that for grandstands or bleachers without back rests and with a railing along the front, these figures may be doubled. No aisles will be required for such grandstands or bleachers where the seats extend to the floor or ground without a railing along the front.

(a) The number of seats in a row may be increased to 100 where self-raising seats are provided which leave an unobstructed passageway between rows of not less than 18 inches in width leading to a side aisle on each side of the auditorium in which exit doorways are located at not more than 20 feet intervals to an exit corridor or exit court.

(4) No seat bench or platform on which seats are placed shall be more than 22 inches in height of riser.

(5) No seat bench, or other platform or floor area on which seats are placed, or the top seat of any bleachers shall be nearer to the ceiling than 8 feet, nor nearer to the bottom of any truss or girder than 6 feet 4 inches.

(6) The requirements of this section do not apply to restaurants, dining or dance halls.

History: 1-2-56; am. Register, January, 1961, No. 61, eff. 2-1-61.

Ind 55.14 Width of aisles. (1) Aisles having seats on both sides shall not be less than 2 feet 10 inches wide at the beginning and shall increase in width toward the exits at the rate of $\frac{1}{4}$ inch per foot of run; or the aisle may have a uniform width not less than the average width of the foregoing calculation. No wall aisle shall be less than 3 feet wide and no other straight aisle shall be less than 3 feet 6 inches wide.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

(2) There shall be a cross aisle leading to each required side exit. Cross aisles shall not be less than 6 feet 8 inches back to back of adjacent rows of seats.

Ind 55.15 Lobbies and foyers. The width of lobbies and foyers shall be determined on the same basis as required for exits in section Ind 55.12, but shall in no case be less than 5 feet wide, and shall be so designed and apportioned as to prevent congestion and confusion. Lobbies and foyers which serve as means of egress shall be at least equal in combined width to the required width of the stairways, passageways, aisles or exit doorways leading to them.

Ind 55.16 Inclines and aisle steps. (1) To overcome any difference in level between courts, corridors, lobbies, passageways or aisles required, or used, in egress from a theater or an assembly hall, approved ramps as specified in section Ind 55.08 shall be employed where the difference in elevation does not exceed 3 feet, except that this requirement need not apply to balconies.

(2) Steps in balcony aisles shall extend the full width of the aisle and shall have a uniform rise and run as specified in section Ind 55.09. No handrails will be required.

Ind 55.17 Obstruction. (1) All lobbies, aisles, passageways and doorways shall be kept free from furniture, drapes, display equipment, merchandise, vending machines and other obstructions, and no person except an employe shall be allowed to stand in or occupy, any of the aisles, passageways, corridors or lobbies during any performance or public gathering. Except that patrons may be allowed to wait in a lobby or similar space if such use does not encroach upon the required clear width of the exits. Such waiting shall be restricted to areas separated from the required exit ways by fixed railings not less than 42 inches high. In entrance lobbies only, the exit space may be divided by railings not less than 36 inches high set up in the direction of travel in an approved manner for the regulation of ingress and egress.

(2) A booth or counter for the sale of package merchandise may be placed in the lobby or foyer of a theater where there is sufficient excess space so that the front of the booth or counter can be located not less than 5 feet back of the line marking the width of the lobby or foyer required for exit purposes.

Ind 55.18 Mirrors and false openings. (1) No mirror shall be placed in any part of a theater or assembly hall used by the public for exit purposes, including lobbies, corridors, stairways, ramps or any other exit facility. Where a mirror is used in an auditorium, it shall be placed flush with the wall and with the bottom at least 7 feet above any floor, balcony, gallery or platform.

(2) No false opening or decorative device giving the appearance of a door or window, where none exists, shall be placed in any part of a theater or assembly hall used by the public.

Ind 55.19 Decorations. Fabric decorations used in theaters and assembly halls shall be flame proof.

Ind 55.20 Elevator and vent shafts. Enclosures for elevator and vent shafts shall be of 2-hour fire-resistive construction as specified in section Ind 51.04 and all openings therein protected by fire-resistive doors or windows as specified in section Ind 51.047.

History: 1-2-56; am. Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. eff. 8-1-71 and exp. 1-1-72; cr. eff. 1-1-72, Register, July, 1971, No. 187.

Ind 55.21 Stage separation. (1) In every theater and assembly hall the stage shall be completely separated from the auditorium by a proscenium wall of 4-hour fire-resistive construction as specified in section Ind 51.04, except as follows:

(a) In theaters and assembly halls having a capacity not exceeding 500 persons, the proscenium wall shall be of 2-hour fire-resistive construction as specified in section Ind 51.04, or better.

(b) In theaters and assembly halls an open stage or platform will be permitted without the proscenium wall separation from the auditorium, provided the stage or platform is not more than 6 feet higher or wider than the proscenium opening.

History: 1-2-56; am. (1) intro par., and (1) (a), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (1) intro. para. and (a), eff. 8-1-71 and exp. 1-1-72, and cr. (1) intro. par. and (a), eff. 1-1-72, Register, July, 1971, No. 187.

Ind 55.22 Proscenium wall. (1) The proscenium wall shall extend from an incombustible foundation, or from the lowest fireproof floor below the stage floor, to the highest adjoining roof, except that where a 4-hour fire-resistive wall is required it shall extend at least 2 feet above the highest adjoining roof.

(2) There shall be not more than 2 openings in the proscenium wall below the level of the auditorium floor, and not more than 2 openings other than the proscenium opening, in the proscenium wall above the level of the auditorium floor, except that in addition to the above openings there may be one opening to provide access through the proscenium wall to the orchestra pit.

(3) Each such opening shall not exceed 21 square feet in area and shall be protected by a fire-resistive door as specified in section Ind 51.047.

History: 1-2-56; am. (3), Register, March, 1972, No. 195, eff. 4-1-72.

Ind 55.23 Proscenium curtain. Where a proscenium wall is required for the separation of a stage from an auditorium, the proscenium opening shall be provided with a curtain as approved by the department.

Note: The department will accept standards for the design and installation of "Proscenium Curtains" as specified in the 1970 edition of the "Uniform Building Code" published by the International Conference of Building Officials.

History: 1-2-56; r. and recr. Register, May, 1971, No. 185, eff. 6-1-71.

Ind 55.24 Automatic smoke outlet. Where a fireproof proscenium curtain is required, or provided, the stage shall be provided with one or more automatic smoke outlets, constructed of metal or other incombustible material, placed near the center and above the highest part of the stage, and having a combined area equal to not less than

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

8% of the area of the stage floor. Vertical louver openings shall be placed not less than 3 feet above the roof and shall be not less than twice the area of the shaft. The smoke outlet shall be designed and constructed so as to open by gravity, and so as to effectively overcome the effects of neglect, rust, dirt, frost, snow, heat, twisting, or warping of the frame work. The louvers, or dampers in the openings shall be held closed by cotton or hemp cords running to the stage floor close to each stage door. Fusible links, or other approved heat release devices, shall be inserted in each cord near the outlets.

Ind 55.25 Stage vestibules. All entrances to the stage shall be vestibuled in such manner as to protect the curtain, scenery, and auditorium from drafts of air.

Ind 55.26 Footlight trough. The footlight trough shall be made of, or lined with, incombustible material.

Ind 55.27 Fireproof paint. All stage scenery, properties, curtains, and decorations made of combustible material, and all woodwork in or about the stage, shall be effectively flame-proofed.

Ind 55.28 Stage accessory rooms. (1) All dressing rooms, property rooms, and other storage or workrooms shall be built of incombustible material throughout, and shall be separated from the stage by a special occupancy separation as specified in Wis. Adm. Code section Ind 51.08.

(2) No dressing room or employes' room shall be placed more than one story below the grade line, and no dressing room shall be placed above or below the auditorium unless separated therefrom by a special occupancy separation as specified in section Ind 51.08.

Ind 55.29 Boiler and furnace rooms. (1) Every boiler or furnace room, including the breeching and fuel room, shall be enclosed with a 3-hour fire-resistive enclosure as specified in section Ind 51.04, except that in case of an assembly hall accommodating not more than 300 persons, a 2-hour fire-resistive enclosure as specified in section Ind 51.04 may be used. All openings shall be protected with self-closing fire-resistive doors as specified in section Ind 51.047.

(2) All appliances used for heating water which are fired with solid fuel, liquid fuel or gas shall be located in a boiler or furnace room except that gas fired booster water heaters used exclusively for sanitizing dishes and cooking utensils need not be installed in a fire-resistive enclosure.

History: 1-2-56; r. and recr. (2), Register, August, 1957, No. 20, eff. 9-1-57; am. (1), Register, September, 1959, No. 45, eff. 10-1-59; am. (1), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (1), eff. 8-1-71, and exp. 1-1-72; cr. (1) eff. 1-1-72, Register, July, 1971, No. 187.

Ind 55.30 Lights and lighting. (1) Electric lights shall be used for lighting where electric current is available. No oil lamps or other open lights shall be used in or about any stage containing scenery.

(2) No gas lighting of any kind shall be used on any stage containing scenery, nor in any property room, storage room, scene dock, or fly gallery, except in localities where electricity is not available.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

(3) In all theaters and assembly halls, all stairways, passageways, and exit doors shall be properly lighted and shall remain lighted throughout every performance or entertainment and until the audience has left the building.

55.32 Sanitary facilities. (1) **TOILET ROOMS.** All occupancies included under the scope of this chapter shall be provided with separate toilet rooms for each sex. Separate toilet rooms for the employes and the general public need not be provided if the toilet rooms are accessible to both the employes and the general public.

(a) *Toilet rooms in connection with stage.* In theaters and assembly halls which are equipped for the showing of stage productions, separate toilet rooms for each sex, furnished with at least one water closet and one lavatory, shall be provided in connection with the stage.

(b) *Toilet room in connection with motion picture booth.* In theaters where motion picture machines are run continuously for a period of more than 2 hours without at least 10 minutes intermission for the motion picture machine operator for each 2-hour period, a toilet room, furnished with one water closet and one lavatory, shall be provided in direct connection with the motion picture booth.

(2) **SANITARY FIXTURES.** The number of fixtures required for the total number of patrons of each sex shall be determined in accordance with the ratios established in Table 55.32. The number of fixtures required for the employes in accordance with Table 54.12 shall be added to the number of fixtures required for the general public. The total number of persons will be considered equally divided between men and women unless a different ratio is established.

TABLE 55.32

Type of Occupancy	Type of Fixture				
	Water Closets (WC)		Urinals (U)	Lavatories (L)	Drinking Facilities (DF)
	Males (M)	Females (F)	Males (M)		
Places of assembly					
0-100 persons of each sex	1	1	0		
101-200 persons of each sex	1	2	1		
201-300 persons of each sex	1	3	2		
301-400 persons of each sex	2	4	2		
401-500 persons of each sex	2	5	3		
501-600 persons of each sex	2	6	4		
Over 600 persons of each sex	One (WC) for each additional 600 (M), or fraction	One (WC) for each additional 275 (F), or fraction	One (U) for each additional 500 (M), or fraction	One (L) for each 2 (WC) and/or (U), or fraction	One additional (DF) for each additional 3000 persons
Taverns and restaurants	One (WC) for each 75 (M), or fraction	One (WC) for each 30 (F), or fraction	One (U) † for each 50 (M), or fraction		0

†Urinal may be omitted in restaurants which accommodate less than 25 males and do not serve alcoholic beverages.

Note: See also rules of the department of health and social services for sanitary fixtures for public swimming places, mobile home parks, camping grounds, camping resorts, recreational camps and educational camps.

History: 1-2-56; r. and recr. Register, December, 1976, No. 252, eff. 1-1-77.

Ind 55.33 Standpipes. (1) **FIRE DEPARTMENT STANDPIPES.** Fire department standpipes shall be provided in all buildings exceeding 60 feet in height.

(2) **FIRST-AID STANDPIPES.** First-aid standpipes shall be provided in all buildings having theaters and assembly halls with an occupancy load of more than 300 persons, unless an approved automatic sprinkler system is installed. First-aid standpipes shall also be provided on the stage of every theater and assembly hall where a fire curtain is required.

History: 1-2-56; r. and recr. Register, December, 1976, No. 252, eff. 1-1-77.

Ind 55.34 Fire extinguishers. (1) Standard fire extinguishers of an appropriate type as specified in section Ind 51.22 shall be provided for all theaters and assembly halls as follows:

- (a) Two on stage, if scenery is used.
- (b) One on stage, if no scenery is used.
- (c) One in motion picture booth, or in ticket office if there is no booth.
- (d) One in dressing room section.

(2) Extinguishers shall be properly exposed to view and always accessible.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

DEPT. OF INDUSTRY, LABOR & HUMAN RELATIONS 165
Theaters, assembly halls

Ind 55.35 Automatic sprinklers. In every theater and assembly hall where a proscenium curtain is required, approved automatic sprinklers, as specified in section Ind 51.23, shall be provided under the stage, under the stage roof, and in the dressing rooms, but not in the automatic smoke outlet.

Ind 55.39 Use of "safety-base" film. (1) The requirements of sections Ind 55.40 through 55.49 will not apply in buildings in which movie projectors are used with "safety-base" film provided the conditions of (a) and (b) in this subsection are met.

(a) The owner shall submit an affidavit to the department of industry, labor and human relations stating that "safety-base" film only will be used in all movie projectors.

(b) The affidavit shall be signed by the owner and the signature notarized.

Note: For definition of "owner", see section 101.01 (2) (i), Wis. Stats.

History: Cr. Register, April, 1971, No. 184, eff. 5-1-71.

Ind 55.40 Motion picture machine booths, general. Every motion picture machine using nitro-cellulose film, together with all auxiliary and associated equipment, shall be enclosed in a booth so arranged as to permit the operator to walk freely on either side and in back of the machine. At least 48 square feet in area shall be provided for one machine, and 24 square feet additional for each machine over one. The ceiling height shall be not less than 7 feet.

Ind 55.41 Construction of booth. The floor of each motion picture booth shall be constructed of masonry or reinforced concrete, or shall be covered with not less than 2 inches of fire-resistive material. The walls and ceilings shall be not less than 2-hour fire-resistive construction as specified in section Ind 51.04.

History: 1-2-56; am. Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. eff. 8-1-71 and exp. 1-1-72; cr. eff. 1-1-72, Register, July, 1971, No. 187.

Ind 55.42 Doors. (1) The door to the booth shall be not larger than necessary for the safe and proper use and maintenance of the booth and equipment, but in no case shall its dimensions be smaller than 2 feet by 5 feet or larger than 3 feet by 7 feet. The top of the door shall be not less than 12 inches below the ceiling of the booth.

(2) The door shall be a tight-fitting self-closing fire door as specified in section Ind 51.047, shall open outwardly, and shall not be equipped with any latch.

History: 1-2-56; am. (2), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (2) eff. 8-1-71 and exp. 1-1-72; cr. (2) eff. 1-1-72, Register, July, 1971, No. 187.

Ind 55.43 Openings. (1) Two openings for each motion picture machine may be provided. The one for the operator's view shall not be larger than 200 square inches and the one for projection not larger than 120 square inches. Where separate stereopticon, spot, or flood-light machines are installed, not more than one opening shall be provided for each such machine for both the operator's view and the projection of light. All such openings shall be as small as practicable.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

(2) Each opening shall be provided with an approved gravity shutter set into guides not less than one inch at sides and bottom, and overlapping the top of the opening by at least one inch when closed. Shutters shall be not less than No. 10 U.S. Standard gauge iron or equivalent, arranged to move freely in guides of like material and thickness bolted to the wall. Each shutter shall be suspended by a cord and shall be so arranged that closing is by gravity action. A fusible link shall be provided in the cord over each shutter. A link shall also be provided over each magazine, which on operating will close all shutters. A manual release shall be provided near each exit door by which all shutters can be closed simultaneously. Shutters shall not be blocked open nor held open in any manner except by the harness of cords and links as herein described.

Ind 55.44 Ventilation of booths. Every booth or room housing projection, sound or any other equipment which vitiates good air conditions or requires the attention of an attendant shall be ventilated as required by section Ind 64.05. Fresh air intakes in booth walls, except for outside air, shall not exceed 72 square inches in area, nor be more than 3 inches above the floor. They shall be equipped with automatic shutters as described for projection openings.

History: 1-2-56; r. and recr. Register, October, 1967, No. 142, eff. 11-1-67; am. Register, December, 1975, No. 240, eff. 1-1-76.

Ind 55.45 Relief outlets. Every booth or room housing projection, sound or other equipment which constitutes a fire, smoke, explosion or fuming hazard shall be equipped with one or more gravity outlets extending upward from the ceiling through the roof. The net area of such gravity relief outlets shall be equal to one per cent of the room or booth floor area, but not less than 12 inches in diameter. Such outlets shall be constructed as sheet metal ducts having double walls with ½ inch air space between, or better construction. Where a relief outlet passes through, or is within 18 inches of any combustible construction, or passes through any other occupancy, approved masonry flues as specified for chimneys, section Ind 64.46, shall be used. The relief outlets shall be equipped, at the booth or room outlets, with a gravity shutter which will open automatically under excessive heat conditions. The automatic shutter shall normally be tightly closed where mechanical exhaust ventilation is required in the same room.

Ind 55.46 Electric wiring. All lights and electric wiring, also motors, arc lamps, rheostats, and associated electrical equipment shall conform in type and arrangement to the requirements of the Wisconsin state electrical code.

Ind 55.47 Motion picture machine. Every projection machine shall be securely fastened to the floor, and together with sound head and other associated equipment, shall be of safe design. No part of the film shall be outside of a tight metal enclosure during projection, and the feed and take-up reels shall have riveted, flanged, or welded joints. A shutter shall be placed in front of the condenser, arranged so as to be closed except when held open by the operator, or by some mechanical device which will assure immediate closure when operation of the machine is stopped.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

Ind 55.48 Fire protection in booth; care and use of film (1) All shelves, furniture and fixtures shall be incombustible. No combustible material shall be permitted to be within such booth, except films and film cement not exceeding one pint. Smoking is prohibited. Heating equipment in booths shall be limited to steam, warm air, hot water or electric convection heaters with low surface temperature elements. Radiators shall be protected by $\frac{1}{4}$ inch mesh screen with the top sloped at least 45 degrees to the horizontal.

(2) Films not in process of rewinding, examination or projection shall be kept in metal containers. Up to 40 pounds of film may be kept in the projection booth in interstate commerce commission shipping containers. Excess over 40 pounds shall be kept in an approved film cabinet, but the total quantity of film in any booth shall not exceed 125 pounds.

(3) Rewinding in the projection booth is prohibited unless done in an approved enclosed type rewind machine. An approved can with self-closing hinged cover shall be provided for scrap film.

(4) Up to 125 pounds of film in addition to that permitted in a projection booth, may be kept in containers as specified above, providing this excess is in a rewind room of not less than 80 square feet area, and of the construction specified in sections Ind 55.41 and Ind 55.42. Such room shall have a vent of at least 50 square inches area extending upward to the outside of the building, with a clearance to combustible material conforming to section Ind 55.45. Furniture and heating shall be as for the projection booth, and smoking is prohibited.

Note: In the foregoing section the weight of a 1000 foot roll of 35 millimeter film is assumed as 5 pounds.

Ind 55.49 Portable booths. (1) Every portable booth used to confine the fire hazards of a motion picture machine shall be of approved design conforming to the requirements for permanent booths.

(2) Every booth used for more than 3 consecutive performances in one location will be considered a permanent booth.

Ind 55.50 Maintenance. All theaters and assembly halls, and all parts thereof, shall be kept clean, sanitary and in good repair.

GRANDSTANDS, BLEACHERS, TENTS AND PLACES OF OUTDOOR ASSEMBLY.

Ind 55.51 Grandstands. (1) Grandstands erected of frame construction shall be located at least 20 feet from any other building or adjoining property line unless the exterior walls of such adjacent building are of 2-hour fire-resistive construction or better and all openings therein are protected with fire-resistive doors and windows as specified in section Ind 51.047.

(2) No wood grandstand unit shall exceed 10,000 square feet in ground area or 200 feet in length.

(3) Wood grandstand units shall be placed not less than 20 feet apart or shall be separated by walls of not less than 2-hour fire-resistive construction.

(4) The highest level of seat platforms of any wood grandstands shall not be more than 20 feet. Portable grandstands or bleachers within tents shall not be more than 12 feet above the ground or surface at the front of the grandstand.

(5) All grandstands shall be designed and constructed to conform with the structural requirements of chapter Ind 53 of this code.

(6) Seat boards and foot boards shall be designed to safely support a live load of not less than 120 pounds per lineal foot. The width of foot boards shall not be less than 7½ inches.

(7) The space under a grandstand shall be kept free from extraneous flammable materials and shall not be occupied for other than exit purposes except that such space, if enclosed with one-hour fire-resistive construction or better, may be used for non-hazardous purposes if approved in writing by the department of industry, labor and human relations.

History: 1-2-56; am. (1), Register, February, 1971, No. 182, eff. 7-1-71; r. and recr. (1) eff. 8-1-71 and exp. 1-1-72; cr. (1) eff. 1-1-72, Register, July, 1971, No. 187.

Ind 55.52 Exits. (1) Every grandstand, balcony or tier considered separately shall be provided with at least 2 exits located as remotely from each other as practicable and leading directly to the outside at grade. If the capacity of any such structure, balcony, or tier exceeds 1,000 persons, there shall be at least 3 exits and where the capacity exceeds 4,000 persons, there shall be at least 4 exits.

(2) Exits shall be distributed uniformly to prevent congestion and shall be so located that the line of travel to an exit or to the entrance to an exit passageway is not greater than 150 feet.

(3) The total width of exits from any grandstand, balcony or tier shall not be less than 22 inches per 100 persons, except that for grandstands which are constructed of incombustible material throughout and have a closed incombustible deck under the seats, the total width of exits may be not less than 22 inches for each 500 persons or fraction.

Ind 55.53 Aisles and passageways. (1) All ramps, stairs, doorways and doors used for exit purposes shall conform to the requirements of sections Ind 55.08, 55.09 and 55.10 of this code.

(2) Aisles having seats on both sides shall not be less than 3 feet 6 inches in width and aisles having seats on one side only shall not be less than 24 inches wide. Cross aisles shall not be less than 48 inches in width. No aisles will be required for grandstands or bleachers where the seats extend to the floor or to the ground without a railing along the front.

(3) Trailer seating mounted on incombustible decking not exceeding 300 capacity each shall be provided with aisles or stairways not less than 36 inches in width.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

Ind 55.54 Seating. (1) The seating arrangement shall comply with the requirements of section Ind 55.13 except that for seats without backs the horizontal distance from back to back of seats shall not be less than 22 inches. There shall be a space of not less than 12 inches between the back of each seat and the front of the seat immediately behind it. All measurement is to be taken between plumb lines.

(2) Where the same level is not used for both seat bench and foot rest, independent foot rests shall be provided.

(3) All seat boards and foot boards shall be securely fastened in place in such a manner that they cannot be accidentally displaced.

(4) Where the rise of a seat bench or platform exceeds 11 inches, intermediate steps shall be provided the full width of the aisles. Such steps shall have a rise of not more than 11 inches and a tread of not less than 10 inches *nominal width*. In no case shall the angle of seating exceed 45 degrees.

Ind 55.55 Guard rails. A substantial guard rail not less than 42 inches in height and having 2 intermediate rails shall be provided along the back and ends of all grandstands where the seats are more than 4 feet above the ground. Where the front foot rest of any grandstand is more than 2 feet above the ground, a guard rail extending not less than 36 inches above such front foot rest shall be provided.

Ind 55.56 Portable grandstands or bleachers. (1) Portable grandstands or bleachers shall be self-contained units having all necessary parts to withstand and restrain all forces which may be developed during occupancy. They shall be so designed and constructed that if any structural member essential to the strength and stability of the structure is omitted during erection, the presence of unused connections or fittings will make the omission self-evident.

(2) A portable grandstand shall not be used for public occupancy until it has been securely assembled in accordance with this requirement.

(3) Portable grandstands shall be provided with base plates, sills, floor runners, or sleepers of sufficient area and strength to support safely the total live and dead loads.

(4) Where portable grandstands rest directly on the ground, mud sills of suitable material and having sufficient area to prevent dangerous settlement shall be provided under the base plates or sleepers. All mud sills shall be properly anchored to the ground and all bearing surfaces shall be in contact.

(5) A-frames or other supports and seat stringers for portable grandstands or bleachers shall be secured to prevent accidental displacement during occupancy.

(6) Field connections to wood members shall be by means of rivets, bolts, connectors, lag screws, friction or other approved devices. Lag screws shall not be used for direct tension. The use of nails and wood screws is permissible for holding wood posts together except that they shall not be used for demountable connections.

(7) Wood members in tension shall be connected at each end by not less than 2 bolts or lag screws or by approved connectors or other approved devices. Adequate provision shall be made to prevent the splitting or shearing of wood at such connections.

(8) The following requirements shall apply to folding and movable bleachers used in places of assembly in addition to the other requirements of sections Ind 55.56 and Ind 55.57.

(a) Shop drawings, specifications and calculations or a test report made by a recognized testing agency covering each bleacher model shall be submitted to the department of industry, labor and human relations by an architect or professional engineer registered in Wisconsin, for approval.

(b) No required exit doors or exit passageways shall be obstructed by any bleacher installation. Floor plans, elevations, and typical structural information showing the location of bleachers, exit doors, and exit passageways, for each installation shall be submitted to the department of industry, labor and human relations in triplicate for approval before work on the installation is commenced. The plans shall be made by and bear the seal of an architect or professional engineer registered in Wisconsin.

(c) All bleachers shall be designed to resist a horizontal swaying force applied to the seats in a direction parallel to the length of the seats of at least 24 pounds per lineal foot of seats and in a direction perpendicular to the seats of not less than 10 pounds per lineal foot of seats.

(d) Seat board and foot boards shall be designed to safely support a live load of not less than 120 pounds per lineal foot.

(e) All bleachers shall be equipped with sockets or holders along the back and ends to support guard rails. A guard rail not less than 42 inches in height and having 2 intermediate rails shall be provided along the back of the top row of seats. Guard rails not less than 42 inches in height above foot boards and having an intermediate rail at mid-height shall be provided at the open end of all bleachers where the seats are more than 4 feet above the floor.

(f) The highest level of seat platforms of any forward folding or movable bleachers shall not be more than 12 rows or 11 feet above the floor.

(g) Forward folding bleachers shall be securely anchored to the floor with bolts, lag screws, or other approved devices.

History: 1-2-56; cr. (8), Register, November, 1963, No. 95, eff. 12-1-63.

Ind 55.57 Inspection. Every portable grandstand or bleacher shall be carefully inspected by a building official before each period of public occupancy and any loose connections, defective or broken members or loose supports shall be properly repaired before the structure is used. In cities or towns which do not have a building official, such inspections shall be made by the chief of the fire department or other public official designated by the department of industry, labor and human relations.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code

Ind 55.58 Tents. (1) For the purpose of this section a tent is a portable, temporary shelter or a structure, the covering of which is made of pliable material.

(2) No tent shall be erected to cover more than 75% of the premises on which it is located.

(3) Tents used for assembly purposes which cover 1500 square feet or more of ground area shall be located at least 20 feet from any other structure or adjoining property lines.

(4) Stake lines of adjacent tents used for assembly purposes shall be sufficient distance from each other to provide an emergency exit passageway not less than 6 feet in width between stake lines. Proper protection shall be provided along such stake lines to eliminate tripping hazards.

(5) Concession and other tents not used for assembly purposes need not be separated from each other and may be located less than 20 feet from other structures.

(6) This section does not apply to tents or shelters used exclusively for construction purposes.

Ind 55.59 Structural requirements. (1) Poles and other members supporting tents shall be of sufficient size and strength to support the structure safely without exceeding the stresses specified in chapter Ind 53 of this code.

(2) All tents shall be adequately guyed, supported and braced to withstand a wind pressure or suction of not less than 10 pounds per square foot.

(3) The poles, guys, stakes, fastening, etc., shall be of sufficient strength and so attached as to resist a wind pressure of at least 20 pounds per square foot of projected area of the tent.

Ind 55.60 Flame resistance. All tents used for assembly purposes or in which animals are stabled and all other tents used by the public in places of outdoor assembly shall be effectively flame-proofed. The owner shall furnish a certificate or a test report by a recognized testing engineer or laboratory as evidence that such tents have the required flame resistance.

Ind 55.61 Fire hazards. (1) The ground enclosed by any tent used in connection with a place of outdoor assembly and for a distance of not less than 10 feet outside such structure on all sides shall be cleared of all flammable material or vegetation which will transmit fire. The premises shall be kept free from such flammable material during the period the premises are used by the public.

(2) No hay, straw, shavings or similar combustible materials other than that necessary for the current feeding and care of animals shall be permitted within any tents used for public assembly except that sawdust and shavings be used if kept damp.

(3) No smoking or unapproved open flame of any kind shall be permitted in any tent while occupied by the public. "No Smoking" signs shall be conspicuously posted in all tents open to the public.

(4) Tents shall not be used for motion picture performances unless safety film is used.

Ind 55.62 Exits. (1) Every tent occupied by the public shall have at least 2 standard exits located at or near opposite ends of the structure.

(2) In tents used for assembly purposes, exits shall be provided on 3 sides if the capacity exceeds 600 persons and on 4 sides where the capacity exceeds 1,000 persons. Exits shall be uniformly distributed but in no case shall the line of travel to an exit be greater than 150 feet.

(3) The total width of exits from a tent used for assembly purposes shall not be less than 44 inches per 100 persons. Exit openings shall comply in all respects with the requirements of Wis. Adm. Code sections Ind 55.10 and Ind 51.15 of this code.

Ind 55.63 Electrical installations. (1) Electrical systems in all places of outdoor assembly shall be installed in accordance with the requirements of the Wisconsin state electrical code. All such systems shall be maintained and operated in a safe and workmanlike manner.

(2) The electrical system and equipment shall be isolated from the public by proper elevation and guarding. All electrical fuses and switches shall be installed in approved enclosures. Cables laid on the ground or in areas traversed by the public shall be placed in trenches or protected by approved covers.

Ind 55.64 Fire extinguishing equipment. One or more fire extinguishers of approved type and size shall be provided in connection with every wood grandstand and in all tents used for assembly purposes. Such extinguishers shall be maintained in proper working order and shall be located where they are easily accessible, preferably in or near the ticket office. In large installations, additional fire extinguishing equipment shall be provided as directed by the building official.

Ind 55.65 Illumination; exit lights and signs. (1) All exits, aisles and passageways leading to exits in grandstands and other places of outdoor assembly shall be kept adequately lighted at all times when the structure is occupied by the public. Artificial illumination having an intensity of not less than 2.5 foot candles at the floor line shall be provided when natural light is inadequate.

(2) Exit lights and signs complying with the requirements of section Ind 55.11 shall be provided in all places of outdoor assembly where more than 100 persons can be accommodated.

Ind 55.66 Boiler and furnace room. Every boiler or furnace room, including the breeching and fuel room, in places of outdoor assembly, shall be enclosed with a 2-hour fire-resistive enclosure or better and all interior openings in walls forming such enclosures shall be protected by self-closing fire-resistive doors. Gas-fired appliances for

heating water shall be installed in a boiler or furnace room. Chimneys shall be constructed in conformity with the requirements of section Ind 64.45 of this code.

Ind 55.67 Toilet facilities. Separate toilets shall be provided for each sex in connection with all places of outdoor assembly. Toilet rooms and equipment shall comply in all respects with the requirements of sections Ind 52.50-Ind 52.64, inclusive, of this code.

Ind 55.68 Outdoor theaters. (1) **DEFINITION AND SCOPE.** For the purpose of this code, an outdoor theater is a place of outdoor assembly used for the showing of plays, operas, motion pictures and similar forms of entertainment in which the audience views the performance from self-propelled vehicles parked within the theater enclosure. The requirements of this section shall apply to outdoor theaters now in existence and to outdoor theaters hereafter constructed, except as provided in subsection (5).

(2) **ENTRANCES AND EXITS.** All entrances and exits for outdoor theaters shall comply with the regulations of the state highway commission for driveways from property abutting state highways and the following additional requirements:

(a) Not more than one entrance shall be provided for each access road but each such entrance may be divided into 2 roadways and channelized to properly provide for vehicles turning right or left from the highway.

(b) That portion of an entrance or exit lying within the highway right-of-way shall comply with the regulations of the authority in charge of the maintenance of the highway or in the event this authority has no regulation, it shall comply with regulations prescribed by the state highway commission.

(c) Not more than one exit shall be provided for each access highway but such exit may be suitably channelized to provide for right and left turns to the highway, and not more than one traffic lane shall be permitted for each traffic lane on the highway available to vehicles leaving the theater.

(3) **VEHICLE STORAGE.** (a) Sufficient area shall be provided between the highway and the ticket booth to provide storage space for vehicles equal to not less than 10% of the theater capacity. In all cases, sufficient storage space shall be provided so the vehicles will not back up on the traveled way of the highway. Storage area shall be calculated on the basis of 162 square feet per vehicle.

(b) A hold-over storage area having sufficient capacity to accommodate not less than 15% of the theater capacity shall be provided between the ticket booth and the ramp area.

(4) **TOWER CONSTRUCTION.** The tower supporting the motion picture screen shall be designed to resist a horizontal wind pressure of not less than 30 pounds for every square foot of exposed surface.

(5) **LOCATION OF TOWER.** The screen shall be so oriented that the picture is not visible from any major highway. This requirement does not apply to towers erected prior to January 1, 1952.

(6) **CONCESSION AND MOTION PICTURE MACHINE BOOTH.** The motion picture booth and equipment shall comply in all respects with the requirements of sections Ind 55.40-55.49, inclusive, of this code.

(a) Concession buildings in connection with outdoor theaters shall comply with the requirements of chapter Ind 54 of this code.

(7) **SANITARY EQUIPMENT.** Separate toilet rooms shall be provided for males and females in connection with all outdoor theaters as required by section Ind 55.32. Toilet rooms and equipment shall comply in all respects with the requirements of sections Ind 52.50-52.64 of this code.

(a) In determining the number of fixtures required for toilet rooms in connection with outdoor theaters, the capacity of the theater is established by allowing $2\frac{1}{4}$ persons for each vehicle accommodated, exclusive of vehicles parked in the waiting or hold-over area.

(b) Where the public toilet rooms are so located that the patrons must cross the ramp area in order to reach the toilet rooms, a suitable approach or passageway leading thereto shall be maintained. Such passageways shall be properly lighted and they shall be kept free from obstructions.

(8) **RAMPS AND SPEAKER EQUIPMENT.** (a) Ramps shall be spaced not less than 38 feet apart. The ramps shall be so designed that any vehicle can move from its parked position to the exit driveway without being required to back up.

(b) All ramps, parking areas, entrance and exit driveways shall be properly surfaced with a gravel surfacing or better, adequate to withstand the weight of the vehicles accommodated.

(c) Where additional seating space is provided in the theater enclosure for patrons using public transportation facilities, the speaker arrangement shall be such that the sound will be confined to the immediate seating area and not broadcast beyond the theater enclosure.

(d) There shall not be less than 18 feet distance between speaker posts, measured parallel to the ramps, except in seated areas for patrons using public transportation. All electrical wiring and electrical equipment shall be installed in accordance with the provisions of the Wisconsin state electrical code. Each speaker post shall be wired with wire approved for underground use laid in trenches not less than 12 inches in depth.

(9) **LIGHTING.** All entrance and exit driveways shall be adequately lighted and properly marked to avoid congestion and confusion and shall remain lighted throughout the performance and until the audience has left the area.

(10) **SPEED LIMIT.** In every outdoor theater, notices of a permanent character shall be prominently displayed designating the maximum speed limit permitted for cars driven within the area. Parking lights shall be used when cars are moving in the theater enclosure.

DEPT. OF INDUSTRY, LABOR & HUMAN RELATIONS 175

Theaters, assembly halls

(11) **RUNNING OF ENGINES.** At each performance, an instructive trailer shall be shown on the screen informing the patrons of the danger of carbon monoxide poisoning when the engine is running and stating that when it becomes necessary to run the engine, the windows of the vehicle should be opened at least one inch.

History: 1-2-56; r. and recr. Register, September, 1959, No. 45, eff. 10-1-59.

Register, December, 1976, No. 252
Building and heating, ventilating
and air conditioning code