

Chapter SPS 324

ELECTRICAL STANDARDS

SPS 324.01 Electrical standards.

Note: Chapter Ind 24 was renumbered to be chapter ILHR 24, Register, February, 1985, No. 350, effective 3-1-85. Chapter ILHR 24 was renumbered to be chapter Comm 24 under s. 13.93 (2m) (b) 1., Stats., and corrections made under s. 13.93 (2m) (b) 7., Stats., Register, January, 1999, No. 517, eff. 2-1-99. Chapter Comm 24 was renumbered chapter SPS 324 under s. 13.92 (4) (b) 1., Stats., Register December 2011 No. 672.

SPS 324.01 Electrical standards. (1) All electrical wiring, installations, equipment and materials used in the construction of dwellings shall comply with the requirements of the

Wisconsin Administrative Electrical Code, Vol. 2., ch. SPS 316, except as provided in sub. (2).

(2) The requirements in NEC section 210.70 (A) (2) (b) do not apply to a stairway for a deck.

Note: A light over the stairs is not required, but a light outside the door is.

History: Cr. Register, November, 1979, No. 287, eff. 6-1-80; am. Register, March, 1992, No. 435, eff. 4-1-92; correction made under s. 13.92 (4) (b) 7., Stats., Register December 2011 No. 672; CR 15-043: am. (1), cr. (2) Register December 2015 No. 720, eff. 1-1-16.