

Chapter NR 665

APPENDIX III

EPA INTERIM PRIMARY DRINKING WATER STANDARDS

Parameter	Maximum level (mg/L)
Arsenic	0.05
Barium	1.0
Cadmium	0.01
Chromium	0.05
Fluoride	1.4–2.4
Lead	0.05
Mercury	0.002
Nitrate (as N)	10
Selenium	0.01
Silver	0.05
Endrin	0.0002
Lindane	0.004
Methoxychlor	0.1
Toxaphene	0.005
2,4–D	0.1
2,4,5–TP Silvex	0.01
Radium	5 pCi/L
Gross Alpha	15 pCi/L
Gross Beta	4 millirem/yr
Turbidity	1/TU
Coliform Bacteria	1/100 ml

Note: Turbidity is applicable only to surface water supplies.