

Chapter PSC 135

GAS SAFETY

PSC 135.01	Character of construction, maintenance, and operation	PSC 135.08	Corrosion control
PSC 135.02	Facilities, inspection and repairs	PSC 135.081	Exemption from corrosion control
PSC 135.03	Application of rules	PSC 135.082	Over-pressure protection
PSC 135.04	Interference with public service facilities	PSC 135.09	Report of proposed construction
PSC 135.05	Protection of utility facilities	PSC 135.10	Adoption of code for gas transmission and distribution piping systems
PSC 135.06	Leak survey reports	PSC 135.11	Adoption of federal minimum safety standards
PSC 135.07	Report to the commission		

History: Chapter PSC 135 as it existed on February 29, 1968 was repealed and a new chapter PSC 135 was created effective March 1, 1968.

PSC 135.01 Character of construction, maintenance, and operation. All gas transmission, distribution, and utilization equipment and facilities shall be constructed, installed, operated, and maintained in a reasonably adequate and safe manner and as a minimum more specifically provided for herein.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.02 Facilities, inspection and repairs. All facilities shall be cleaned when necessary and inspected at such intervals as experience has shown to be necessary. Any facilities known to be defective so as to endanger life or property shall be promptly repaired, permanently disconnected, or isolated until repairs can be made. Construction, repairs, additions, and changes to gas transmission and distribution facilities shall be made by qualified persons only.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.03 Application of rules. Every gas utility or operating company as defined in 805.72 (see section PSC 135.10 (3) for the meaning of this type of numbers) that operate gas transmission or distribution facilities in the state shall comply with the rules in this chapter and the application of these rules shall be as provided in 804.6 as revised.

(1) **WAIVING RULES.** The rules may be modified or waived by the public service commission. They may be so modified or waived in particular cases wherever shown to be impracticable for special reasons or where the advantage of uniformity with existing construction is greater than the advantage of construction in compliance with the rules providing the existing construction is reasonably safe or if equivalent or safer construction is secured in other ways.

(2) **TEMPORARY INSTALLATIONS.** It will sometimes be necessary to modify or waive certain of the rules in case of temporary installations or installations which are shortly to be dismantled or reconstructed. Such temporary construction may be used for a reasonable length of time provided it is under competent supervision while it

or adjoining equipment is under pressure or if it is protected by suitable barriers or warning signs when accessible to any person, without fully complying with this code; but all such construction shall be made reasonably safe.

(3) **EMERGENCY.** In case of emergency or pending decision of the public service commission, the person responsible for the installation may decide as to modification or waiver of any rule or order, subject to review by the public service commission.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.04 Interference with public service facilities. (1) No utility or operating company having any work upon, over, along, or under any public street or highway or upon, over, along, or under any private property shall interfere with, destroy, or disturb the facilities of any other public service corporation or railroad encountered in the performance of such work so as to interrupt, impair, or affect the public service for which such facilities may be used, without first reaching an agreement concerning the location and the nature of the proposed work.

(2) A utility or operating company shall exercise care when working in close proximity of existing facilities. When the facilities are underground and are to be exposed or possibly may be exposed, hand-digging shall be employed. In these cases, such support as may be reasonably necessary for protection of the facilities shall be provided in and near the construction area. When backfilling an excavation, such procedures and materials shall be employed to provide reliable support for existing underground facilities in and near the construction area.

(3) A utility or operating company shall, in the absence of working arrangements, give at least 3 days' written notice (not counting Saturdays, Sundays, and legal holidays) to all utilities, operating companies, or railroads and to those who may have facilities in and near the construction area which may be affected by the proposed work. The utility or operating company proposing to work shall obtain from the affected party the location of the existing facilities determined to be affected or to be in and near the construction area.

(4) A utility or operating company upon receiving a notice of proposed construction shall furnish in 3 days detailed information relative to location and type of facilities that are present in the proposed construction area. In those cases where the facilities are underground, they shall be marked physically in the field relative to location.

(5) Nothing in the above shall prevent a utility or operating company from proceeding as quickly as possible with any emergency construction work which might interfere with existing facilities. However, all reasonable precautions shall be taken to avoid or minimize damage or interference to the other facilities and notification shall be given as soon as possible to the utilities or operating company which have facilities in the construction area.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.05 Protection of utility facilities. A public utility or operating company upon receipt of written notice as required by section Register, December, 1970, No. 180

66.047 (2), Wis. Stats., from the property owner or from a contractor of work which may affect its facilities used for serving the public:

(1) Shall investigate and decide what action, if any, must reasonably be taken to protect or alter facilities, in order to protect service to the public and to avoid unnecessary damage, such as identifying in a suitable manner the location of any underground facilities which may be affected by the work.

(2) The utility or operating company shall take such action as is reasonably and legally necessary to protect, remove, alter, or reconstruct its facilities, and shall perform such work with reasonable dispatch taking into account the conditions to be met, provided that nothing in this rule shall be deemed to affect any right which the utility or operating company may have to require advance payment or adequate assurance of payment of the reasonable cost thereof to the utility or operating company by the property owner or contractor.

(3) The utility or operating company may, in order to protect its interests, require that the owner or contractor perform certain work upon that part of the service piping or wiring on or being removed from the property upon which the excavating, building, or wrecking operations are being performed.

(4) This rule is not intended to affect the responsibility of the contractor or owner, or the liability or legal rights of any party.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.06 Leak survey reports. On or before April 15 of each year all gas utilities shall report to the commission a summary of the results of the leak surveys made during the previous calendar years. The report shall contain at least the following information:

(1) The number and type of leak surveys which were made by the utility during the previous calendar year.

(2) The number of leaks, both inside and outside, which were found, by either a survey or complaint, in the utility's service area during the previous calendar year.

(3) The number of leaks found during the previous calendar year which were repaired the same year.

(4) The number of leaks found in earlier years which were repaired during the year for which this report is being filed.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.07 Report to the commission. (1) Every utility or operating company transmitting or distributing gas by any pipeline or distribution main intended to be subjected to pressures in excess of 100 p.s.i.g. shall:

(a) Within 180 days from the date of publication of the rules, file with the public service commission a statement verified by an officer setting forth a description of the pipeline and distribution facilities in operation as of the date of publication. Such description shall be based upon the records of the utility or operating company including records of tests, specifications, identification of national codes if followed, or other available data. This verified statement shall include a statement of the operation and maintenance practices that were followed during the life of the existing facilities and further whether or not in the officer's opinion said facilities are suitable for continued operation.

(b) In each instance where any utility or operating company required by section PSC 135.07 (1) (a) to file a verified statement claims that it is not possible or practicable to obtain the necessary data to prepare the same, a verified statement setting forth such claim shall nevertheless be filed within the period required by section PSC 135.07 (1) (a), and the basis for such claim shall be set forth in such statement.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.08 Corrosion control. Corrosion control is required by 841.173 and 849.21 (e) and shall apply to all facilities. Within 180 days of publication of these rules each utility or operating company shall file with the commission its plans for corrosion protection of the existing facilities.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.081 Exemption from corrosion control. Whenever any operating utility or operating company finds upon investigation that corrosion protection is not needed as required by 841.173 or 849.21 (e), such utility or operating company shall submit to the public service commission a request for exemption setting forth good and sufficient reasons why such protection is not required, such request to include the results of soil tests and other supporting data.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.082 Over-pressure protection. Over-pressure protection is required by 845.52 and 845.53 and shall apply to all installations. All present installations where such protection is not provided shall be changed so that 100% compliance will be attained by the end of the first testing cycle as provided in section PSC 134.30.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.09 Report of proposed construction. Prior to construction or reconstruction of any gas transmission line exceeding one mile in length or any gas main exceeding 1,000 feet in length intended to be subjected to pressures in excess of 100 p.s.i.g., a report shall be filed with the commission setting forth the specifications for such pipeline or main. This report shall contain at least the following information:

(1) The necessary data to calculate the design pressure as set forth in 841.1.

(2) The design pressure as determined by the utility or operating company.

(3) The expected pressure which the pipeline or main will be operated.

(4) The pressure to which the pipeline or main will be tested.

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68.

PSC 135.10 Adoption of code for gas transmission and distribution piping systems. (1) The USA Standard Code for Pressure Piping—Gas Transmission and Distribution Piping Systems, USAS B31.8—1967, general provisions and definitions, chapters I through VII, inclusive, and index, subject to omissions, changes, and additions shown in subsection (3) of this section, is hereby adopted as a code for the design and construction of gas public utility systems in the state of Wisconsin. The USA Standard Code for Pressure Piping—Gas Trans-

Register, February, 1968, No. 146

mission and Distribution Piping Systems is periodically revised by its sponsors, but these revisions will have no effect in the state of Wisconsin until such time as this subsection is correspondingly revised to reflect those changes.

(2) Pursuant to section 227.025, Wis. Stats., the attorney general and the revisor of statutes have consented to the incorporation by reference in this section, of the standards, with certain exceptions shown in subsection (3), contained in USA Standard Code for Pressure Piping—Gas Transmission and Distribution Piping Systems, USAS B31.8—1967 which can be obtained through The American Society of Mechanical Engineers, United Engineering Center, 345 East 47th Street, New York, New York 10017. Copies of the aforementioned standard code are on file in the offices of the public service commission, the secretary of state, and the revisor of statutes.

(3) The following are changes or additions to the USAS B31.8—1967 Code. (The numbering system and sequence used in said USAS B31.8—1967 code are here used for convenience and clarity. The word "Change" following the number means that the corresponding wording of the USAS B31.8—1967 Code has been changed and that the new wording is substituted at the appropriate location. The word "Addition" following the number means that a new requirement is incorporated in the USAS B31.8—1967 code and that the new requirement is inserted at the appropriate location.)

**WISCONSIN CODE CHANGES AND ADDITIONS
TO
USA STANDARD CODE FOR PRESSURE PIPING
GAS TRANSMISSION AND DISTRIBUTION PIPING
SYSTEMS, USAS B31.8—1967**

804.3 (c) (Change) Piping beyond the outlet of the customer's meter set assembly.

804.3 (d) (Change) Piping in oil refineries or natural gasoline extraction plants, gas treating plant piping other than main gas stream piping in dehydration, and all other processing plants installed as part of a gas transmission system, gas manufacturing plants, industrial plants, or mines.

804.3 (i) (Change) Liquid petroleum transportation piping systems.

804.6 (Change) Unless otherwise specifically provided for in a rule or special order, it is not intended that this code be applied retroactively to existing installations insofar as design, fabrication, installation, and testing at the time of construction are concerned. Further, it is not intended that this code be applied retroactively to established operating pressures of existing installations except as provided for in chapter V. It is intended, however, that the provisions of this code shall be applicable to operating and maintenance procedures of existing installations, and when existing installations are updated.

As revisions of this code are published from time to time, they may contain new provisions with respect to the operation, maintenance, uprating, and confirmation of established operating pressures which may require changes in established procedures or actual physical alteration of facilities. When this becomes necessary, it is anticipated that

such procedural changes or physical alterations will be introduced or made in a systematic, methodical, and orderly manner. It is recognized, that in some cases, particularly when substantial construction programs may be involved or when service to customers may be directly affected, and when an immediate hazard does not exist, such changes or alterations may have to be introduced or made gradually over a period of years in order to prevent undue hardship or loss of service.

810.2 (Addition) Cast iron pipe shall not be used as a permanent part of any piping system constructed under this code except where it is used as a temporary installation or replacement of short sections of existing cast iron pipe because of maintenance or relocation. In those cases where cast iron pipe is used it shall be designed, installed, and operated in accordance with the applicable sections of this code.

811.221 (Change) By petitioning the public service commission for approval. If possible, the material shall be identified with a comparable material, and it should be stated that the material will comply with that specification except as noted. Complete information as to chemical composition and physical properties shall be supplied to the public service commission, and its approval shall be obtained before this material may be used.

814 (Change) Materials for use in cold climates. Some of the materials conforming to specifications approved for use under this code may not have properties suitable for the lower portion of the temperature band covered by this code. Engineers are cautioned to give attention to the low-temperature properties of the materials used for facilities to be exposed to unusually low ground temperatures or low atmospheric temperatures. All pipe intended for installation in accordance with this code shall meet specifications set forth in this code. When substantial quantities of pipe are acquired, certified reports of chemical composition and physical properties shall be obtained; when the quantity of pipe involved is so limited that this requirement would be impractical, a certified statement shall be obtained setting forth the specification under which the pipe was manufactured. Pipe manufactured from steel made by the Bessemer process shall not be used. The chemical composition of the various elements shall not exceed the maximums set forth in the specification.

Within one year of the date of publication of this code, the operating companies shall submit a report to the public service commission of Wisconsin giving the low-temperature fracture-toughness standard, the method of testing for such toughness, and the results of applying this method to available pipe.

Within 6 months of the publication of this code, the operating companies shall submit data on the low-temperature fracture-toughness of large diameter pipe.

821.3 (Change) Each utility shall establish and qualify a welding procedure for sound and ductile welds. In applying these standards, the welder is required to qualify under the procedure employed. These standards establish the groupings of materials that can be welded under a procedure which has been qualified with any one of the materials included in the group. The changes in material, filler metal,

process, or procedure that require requalification of either welding procedure or welder are set out in 824.21 (a), (b), and (c).

826.1 (Change) Carbon steels having a carbon content in excess of 0.32% (ladle analysis) or a carbon equivalent ($C + \frac{1}{4} Mn.$) in excess of 0.65% (ladle analysis) shall be preheated as prescribed in ASME Boiler and Pressure Vessel Code, section VIII. Preheating also is required for steels having lower carbon or carbon equivalent, when conditions exist that either limit the welding technique that can be used, or that tend to adversely affect the quality of the weld.

827.1 (Change) Carbon steels having a carbon content in excess of 0.32% (ladle analysis) or a carbon equivalent ($C + \frac{1}{4} Mn.$) in excess of 0.65% (ladle analysis) shall be stress relieved as prescribed in ASME Boiler and Pressure Vessel Code, section VIII. Stress-relieving also is required for steels having lower carbon or carbon equivalent when adverse conditions exist which too rapidly cool the weld.

828.1 (Change) Inspection of welds on piping systems intended to operate at both less than 100 p.s.i. and less than 20% of the specified minimum yield strength. The quality of welding shall be checked visually or subjected to a non-destructive test on at least a 30% sampling basis, and if there is any reason to believe that the weld is defective, it shall be removed from the line and tested in accordance with the specification or may be subjected to a non-destructive test as outlined in 828.2.

828.2 (Change) Inspection and tests of welds on piping systems intended to operate at both 100 p.s.i. or more and 20% or more of the specified minimum yield strength. (a) The quality of welding shall be checked by non-destructive inspection. Non-destructive inspection may consist of radiographic examination, magnetic particle testing, or other acceptable methods. The trepanning method of non-destructive testing is prohibited.

(b) The following minimum number of field butt welds shall be selected by the operating company from each day's construction for inspection. The welds selected for inspection may include welds selected on a random basis and/or welds in which defects may be indicated. Each weld so selected shall be examined over its entire circumference, or an equivalent length of welding if portions of the circumference are examined. The same minimum percentages shall be examined for double ending at railhead or yard:

- 10% of welds in class 1 locations
- 15% of welds in class 2 locations
- 40% of welds in class 3 locations
- 75% of welds in class 4 locations
- 100% of welds at major or navigable river crossings, major highway crossings, railroad crossings, and all tie-in sections if practicable, but in no case less than 90%. In addition, all welds within 500 feet of buildings intended for human occupancy shall be examined.

If one weld in any random sample is found to be unacceptable as determined by 829, then the minimum percentage of welds selected for examination will be that of the next higher class location. If a

second weld is found to be unacceptable or if 2 or more welds are found to be unacceptable in the original random sample, then 100% of the welds shall be inspected if practicable, but in no case less than 90% of the welds in that day's construction.

(c) When radiographic examination is employed, a procedure meeting the requirements of API Standard 1104 (Standard for Welding of Pipelines and Related Facilities), shall be followed.

(d) When pipe has a nominal diameter of less than 6 inches or when the construction project involves such a limited number of welds that non-destructive inspection would be impractical and the pipe is intended to operate at 40% or less of the specified minimum yield strength, then 828.2 (a) and (b) above are not mandatory, provided the welding is inspected in accordance with 828.1 by a qualified welding inspector.

(e) In addition to non-destructive inspection requirements outlined above, there shall be continual control of the quality of welding by qualified personnel.

841.016 (Change) When classifying locations for the purposes of determining the type of pipeline construction and testing that should be prescribed, due consideration shall be given to the possibility of future development of the area. If, at the time of planning a new pipeline this future development appears likely to be sufficient to change the class location, this shall be taken into consideration in the design and testing of the proposed pipeline.

841.15 (Change) Protection of pipelines and mains from hazards. When pipelines and mains must be installed where they will be subjected to natural hazards, such as washouts, floods, unstable soil, land slides, or other conditions which may cause serious movement of, or abnormal loads on, the pipeline, reasonable precaution shall be taken to protect the pipeline, such as increasing the wall thickness, constructing revetments, erosion prevention, installing anchors, etc. Where pipelines and mains are exposed, such as at spans, trestles, and bridge crossings, the pipelines and mains shall be reasonably protected by distance or barricades from accidental damage by vehicular traffic or other causes. Where pipelines and mains are located outside urban areas, their location shall be marked (recognizable to the public) at each fence line, road crossing, railroad crossing, river, lake, stream, or drainage ditch crossing and wherever it is considered necessary to identify the location of a pipeline to reduce the possibility of damage or interference.

841.161 (Change) Cover requirements for pipelines and mains. (a) All buried pipelines, mains, and casings when used, shall be installed with a minimum cover of 24 inches unless otherwise provided herein.

(b) Buried pipelines and mains installed in areas where farming or other operations might result in deep plowing, or in thoroughfares or other locations where grading is done, or where the area is subject to erosion, shall be provided with a cover of 30 inches or more.

(c) Casing requirements of highway authorities shall be followed; however, construction type shall not be any less than provided by this code.

(d) Where it is impractical to comply with the provisions of 841.161

(a) and it is necessary to prevent damage from external loads, the pipe shall be cased or bridged.

841.163 (Change) Clearance between pipelines or mains and other underground structures. When conditions permit, there shall be at least 6 inches' separation of well-tamped earth between any gas main piping and any other parallel underground structure not used in conjunction with the pipeline or main. They may be as close as 2 inches where they cross provided suitable precautions are taken to protect the pipe, such as installation of insulating material, installation of casing, etc. If the structure is a public building where people assemble or in areas such as playground, assembly ground, or park, wherever possible the clearance shall be at least 100 feet if the main is operated at more than 100 p.s.i. but less than 500 p.s.i. and shall be at least 150 feet if operated at 500 p.s.i. or more. If these clearances cannot be maintained, then the next higher type of construction shall be used except such construction may be pressure-tested the same as the remainder of the line. No gas main or pipeline shall be installed under buildings.

841.173 (Change) Corrosion control. (a) Every operating company shall make a proper investigation to determine whether new and existing facilities require corrosion protection and if not exempted by the commission under section PSC 135.081, shall employ recognized methods of corrosion control. In new construction, corrosion control shall consist of coating with protective material, application of cathodic protection, and the electrical bonding or insulation by sections. Corrosion control of existing facilities shall at least consist of cathodic protection and the electrical bonding or insulation by sections.

(b) Whenever pipe coating is applied, the following additional precautions shall be taken:

(1) Tests and inspections shall be made before backfill to insure that the coating is adequate and satisfactory.

(2) During backfill, precautions shall be taken to insure that the coating is not damaged.

(3) On completion of backfill, proper tests shall be made to ascertain that the coating is adequate and satisfactory.

(c) In addition to the foregoing, every operating company shall make periodic inspections and tests of all facilities or at reasonable intervals to determine whether or not the facilities are adequately protected against corrosion.

(d) Operating companies shall promote cooperative efforts on the part of all agencies having underground facilities toward the reduction of corrosion.

841.222 (Change) The installation inspection provisions for pipelines and other facilities to operate at hoop stresses of 20% or more of the specified minimum yield strength shall be adequate to make possible the following inspections at sufficiently frequent intervals and to do other things that will assure good quality of workmanship.

841.231 (Change) All smooth bends shall be free from buckling, cracks, or other evidence of mechanical damage. Smooth bends on pipe 4 inches in size and smaller shall have a difference between the maximum and minimum diameter of not more than 12.5% of the

nominal diameter. All other smooth bends shall have a difference between the maximum and minimum diameter of not more than 2.5%. In addition, for smooth field bends on sizes 12 inches and larger, the longitudinal axis of the pipe shall not be deflected more than 1½ degrees in any length along the pipe axis equal to the diameter of the pipe.

841.241 (a) (Change) The field inspection provided on each job shall be suitable to reduce to an acceptable minimum the chances that gouged or grooved pipe will get into the finished pipeline or main. Inspection for this purpose just ahead of the coating operation and during the lowering in and backfill operation is required.

841.246 (Addition) Pipe surface and installation provisions for pipelines and mains to operate at hoop stresses of less than 20% of the specified minimum yield strength. Due primarily to climate conditions, gouges, grooves, notches, and dents have been found to be an important cause of steel pipe failures and an attempt shall be made to prevent or eliminate harmful defects of this nature. 841.222 and 841.24 pertain to pipelines and mains intended to operate at hoop stresses of 20% or more of the specified minimum yield strength. However, applicable portions of these paragraphs should also be applied to facilities intended to operate below this hoop stress level. Particular attention should be given to 841.222, 841.222 (a) and (b), 841.241, 841.242, and 841.243.

841.271 (Change) Handling, hauling, and stringing. Care shall be taken in the selection of the handling equipment and in handling, hauling, unloading, and placing the pipe so as not to damage the pipe.

841.272 (Change) Installation of pipe in the ditch. On pipes operating at stresses of 20% or more of the specified minimum yield strength, it is important that stresses induced into the pipe by construction be minimized. This includes grading the ditch so that the pipe has a firm, substantially continuous bearing on the bottom of the ditch. The pipe shall fit the ditch without the use of external force to hold it in place until the backfill is completed. When long sections of pipe that have been welded alongside the ditch are lowered in, care shall be exercised so as not to jerk the pipe or impose any strains that may kink or put a permanent bend in the pipe. Slack loops are not prohibited by this paragraph where laying conditions render their use advisable.

841.283 (Change) No welding or acetylene cutting shall be done on a pipeline, main, or auxiliary apparatus that contains air if it is connected to a source of gas, unless a suitable means has been provided to prevent the leakage of gas into the pipeline or mains.

841.284 (Change) In situations where welding or cutting must be done on facilities which are filled with air and connected to a source of gas and the precautions recommended above cannot be taken, one or more of the precautions, depending upon the circumstances at the job are required.

841.285 (e) (Addition) No pipeline, main, or service shall be purged into any building or confined space.

841.286 (d) (Change) Provide fire extinguishers of appropriate size and type in accordance with the department of industry, labor and human relations' requirements.

841.31 (Change) General provisions. All pipelines, mains, and service lines shall be tested after construction except as follows:

TIE-INS. Because it is sometimes necessary to divide a pipeline or main into sections and install test heads, connecting pipe, and other

necessary appurtenances for testing, it is not required that the tie-in sections of pipe be tested. However, welds on tie-in sections of pipe shall be inspected and tested as set forth in 828.

841.412 (e) (Addition) Test pressures shall be maintained until the pressure has stabilized in all portions of the test sections. In no event shall the duration of the test be less than 24 hours following such stabilization except that, in the case of a short length of pipeline, main, or pipe which has not been backfilled prior to the test where, throughout its entire length, its entire circumference can be readily examined visually for the detection of leakage, the duration of the test shall not be less than 4 hours following such stabilization.

841.412 (f) (Addition) Where water is utilized as the test medium, proper authorization shall be obtained from the department of natural resources and adequate provisions shall be made for disposal of the water and steps shall be taken to guard against contamination of local water supply.

841.412 (g) (Addition) Except in freezing weather or when water is not available, pipelines or mains larger than 6 inches in diameter, installed in class locations 1, 2, or 3, shall be hydrostatically tested in place to at least 90% of the specified minimum yield strength.

841.42 (Change) Test required to prove strength for pipelines and mains to operate at less than 30% of the specified minimum yield strength of the pipe, but in excess of 100 p.s.i. Steel piping that is to be operated at stresses less than 30% of the specified minimum yield strength shall be tested in accordance with Table 841.412 (d), except that gas or air may be used as the test medium with the maximum limits set in Table 841.421.

**TABLE 841.421
MAXIMUM HOOP STRESS PERMISSIBLE DURING TEST**

Class Location Test Medium	Per cent of Specified Minimum Yield Strength			
	1	2	3	4
Air	75	75	50	40
Gas	30	30	30	30

841.431 (Change) Each pipeline and main shall be tested after construction and before being placed in operation to demonstrate that it does not leak. If the test indicates that a leak exists, the leak or leaks shall be located and eliminated.

842.15 (a) (Change) Caulked bell and spigot joints. Dimensions for caulked bell and spigot joints shall conform to USA standards A 21.3, A 21.7, A 21.9, and A 21.10. This type of joint shall not be used unless reinforced with mechanical clamps.

842.162 (Change) Underground cast iron pipe shall be installed with the cover requirements of 841.161 (a) and (b) unless prevented by other underground structures.

842.167 (Addition) Cast iron shall not be installed under buildings.

842.215 (b) (Change) Other joints. Ductile iron pipe may be furnished with other types of joints provided they are properly qualified and meet the appropriate provisions of this code. Such joints shall be assembled in accordance with applicable standards or in accordance with the manufacturers' written recommendations. However, no caulked bell and spigot joints shall be used unless reinforced with mechanical clamps.

842.222 (Change) Underground ductile iron pipe shall be installed with the cover requirements of 841.161 (a) and (b) unless prevented by other underground structures. Where sufficient cover cannot be provided to protect the pipe from external loads or damage and the pipe is not designed to withstand such external loads, the pipe shall be cased or bridged to protect the pipe. Ductile iron pipe shall not be installed under buildings.

842.37 (Change) Cover and casing requirements. The requirements for plastic piping shall conform to the applicable provisions of 841.161 and 841.162.

842.423 (Change) Skillful application of qualified techniques and use of proper materials and equipment in good condition are required to achieve sound joints in plastic piping by the solvent cement, adhesive, or heat-fusion methods. The quality of the joints shall be checked visually on at least a 30% sampling basis and if there is any reason to believe the joint is defective, it shall be removed and replaced.

842.43 (d) (Addition) A plastic pipe main shall not be installed under buildings.

842.431 (g) (Change) An electrically conductive wire shall be installed with the pipe to facilitate locating it with an electronic pipe locator. Other suitable material or means for accomplishing this purpose may be employed.

842.616 (Addition) Copper pipe or tubing shall be installed in accordance with applicable provisions for the installation of plastic pipe and tubing and shall be tested after construction in accordance with the provisions of 841.44.

843.12 (Change) Building construction. All compressor station buildings shall be constructed of non-combustible materials as defined by the Wisconsin state building code administered by the department of industry, labor and human relations.

843.13 (Change) Exits. Exits shall be provided in compliance with the requirements of the Wisconsin state building code administered by the department of industry, labor and human relations. Ladders shall not be used for exits.

843.2 (Change) Electrical facilities. All electrical equipment and wiring installed in gas transmission and distribution compressor stations shall conform to the requirements of the Wisconsin state electrical code.

843.42 (Change) Fire protection. Fire-protection facilities shall be provided as specifically directed by the department of industry, labor and human relations and the local fire department. The operation of fire-protection facilities, such as pumps, shall not be affected by an emergency shutdown.

843.472 (Change) Building ventilation. Ventilation shall be sufficient so that employes are not endangered under normal operating conditions (or such abnormal conditions as a blown gasket, packing gland, etc.) by accumulations of hazardous concentrations of flammable or noxious vapors or gases in rooms, sumps, attics, pits, or similarly enclosed places, or in other portions thereof. There shall be compliance with the department of industry, labor and human relations' heating, ventilation, and air conditioning code.

843.57 (Change) Hydraulic piping. All hydraulic power piping within gas compressing stations shall be constructed in accordance with USAS code for pressure piping—petroleum refinery piping, USAS B31.3.

845.23 (c) (Change) In no case shall the maximum allowable operating pressure of a pipeline be raised to a value higher than would be permitted by this code for a new line constructed of the same materials and in the same locations. However, this does not preclude the continued operation of pipelines or mains at established maximum allowable operating pressures as provided in 850.5.

The rate of pressure increase to the new maximum allowable operating pressure shall be gradual so as to allow sufficient time for periodic observation of the pipeline.

845.32 (Change) In addition to the pressure-regulating devices prescribed in 845.31, a suitable method shall be provided to prevent accidental overpressuring of a high-pressure distribution system and prevent the pressure from exceeding the maximum allowable operating pressure plus 10%.

Suitable types of protective devices to prevent overpressuring of high-pressure distribution systems include:

845.33 (b) (Change) Sixty p.s.i.g. in individual distribution systems or portions thereof. The intercity or supply mains for these distribution systems may be operated at higher pressures provided by this code if the number of services supplied from these mains are limited and these mains are not an integral part of the distribution system. The pressure and the services supplied from these higher pressure intercity and supply mains shall be limited to 60 p.s.i.g. unless the service lines are equipped with series regulators or other pressure-limiting devices as prescribed in 845.53.

845.33 (c) (Change) Twelve inches of water column in cast iron systems having unreinforced bell and spigot joints as prescribed in 842.15 (a) except as provided by section PSC 135.03 and 804.06. However, the maximum allowable operating pressure under any circumstances shall not exceed 15 p.s.i.g.

845.33 (e) (Change) Low pressure as defined by 805.65 unless the distribution system is equipped with service regulators meeting the

requirements of 845.51 and have an over-pressure protective device as defined in 845.52.

In some cases the operating company will consider the maximum pressure to which a system should be subjected is less than the pressure obtained by applying the applicable limits in 845.33 (a), (b), (c), (d) or (e). Systems that are known to be corroded and that have been operated for years at lower pressures than these limits fall into this category. In such cases, the operating company shall decide the maximum pressure it considers safe, and shall install over-pressure protection devices to prevent accidentally exceeding this maximum pressure if there is a reasonable possibility that the pressure will be exceeded.

845.34 (a) (Change) Before increasing the maximum allowable operating pressure of a high-pressure distribution system, that has been operating at less than the applicable maximum pressure stated in 845.33, to a new maximum allowable operating pressure equal to or less than the maximum applicable pressure in 845.33, the following factors shall be taken into consideration:

845.34 (b) (Change) Before increasing the pressure, the following steps shall be taken:

845.34 (b) (1) (Change) Make a leak survey and repair leaks found.

845.42 (Change) In addition to the pressure-regulating device prescribed in 845.41, a suitable device shall be provided to prevent accidental overpressuring and to prevent the system from developing pressures in excess of $1\frac{1}{2}$ p.s.i.g. or would cause the unsafe operation of any connected or properly adjusted gas-burning equipment. Suitable types of protective devices to prevent overpressuring of low-pressure distribution systems include:

845.43 (b) (Change) A pressure in excess of that provided by section PSC 134.23 (1)

845.44 (a) (Change) Before converting a low-pressure distribution system to a high-pressure system, the following factors shall be taken into consideration:

845.44 (b) (Change) Before increasing the pressure, the following steps (not necessarily in sequence shown) shall be taken:

845.44 (b) (1) (Change) Make a leakage survey and repair leaks found.

845.44 (c) (Change) The pressure in the system being converted shall be increased by steps, with a period to check the effect of the previous increase before making the next increase. The desirable magnitude of each increase and the length of the checked period may vary depending upon conditions. The objective of this procedure is to afford an opportunity to discover, before excessive pressures are reached, any unknown open and unregulated connections to adjacent low-pressure systems or to individual customers.

845.5 (Change) Control and limiting of the pressure of gas delivered

to domestic, small commercial, and small industrial customers from high-pressure distribution systems.

Note: When the pressure of the gas and the demand by the customer are greater than that which is applicable under the provisions of 845.5, the requirements for control and limiting of the pressure of gas delivered are included in 845.1. In those cases where 845.5 is applicable, the requirements for control and limiting of pressure of gas delivered are included in section PSC 134.23.

845.51 (Change) If the maximum actual operating pressure of the distribution system is greater than low pressure as defined by 805.65 but equal to or less than 60 p.s.i.g., a service regulator having the characteristics listed below is required:

845.51 (e) (Change) The regulator must be of a type that is capable under normal operating conditions of regulating the downstream pressure within the limits of section PSC 134.23 and of limiting the build-up of pressure under no-flow conditions to 50% or less of the discharge pressure maintained under flow conditions.

845.52 (Change) If the maximum actual operating pressure of the distribution system is greater than low pressure as defined by 805.65 and is equal to or less than 60 p.s.i.g., a suitable protective device shall be installed to prevent unsafe overpressuring of the customers' appliances should the service regulator fail. Some of the suitable types of protective devices to prevent overpressuring of customers' appliances are:

- (a) A monitoring regulator.
- (b) A relief valve.
- (c) An automatic shut-off device.

These devices may be installed as an integral part of the service regulator or as a separate unit.

845.53 (Change) If the maximum actual operating pressure of the distribution main system, intercity main, or supply main (see 845.33 (b)) exceeds 60 p.s.i.g., suitable methods shall be used to regulate and limit, to the maximum safe value, the pressure of gas delivered to the customer, such as the following:

845.62 (Change) Breather vents and discharge stacks shall be provided on all pressure-relief devices located inside buildings, pits, and confined spaces. The discharge stacks, vents, or outlet ports of all pressure-relief devices shall terminate outside buildings, pits, and confined spaces in rain-proof, insect-proof fittings where gas can be discharged into the atmosphere without undue hazard. Consideration should be given to the specific gravity of the gas being discharged to the atmosphere to prevent accumulation of gases after discharge. Additional consideration should be given to all exposures in the immediate vicinity including windows or locations where gas can enter confined areas.

845.67 (Addition) Breather vents shall be provided on all service regulators and such vents shall terminate outside buildings, pits, and confined spaces in rain-proof, insect-proof fittings.

846.22 (a) (Change) A valve shall be installed on the inlet piping of each regulator station controlling the flow or pressure of gas in

a distribution system. These valves shall be in accessible locations not closer than 25 feet and preferably not more than 1,500 feet distant from each regulator station. Records shall be maintained to show specific valve locations and such records shall be made continuously accessible for use under emergency conditions. Such valves shall be inspected at least once each year and maintained in operating condition. It is intended that the distance between the valve and the regulator or regulators shall be sufficient to permit the operation of the valve during an emergency, such as a large gas leak or a fire in the station.

847.4 (c) (Change) Electrical equipment in vaults shall conform to the applicable requirements of the Wisconsin state electrical code.

849.11 (a) (Change) Service lines shall be installed at a depth which will protect them from excessive external loadings and local activities such as gardening. Whenever conditions permit, service pipes shall be laid with a cover of not less than 18 inches above the top of pipe. Where this cannot be done to existing structures, etc., less cover is permitted provided, however, that where such service lines are subject to excessive superimposed loads, those portions of the service line shall be cased or bridged to avoid harmful additional loads on the pipe or strengthened to resist them.

849.11 (d) (Addition) It is recommended that service to one customer and/or one building be supplied through one service and one shut-off valve.

849.14 (Change) Location of service line connections to main piping. Services shall be connected to either the top or the side of the main. The connection to the top of the main is preferred in order to minimize the possibility of dust and moisture being carried from the main into the service.

849.152 (a) (Change) Service lines to operate at a pressure between 0 and 40 p.s.i.g. shall be given a stand-up air or gas pressure test at not less than 50 p.s.i.g. for at least 5 minutes before being placed in service. Maximum test pressure for plastic service lines, however, shall not exceed 3 times the design pressure.

849.152 (f) (Addition) All service lines shall be tested after construction and before being placed in operation to determine that they do not leak.

849.21 (b) (Change) Steel service pipe shall be designed in accordance with the requirements of 841.1 through 841.14. Where pressure is less than 100 p.s.i.g., the steel service pipe shall be designed for at least 100 p.s.i.g. pressure.

849.21 (e) (Change) Corrosion protection. Any steel pipe used in service lines shall be protected from external corrosion as provided in 841.173 (a).

849.21 (f) (Change) All services shall be electrically insulated near or within the building so as to eliminate possible galvanic corrosion. This is especially important in areas where stray current electrolysis

is prevalent or where copper or lead water services are used. The services shall be protected from corrosion as provided in 841.173.

850.1 (Change) Because of many variables, it is not possible to prescribe in a code a set of operating and maintenance procedures that will be adequate from the standpoint of public safety in all cases without being burdensome and impractical.

850.2 (Change) It is possible, however, for each operating company to develop operating and maintenance procedures based on experience, knowledge of its facilities, and conditions under which they are operated, which will be entirely adequate from the standpoint of public safety.

850.3 (Change) Basic requirement. Each operating company having gas transmission or distribution facilities within the scope of this code shall:

(a) Have a plan covering operating and maintenance procedures in accordance with the purpose of this code.

(b) Operate and maintain its facilities in conformance with this plan.

(c) Keep records necessary to administer the plan properly.

(d) Modify the plan from time to time as experience with it dictates and as exposure of the public to the facilities and changes in operating conditions require.

(e) Operate its existing unreinforced bell and spigot-jointed cast iron pipe distribution systems at low pressure unless it can be proved to the commission that they can be satisfactorily operated at a higher pressure. However, the maximum allowable operating pressure for such system under any circumstances shall not exceed 15 p.s.i.g.

850.4 (Change) Essential features of the plan. The plan prescribed in 850.3 (a) above should include:

(a) Detailed plans and instructions to employes covering operating and maintenance procedures for gas facilities during normal operations and repairs and during emergency.

(b) Items recommended for inclusion in the plan for specific classes of facilities are given in 851 to 858, inclusive.

(c) Particular attention should be given to those portions of the facilities presenting the greatest hazard to the public in the event of an emergency or because of construction of extraordinary maintenance requirements.

(d) Set up an emergency plan to be implemented in the event of facility failures or other emergencies.

(1) Assure that appropriate maintenance and operating employes are acquainted with the operation of the applicable portions of the plan.

(2) Establish liaison with respect to this emergency plan with appropriate public officials, such as police departments, fire departments, etc.

850.5 (Addition) Changes in class location.

850.51 (Addition) Where observed increases in population density in the vicinity of existing steel pipelines or mains operating at hoop stress in excess of 40% of specified minimum yield strength indicate a change in class location since the original installation, or where

detailed population index surveys or other studies indicate that the hoop stress corresponding to the established maximum allowable operating pressure for a section of existing pipeline or main is not commensurate with the existing class location, a study shall be made to determine the following:

(a) The existing class location for the section of pipeline or main involved.

(b) The design, construction, and testing procedures followed in the original construction and a comparison of such procedures with the applicable provisions of this code.

(c) The physical condition of the pipeline or main to the extent that this can be ascertained from available records.

(d) Operating and maintenance history of the pipeline or main.

(e) The maximum actual operating pressure and the corresponding operating hoop stress taking pressure gradient into account in the section of the pipeline or main directly affected by the class location change.

(f) The actual area affected by the observed population density increase and physical barriers or other factors which may limit the further expansion of the more densely populated area.

850.52 (Addition) If the study described in 850.51 indicates that the hoop stress corresponding to the established maximum allowable operating pressure of a section of pipeline or main is not commensurate with the existing class locations 2, 3, or 4 and such section is in satisfactory physical condition, the maximum allowable operating pressure of that section shall be confirmed or revised as follows:

(a) If the section involved has been previously tested in place to at least 90% of its specified minimum yield strength for a period of not less than 8 hours, the maximum allowable operating pressure shall be confirmed or reduced so that the corresponding hoop stress will not exceed 72% of specified minimum yield strength of the pipe in class 2 locations, 60% of the specified minimum yield strength of the pipe in class 3 locations, or 50% of the specified minimum yield strength in class 4 locations.

(b) If the section involved has not been previously tested in place as described in 850.52 (a) above, the maximum allowable operating pressure shall be reduced so that the corresponding hoop stress will be equal to or less than that permitted in this code for new pipelines or mains in the existing class location.

(c) If the provisions of 850.52 and its parts (a) or (b) above are not used to qualify the section involved for operation, then such section of pipeline or main shall be hydrostatically tested for a period of not less than 8 hours. The maximum allowable operating pressure shall then be established so as to be equal to or less than shown in Table 850.521.

The maximum allowable operating pressure confirmed or revised in accordance with 850.52 shall not exceed the maximum allowable operating pressure established under this code, or previously established under applicable editions of the B31 code, prior to the confirmation or revision, and the corresponding hoop stress shall not exceed 72% of the specified minimum yield strength in class 2 locations, 60% of the specified minimum yield strength of the pipe in class 3 locations, or 50% of the specified minimum yield strength of the pipe in class 4

locations. No confirmation or revision of the maximum allowable operating pressure of a section of pipeline or main in accordance with 850.52 shall preclude the application of 845.23.

TABLE 850.521
MAXIMUM ALLOWABLE OPERATING PRESSURES
AFTER REQUALIFICATION TEST

Existing Class Location	Maximum Allowable Operating Pressure After Test
2	<u>Test Pressure</u> 1.25
3	<u>Test Pressure</u> 1.50
4	<u>Test Pressure</u> 1.80

850.53 (Addition) Where the maximum allowable operating pressure of a section of pipeline or main is revised in accordance with 850.52 and becomes less than the maximum allowable working pressure of the pipeline or main of which it is a part, a suitable pressure-relieving or pressure-limiting device shall be installed in accordance with provisions of 845.1, 845.2, and 845.21.

850.6 (Addition) Continuing surveillance of pipeline and distribution systems. As a means of maintaining the integrity of a pipeline or distribution system, each operating company shall have a procedure for continuing surveillance of its facilities. A study shall be initiated and appropriate action taken when unusual operating and maintenance conditions occur, such as failures, leakage history, drop in flow efficiency due to internal corrosion, or substantial changes in cathodic protection requirements.

If such studies indicate that the facility is not in satisfactory condition but an imminent hazard does not exist requiring immediate action, a planned program to recondition or phase out such facility shall be initiated. If such facility cannot be reconditioned or phased out, the maximum allowable operating pressure shall be reduced commensurate with the requirements described in 845.22 (c) of this code.

850.7 (Addition) Pipeline and distribution failure investigation. Each operating company shall establish procedures to analyze all failures and accidents for the purpose of determining the cause and to minimize the possibility of recurrence. This plan shall include a procedure to select samples of the failed facility or equipment for laboratory examination.

850.8 (Addition) Repair procedures for steel pipelines or mains operating at or above 40% of the specified minimum yield strength. For pipelines operating at or above 40% of the specified minimum yield strength of the pipe, if inspections at any time reveal an injurious defect, gouge, groove, dent, or leak, immediate temporary measures shall be employed to protect the property and the public, if it is not feasible to make a permanent repair at the time of discovery. As soon as feasible, permanent repairs shall be made as described herein. The use of a welded patch as repair method is prohibited except as provided in 850.83 (d).

850.81 (Addition) Permanent field repairs of gouges, grooves, and dents. (a) Injurious gouges, grooves, and dents shall be removed or reinforced.

(b) Gouges and grooves of lesser depth than 10% of the nominal wall thickness of the pipe may be removed by grinding out to a smooth contour provided the grinding does not reduce the remaining wall thickness to less than the minimum prescribed by this code for the conditions of use.

(c) If feasible, gouges, grooves, and dents shall be removed by taking the pipeline out of service and cutting out a cylindrical piece of pipe and replacing same with pipe of similar or greater wall thickness and grade.

(d) If not feasible to take the pipe out of service or operate at a reduced pressure, a full-encirclement welded split-sleeve shall be applied over injurious gouges, grooves, and dents.

(e) All repairs performed under 850.81 (c) and (d) shall pass a non-destructive inspection and tests as provided in 850.91 and 850.92.

(f) If the pipe is not taken out of service, the operating pressure of same shall be reduced to a level which will provide safety during the repair operations.

850.82 (Addition) Permanent field repair of welds having injurious defects. (a) All welds found during maintenance inspection to have injurious defects shall be repaired in accordance with requirements of 829.9 provided the pipe can be taken out of service. Repairs on welds may be made while the pipe is in service provided: the weld is not leaking and the pressure in the pipe has been reduced to that which will not produce a stress in excess of 20% of the specified minimum yield of the pipe, and grinding of the defective area can be limited so that there will remain at least $\frac{1}{8}$ inch thickness in the pipe weld.

(b) Defective welds which cannot be repaired under 850.82 (a) above, and where it is not feasible to remove the defect from the pipe by replacement, may be repaired by the installation of a full-encirclement welded split-sleeve.

(c) All repairs performed under 850.82 (a) and (b) above shall be tested and inspected as provided in 850.91 and 850.92.

850.83 (Addition) Permanent field repair of leaks. (a) If feasible, the pipe shall be taken out of service and repaired by cutting out a cylindrical piece of pipe and replacing same with pipe of similar or greater wall thickness and grade.

(b) If not feasible to take the pipe out of service, repairs shall be made by the installation of a full-encirclement welded split-sleeve.

(c) If the leak is due to a corrosion pit, the repair may be made by the installation of a properly designed bolt-on leak clamp.

(d) If the leak is due to a corrosion pit and on pipe of not more than 40,000 p.s.i. specified minimum yield strength, a steel plate patch with rounded corners and with dimensions not in excess of one-half the diameter of the pipe may be fillet-welded over the pitted area. The thickness of the plate shall be the same or greater than the pipe.

(e) All repairs performed under 850.83 (a), (b), and (d) above shall be tested and inspected as provided in 850.91 and 850.92.

850.9 (Addition) Testing repairs to steel pipelines or mains operating at hoop stress levels at or above 40% of the specified minimum yield strength.

850.91 (Addition) Testing of replacement pipe sections.

850.911 (Addition) When a scheduled repair to a pipeline or main is made by cutting out the damaged portion of the pipe as a cylinder and replacing it with another section, the replacement section of a pipe shall be subjected to a pressure test. The replacement section of pipe shall be tested to the pressure required for a new pipeline or main installed in the same location. The tests may be made on the pipe prior to use, provided non-destructive tests are made on all girth butt-welds after installation.

850.92 (Addition) Testing of repaired gouges, grooves, dents, and welds.

850.921 (Addition) If gouges or grooves are repaired by grinding to a smooth contour in accordance with the provisions of 850.81 (a), no pressure testing is required of the repaired section of pipe.

850.922 (Addition) If gouges, grooves, dents, or welds are repaired by welding in accordance with the provisions of 850.81, 850.82, and 850.83, the welding shall be visually inspected by a qualified inspector.

850.10 (Addition) Repair procedures for steel pipe operating below 40% of the specified minimum yield strength. Due primarily to climate conditions gouges, grooves, notches, and dents have been found to be an important cause of steel pipe failures. If inspections at any time reveal an injurious defect, gouge, groove, dent, or leak, immediate temporary measures shall be employed to protect the property and the public if it is not feasible to make permanent repair at time of discovery. As soon as feasible, permanent repair shall be made using recognized methods of repair.

851.1 (Change) Pipeline patrolling. Each operating company shall maintain a periodic pipeline patrol program to observe surface conditions on and adjacent to the pipeline right-of-way, indications of leaks, construction activity other than performed by the company, and any other factors affecting the safety and operation of the pipeline. Weather, terrain, size of line, operating pressure, class location, and other conditions will be factors in determining the frequency of patrol. Main highways and railroad crossings shall be inspected with greater frequency and more closely than pipelines in open country.

851.3 (Change) Internal corrosion of pipelines. When active corrosive agents are known to be present in the gas being transmitted, or if evidence of internal corrosion is discovered, the gas shall be periodically analyzed to determine the concentration of any destructive agent and precautions taken, if necessary, to prevent the development of a hazardous condition. Whenever a pipeline is cut for any reason, the internal surface shall be carefully inspected for evidence of internal corrosion.

851.7 (Addition) Abandoning of transmission facilities. Each oper-

ating company shall have a plan in its operating and maintenance procedures for abandoning transmission facilities. The plan shall include the following provisions:

(a) Facilities to be abandoned shall be disconnected from all sources and supplies of gas such as other pipelines, mains, cross-over piping, meter stations, control lines, and other appurtenances.

(b) Facilities to be abandoned in place shall be purged of gas with an inert material and the ends sealed, except as provided in 851.7 (c).

(c) If precautions are taken to insure that no liquid hydrocarbons remain in the facilities to be abandoned, then such facilities may be purged with air. If the facilities are purged with air, then precautions must be taken to insure that a combustible mixture is not present after purging. (See 841.285.)

852.2 (Change) Leakage surveys and routine procedures. Every gas utility shall maintain a gas leak-detection program and shall maintain records of operation under the program. The program shall consist of not less than the following:

(a) In principal business districts (as shown by maps filed with the public service commission by each utility) a reasonable street-opening survey shall be conducted twice annually by making tests with combustible gas indicators in street openings such as telephone and electric vaults and manholes, catch basins and sewer system manholes, and gas system openings.

(b) In each principal business district a building survey shall be conducted once a year. The piping from the entrance to the meter outlet and metering and regulating equipment shall be tested for gas leakage in those buildings that have gas service.

(c) A survey of all buildings used for public gatherings such as schools, churches, hospitals, and theaters shall be conducted once each year. The piping from the service entrance to the meter outlet and metering and regulating equipment shall be tested for gas leakage.

(d) In residential areas, in addition to a survey of public buildings, the vegetation shall be checked. At least 3 barhole tests shall be made in each block; at least one street opening shall be checked if one exists in each block or at each intersection; and on streets where system is operating at a pressure of more than 10 p.s.i.g., all street openings shall be checked. (See 852.21 (a) above for types of street openings.) The utility may substitute for the barhole tests a ground surface survey with a hand-operated, continuous-sampling instrument capable of detecting combustible gas in air concentrations of 100 parts per million. The utility may substitute for all the tests required by this section above a survey by mobile flame ionization or infrared gas detection units, provided that a method be included to check individual services. The tests required by this section shall be made once each year.

(e) Along lines in rural areas, the vegetation shall be checked annually.

(f) When a leak complaint is received and the odor of gas indicates that there is a leak in or near the premises, a search shall be carried to conclusion until such leak is found.

852.22 (Change) When a leak is found and repaired, a further check shall be made in the vicinity of the repaired leak to determine if there is any other source of migrant gas in the neighborhood.

852.3 (Change) Abandoning of distribution facilities. Each operating company shall have a plan in its operating and maintenance procedure for sealing off the supply of gas to all distribution facilities for which there is no planned use, including service lines, mains, control lines, equipment, and appurtenances. Special efforts shall be made to include services which have not been used for 2 years in a way that will remove gas from the customers' premises. The plan shall include the following provisions:

(a) If the facilities are abandoned in place, they shall be physically disconnected from the piping system. The open ends of all abandoned facilities shall be capped, plugged, or otherwise effectively sealed.

In addition, the need for purging the abandoned facility to prevent the development of a potentially hazardous condition shall be considered. Air or inert gas may be used for purging, or the facility may be filled with water or other inert materials. (See 841.285.)

(b) In cases where a main is abandoned, together with the service lines connected to it, insofar as service lines are concerned, only the customers' end of such service lines need be sealed as stipulated above.

(c) When vaults are abandoned in place, the entire vault shall be filled with a suitable compacted material.

852.4 (Change) Testing of abandoned services and mains. Service lines and mains previously abandoned shall be tested in the same manner as new service lines before being reinstated. Service lines temporarily disconnected because of main renewals or other planned work shall be tested from the point of disconnection to the service line valve in the same manner as new service lines before reconnecting. If, however, provisions are made to maintain continuous service, such as by installation of a bypass, any portion of the original service line used to maintain continuous service need not be tested.

852.5 (Addition) When street is paved or repaved. Whenever a road or street is paved or repaved with permanent pavement, the utility shall:

(a) Check for leaks along all mains and services in the streets and abutting property. This check shall be conducted by testing with a combustible gas indicator air samples taken from holes placed near the pipes.

(b) Determine condition of pipe and joints by sample visual examination.

(c) Place clamps on, reconstruct, or repair joints if they are likely to dry out or are leaking.

(d) Replace pipe if existing pipe is corroded to such an extent that it is likely to require replacement before the street is again resurfaced.

852.6 (Addition) Underground pipes. Whenever underground pipes are exposed in order to repair leaks, the utility shall record on the repair order the nature of the leak and possible cause from observation.

853.5 (Change) Storage of combustible materials. All flammable or combustible materials in quantities beyond those required for every-

day use, or other than those normally used in compressor buildings, shall be stored in a separate structure built of non-combustible material located at a suitable distance from the compressor building. All above-ground oil or gasoline storage tanks shall be constructed and protected in accordance with the applicable codes of the department of industry, labor and human relations.

855.1 (Change) All pressure-limiting stations, relief devices, and pressure-regulating stations and equipment shall be subjected to systematic periodic inspections and suitable tests to determine that they are:

(a) In good mechanical condition.

(b) Adequate from the standpoint of capacity and reliability of operation for the service in which they are employed.

(c) Set to function at the correct pressure.

(d) Properly installed and protected from dirt, liquids, or other conditions that might prevent proper operation.

In addition, all district regulators and associated safety devices shall be cleaned, lubricated, and checked for proper operation. Worn, damaged, or corroded parts shall be replaced and the entire installation checked to determine compliance with this code and rules of good practice. The inspection shall be made annually.

855.11 (Change) Company service regulators and associated safety devices on customers' premises shall be inspected and tested periodically to determine whether they are in proper operating condition. The above shall include testing of the set pressure of the regulator at a specific flow rate, determination of the lock-up pressure, and determine as to whether there are any leaks, internal or external, associated with the regulator. The test interval shall be the same as the interval between meter changes in the meter rotation program. (See section PSC 134.30.)

855.3 (Change) Whenever it is practicable to do so, pressure relief valves shall be tested in place to determine that they have sufficient capacity to limit the pressure on the facilities to which they are connected to the desired maximum pressure. If such tests are not feasible, periodic review and calculation of the required capacity of the relieving equipment at each station shall be made and this required capacity compared with the rate or experimentally determined relieving capacity of the installed equipment for the operating conditions under which it works. If it is determined that the relieving equipment is of insufficient capacity, steps shall be taken to install new or additional equipment to provide capacity.

856.2 (Change) Distribution system valves. Valves, the use of which may be necessary for the safe operation of a gas distribution system, shall be checked and serviced, including lubrication when necessary, at least once per year to be reasonably assured of their satisfactory operation. Inspection shall include checking of alignment to permit use of a key or wrench and clearing from the valve box or vault any debris which would interfere or delay the operation of the valve.

861 (Change) Odorization. Any gas distributed by distribution utilities to customers through intercity mains, distribution mains, or

services or used for domestic purposes in compressor plants shall have a distinctive odor of sufficient intensity to produce a detectable and recognizable odor at the most remote utilization equipment when the amount of gas in the air is 20% of the lower limit of combustibility. Whenever necessary to maintain this level of intensity, a suitable odorant shall be added in accordance with the following:

- (1) Odorants in the concentrations used shall be:
 - (a) Harmless to humans.
 - (b) Non-corrosive or harmful to steel, iron, brass, copper, plastic, and leather.
 - (c) Not soluble in water to an extent greater than 2.5 parts by weight of odorant to 100 parts by weight of water.
- (2) Odorizing equipment shall be designed to maintain uniform level of odor in the gas.

Appendix C (Addition) Add to the table the following:

Specification	Specified Minimum Yield Strength (p.s.i.)
API 5LX Grade X65 _____	65,000

History: Cr. Register, February, 1968, No. 146, eff. 3-1-68; am. (3), Register, May, 1969, No. 161, eff. 6-1-69.

PSC 135.11 Adoption of federal minimum safety standards. (1) The federal Department of Transportation, Office of Pipeline Safety, pursuant to the Natural Gas Pipeline Safety Act of 1968 (49 U.S.C. 1675, et seq.) has established Minimum Safety Standards for pipeline facilities and the transportation of gas. The standards adopted appeared in the Federal Register, Volume 35, No. 161, August 19, 1970, Part II, at pages 13257 through 13276, inclusive, and Volume 35, No. 205, October 21, 1970 at pages 16405 and 16406, inclusive, and established a new Part 192 in Title 49, Code of Federal Regulations. In accordance with the Natural Gas Pipeline Safety Act of 1968 and requirements of the federal Department of Transportation, such Minimum Safety Standards are hereby adopted as state Safety Standards. (The numbering system and sequence used in said Minimum Safety Standards are herein used for convenience and clarity.) The standards adopted under this section are the only state standards of this commission applicable to interstate natural gas facilities. The standards of this section are also applicable to all intrastate gas utility facilities but any rules, regulations, or standards in other sections of chapter PSC 135 which are more stringent than those prescribed by this section will remain in force and effect and shall be applicable.

(2) The inspection and maintenance plans required to be filed by intrastate gas utilities in accordance with section PSC 135.11-192.17 shall be filed with this commission not later than February 1, 1971. Each change in such plans shall be filed with this commission within 20 days after the change is made.

**WISCONSIN CODE ADOPTION
OF
PART 192 IN TITLE 49
CODE OF FEDERAL REGULATIONS**

Sec.	Subpart A—General	Sec	
192.1	Scope of part.	192.173	Compressor stations: venti- lation.
192.3	Definitions.	192.175	Pipe-type and bottle-type holders.
192.5	Class locations.	192.177	Additional provisions for bottle-type holders.
192.7	Incorporation by reference.	192.179	Transmission line valves.
192.9	Gathering lines.	192.181	Distribution line valves.
192.11	Petroleum gas systems.	192.183	Vaults: structural design requirements.
192.13	General.	192.185	Vaults: accessibility.
192.15	Rules of regulatory con- struction.	192.187	Vaults: sealing, venting, and ventilation.
192.17	Filing of inspections and maintenance plans.	192.189	Vaults: drainage and wa- terproofing.
	Subpart B—Materials	192.191	Design pressure of plastic fittings.
192.51	Scope.	192.193	Valve installation in plastic pipe.
192.53	General.	192.195	Protection against acciden- tal over-pressuring.
192.55	Steel pipe.	192.197	Control of the pressure of gas delivered from high- pressure distribution sys- tems.
192.57	Cast iron or ductile iron pipe.	192.199	Requirements for design of pressure relief and limit- ing devices.
192.59	Plastic pipe.	192.201	Required capacity of pres- sure relieving and limit- ing stations.
192.61	Copper pipe.	192.203	Instrument, control, and sampling pipe and com- ponents.
192.63	Marking of materials.		Subpart E—Welding of Steel in Pipelines
192.65	Transportation of pipe.	192.221	Scope.
	Subpart C—Pipe Design	192.223	General.
192.101	Scope.	192.225	Qualifications of welding procedures.
192.103	General.	192.227	Qualification of welders.
192.105	Design formula for steel pipe.	192.229	Limitations on welders.
192.107	Yield strength (<i>S</i>) for steel pipe.	192.231	Protection from weather.
192.109	Nominal wall thickness (<i>t</i>) for steel pipe.	192.233	Miter joints.
192.111	Design factor (<i>F'</i>) for steel pipe.	192.235	Preparation for welding.
192.113	Longitudinal joint factor (<i>B</i>) for steel pipe.	192.237	Preheating.
192.115	Temperature derating fac- tor (<i>T</i>) for steel pipe.	192.239	Stress relieving.
192.117	Design of cast iron pipe.	192.241	Inspection and test of welds.
192.119	Design of ductile iron pipe.	192.243	Nondestructive testing.
192.121	Design of plastic pipe.	192.245	Repair or removal of de- fects.
192.123	Design limitations for plas- tic pipe.		Subpart F—Joining of Materials Other Than by Welding
192.125	Design of copper pipe.	192.271	Scope.
	Subpart D—Design of Pipeline Components	192.273	General.
192.141	Scope.	192.275	Cast iron pipe.
192.143	General requirements.	192.277	Ductile iron pipe.
192.145	Valves.	192.279	Copper pipe.
192.147	Flanges and flange acces- sories.	192.281	Plastic pipe.
192.149	Standard fittings.		Subpart G—General Construction Requirements for Trans- mission Lines and Mains
192.151	Tapping.	192.301	Scope.
192.153	Components fabricated by welding.	192.303	Compliance with specifica- tions or standards.
192.155	Welded branch connections.	192.305	Inspection: general.
192.157	Extruded outlets.	192.307	Inspection of materials.
192.159	Flexibility.		
192.161	Supports and anchors.		
192.163	Compressor stations: design and construction.		
192.165	Compressor stations: liquid removal.		
192.167	Compressor stations: emer- gency shutdown.		
192.169	Compressor stations: pres- sure limiting devices.		
192.171	Compressor stations: addi- tional safety equipment.		

Sec.	
192.309	Repair of steel pipe.
192.311	Repair of plastic pipe.
192.313	Bends and elbows.
192.315	Wrinkle bends in steel pipe.
192.317	Protection from hazards.
192.319	Installation of pipe in a ditch.
192.321	Installation of plastic pipe.
192.323	Casing.
192.325	Underground clearance.
192.327	Cover.

Subpart H—Customer Meters, Service Regulators, and Service Lines

192.351	Scope.
192.353	Customer meters and regulators: location.
192.355	Customer meters and regulators: protection from damage.
192.357	Customer meters and regulators: installation.
192.359	Customer meter installations: operating pressure.
192.361	Service lines: installation.
192.363	Service lines: valve requirements.
192.365	Service lines: location of valves.
192.367	Service lines: general requirements for connections to main piping.
192.369	Service lines: connections to cast iron or ductile iron mains.
192.371	Service lines: steel.
192.373	Service lines: cast iron and ductile iron.
192.375	Service lines: plastic.
192.377	Service lines: copper.

Subpart I—[Reserved]

Subpart J—Test Requirements

192.501	Scope.
192.503	General requirements.
192.505	Strength test requirements for steel pipeline to operate at a hoop stress of 30 percent or more of SMYS.
192.507	Test requirements for pipeline to operate at a hoop stress less than 30 percent of SMYS and above 100 p.s.i.g.
192.509	Test requirements for pipelines to operate at or below 100 p.s.i.g.
192.511	Test requirements for service lines.
192.515	Environmental protection and safety requirements.
192.517	Records.

Subpart K—Upgrading

192.551	Scope.
192.553	General requirements.
192.555	Upgrading to a pressure that will produce a hoop stress of 30 percent or more of SMYS in steel pipelines.
192.557	Upgrading: steel pipelines to a pressure that will produce a hoop stress less than 30 percent of SMYS; plastic, cast iron, and ductile iron pipelines.

Sec.

Subpart L—Operations

192.601	Scope.
192.603	General provision.
192.605	Essentials of operating and maintenance plan.
192.607	Initial determination of class location and confirmation or establishment of maximum allowable operating pressure.
192.609	Change in class location: required study.
192.611	Change in class location: confirmation or revision of maximum allowable operating pressure.
192.613	Continuing surveillance.
192.615	Emergency plans.
192.617	Investigation of failures.
192.619	Maximum allowable operating pressure: steel or plastic pipelines.
192.621	Maximum allowable operating pressure: high-pressure distribution systems.
192.623	Maximum and minimum allowable operating pressure: low-pressure distribution systems.
192.625	Odorization of gas.
192.627	Tapping pipelines under pressure.
192.629	Purging of pipelines.

Subpart M—Maintenance Procedures

192.701	Scope.
192.703	General.
192.705	Transmission lines: patrolling.
192.707	Transmission lines: markers.
192.709	Transmission lines: record-keeping.
192.711	Transmission lines: general requirements for repair procedures.
192.713	Transmission lines: permanent field repair of imperfections and damage.
192.715	Transmission lines: permanent repair of welds.
192.717	Transmission lines: permanent field repair of leaks.
192.719	Transmission lines: testing of repairs.
192.721	Distribution systems: patrolling.
192.723	Distribution systems: leakage surveys and procedures.
192.725	Test requirement for reinstating service lines.
192.727	Abandonment or inactivation of facilities.
192.729	Compressor stations: procedure for gas compressor units.
192.731	Compressor stations: inspection and testing of relief services.
192.733	Compressor stations: isolation of equipment for maintenance or alterations.
192.735	Compressor stations: storage of combustible materials.

Sec. 192.737	Pipe-type and bottle-type holders: plan for inspection and testing.	Sec. 192.749	Valve maintenance.
192.739	Pressure limiting and regulating stations: inspection and testing.	192.751	Prevention of accidental ignition.
192.741	Pressure limiting and regulating stations: telemetering or recording gages.	192.753	Caulked bell and spigot joints.
192.743	Pressure limiting and regulating stations: testing of relief devices.	Appendix A	—Materials incorporated by reference.
192.745	Valve maintenance: transmission lines.	Appendix B	—Qualification of pipe.
192.747	Valve maintenance: distribution systems.	Appendix C	—Qualification of welders for low stress level pipe.
		AUTHORITY: The provisions of this Part 192 issued under 49 U.S.C. 1671 et seq.	

Subpart A—General

§ 192.1 Scope of part.

(a) This part prescribes minimum safety requirements for pipeline facilities and the transportation of gas, including pipeline facilities and the transportation of gas within the limits of the outer continental shelf as that term is defined in the Outer Continental Shelf Lands Act (43 U.S.C. 1331).

(b) This part does not apply to the gathering of gas outside of the following areas:

(1) An area within the limits of any incorporated or unincorporated city, town, or village.

(2) Any designated residential or commercial area such as a subdivision, business or shopping center, or community development.

§ 192.3 Definitions.

As used in this part—

“Distribution Line” means a pipeline other than a gathering or transmission line.

“Gas” means natural gas, flammable gas, or gas which is toxic or corrosive.

“Gathering Line” means a pipeline that transports gas from a current production facility to a transmission line or main.

“High pressure distribution system” means a distribution system in which the gas pressure in the main is higher than the pressure provided to the customer.

“Listed specification” means a specification listed in section I of Appendix B of this part.

“Low-pressure distribution system” means a distribution system in which the gas pressure in the main is substantially the same as the pressure provided to the customer.

“Main” means a distribution line that serves as a common source of supply for more than one service line.

“Maximum actual operating pressure” means the maximum pressure that occurs during normal operations over a period of 1 year.

“Maximum allowable operating pressure” means the maximum pressure at which a pipeline or segment of a pipeline may be operated under this part.

“Municipality” means a city, county, or any other political subdivision of a State.

"Operator" means a person who engages in the transportation of gas.

"Person" means any individual, firm, joint venture, partnership, corporation, association, State, municipality, cooperative association, or joint stock association, and includes any trustee, receiver, assignee, or personal representative thereof.

"Pipe" means any pipe or tubing used in the transportation of gas, including pipe-type holders.

"Pipeline" means all parts of those physical facilities through which gas moves in transportation, including pipe, valves, and other appurtenance attached to pipe, compressor units, metering stations, regulator stations, delivery stations, holders, and fabricated assemblies.

"Pipeline facility" means new and existing pipelines, rights-of-way, and any equipment, facility, or building used in the transportation of gas or in the treatment of gas during the course of transportation.

"Secretary" means the Secretary of Transportation or any person to whom he has delegated authority in the matter concerned.

"Service Line" means a distribution line that transports gas to a customer meter set assembly from a common source of supply.

"SMYS" means specified minimum yield strength is—

(1) For steel pipe manufactured in accordance with a listed specification, the yield strength specified as a minimum in that specification; or

(2) For steel pipe manufactured in accordance with an unknown or unlisted specification, the yield strength determined in accordance with § 192.107(b).

"State" means each of the several States, the District of Columbia, and the Commonwealth of Puerto Rico.

"Transmission line" means a pipeline, other than a gathering line, that—

(1) Transports gas from a gathering line or storage facility to a distribution center or storage facility;

(2) Operates at a hoop stress of 20 percent or more of SMYS; or

(3) Transports gas within a storage field.

"Transportation of gas" means the gathering, transmission, or distribution of gas by pipeline or the storage of gas, in or affecting interstate or foreign commerce.

§ 192.5—Class locations.

(a) Class location is determined by applying the criteria set forth in this section. The class location unit is an area that extends 220 yards on either side of the centerline of any continuous 1-mile length of pipeline. Except as provided in paragraphs (d) (2) and (f), of this section, the class location is determined by the buildings in the class location unit. For the purposes of this section, each separate dwelling unit in a multiple dwelling unit building is counted as a separate building intended for human occupancy.

(b) A Class 1 location is any class location unit that has 10 or less buildings intended for human occupancy.

(c) A Class 2 location is any class location unit that has more than 10 but less than 46 buildings intended for human occupancy.

(d) A Class 3 location is—

(1) Any class location unit that has 46 or more buildings intended for human occupancy; or

(2) An area where the pipeline lies within 100 yards of any of the following:

(i) A building that is occupied by 20 or more persons during normal use.

(ii) A small, well-defined outside area that is occupied by 20 or more persons during normal use, such as a playground, recreation area, outdoor theater, or other place of public assembly.

(e) A Class 4 location is any class location unit where buildings with four or more stories above ground are prevalent.

(f) The boundaries of the class locations determined in accordance with paragraphs (a) through (e) of this section may be adjusted as follows:

(1) A Class 4 location ends 220 yards from the nearest building with four or more stories above ground.

(2) When a cluster of buildings intended for human occupancy requires a Class 3 location, the Class 3 location ends 220 yards from the nearest building in the cluster.

(3) When a cluster of buildings intended for human occupancy requires a Class 2 location, the Class 2 location ends 220 yards from the nearest building in the cluster.

§ 192.7 Incorporation by reference.

(a) Any documents or parts thereof incorporated by reference in this part are a part of this regulation as though set out in full.

(b) All incorporated documents are available for inspection in the Office of Pipeline Safety, Room 107, 400 Sixth Street SW., Washington, D. C. In addition, the documents are available at the addresses provided in Appendix A to this part.

(c) The full titles for the publications incorporated by reference in this part are provided in Appendix A to this part.

§ 192.9 Gathering lines.

Each gathering line must comply with the requirements of this part applicable to transmission lines.

§ 192.11 Petroleum gas systems.

(a) No operator may transport petroleum gas in a system that serves 10 or more customers, or in a system, any portion of which is located in a public place (such as a highway), unless that system meets the requirements of this part and of NFPA Standards No. 58 and No. 59. In the event of a conflict, the requirements of this part prevail.

(b) Each petroleum gas system covered by paragraph (a) of this section must comply with the following:

(1) Aboveground structures must have open vents near the floor level.

(2) Belowground structures must have forced ventilation that will prevent any accumulation of gas.

(3) Relief valve discharge vents must be located so as to prevent any accumulation of gas at or below ground level.

(4) Special precautions must be taken to provide adequate ventilation where excavations are made to repair an underground system.

(c) For the purpose of this section, petroleum gas means propane, butane, or mixtures of these gases, other than a gas air mixture that is used to supplement supplies in a natural gas distribution system.

§ 192.13 General.

(a) No person may operate a segment of pipeline that is readied for service after March 12, 1971, unless that pipeline has been designed, installed, constructed, initially inspected, and initially tested in accordance with this part.

(b) No person may operate a segment of pipeline that is replaced, relocated, or otherwise changed after November 12, 1970, unless that replacement, relocation, or change has been made in accordance with this part.

(c) Each operator shall maintain, modify as appropriate, and follow the plans, procedures, and programs that it is required to establish under this part.

§ 192.15 Rules of regulatory construction.

(a) As used in this part—

“Includes” means including but not limited to.

“May” means “is permitted to” or “is authorized to”.

“May not” means “is not permitted to” or “is not authorized to”.

“Shall” is used in the mandatory and imperative sense.

(b) In this part—

(1) Words importing the singular include the plural;

(2) Words importing the plural include the singular; and

(3) Words importing the masculine gender include the feminine.

§ 192.17 Filing of inspection and maintenance plans.

(a) Except as provided in paragraph (b) of this section, each operator shall file with the secretary not later than February 1, 1971 a plan for inspection and maintenance of each pipeline facility which he owns or operates. In addition, each change to an inspection and maintenance plan must be filed with the secretary within 20 days after the change is made.

(b) The provisions of paragraph (a) of this section do not apply to pipeline facilities—

(1) That are subject to the jurisdiction of a state agency that has submitted a certification or agreement with respect to those facilities under section 5 of the Natural Gas Pipeline Safety Act (49 U.S.C. 1675); and

(2) For which an inspection and maintenance plan is required to be filed with that state agency.

(c) Plans filed with the secretary must be sent to the office of Pipeline Safety, Department of Transportation, Washington, D. C. 20590.

Subpart B—Materials**§ 192.51 Scope.**

This subpart prescribes minimum requirements for the selection and qualification of pipe and components for use in pipelines.

§ 192.53 General.

Materials for pipe and components must be—

(a) Able to maintain the structural integrity of the pipeline under temperature and other environmental conditions that may be anticipated;

(b) Chemically compatible with any gas that they transport and with any other material in the pipeline with which they are in contact; and

(c) Qualified in accordance with the applicable requirements of this subpart.

§ 192.55 Steel pipe.

(a) New steel pipe is qualified for use under this part if—

(1) It was manufactured in accordance with a listed specification;

(2) It meets the requirements of paragraphs II-A through II-D of Appendix B of this part; or

(3) It is used in accordance with paragraph (c) of this section.

(b) Used steel pipe is qualified for use under this part if—

(1) It was manufactured in accordance with a listed specification and it meets the requirements of paragraph II-C of Appendix B to this part;

(2) It meets the requirements of paragraph II-A through II-D of Appendix B to this part.

(3) It has been used in an existing line of the same or higher pressure and meets the requirements of paragraph II-C of Appendix B to this part; or

(4) It is used in accordance with paragraph (c) of this section.

(c) New or used steel pipe may be used at a pressure resulting in a hoop stress of less than 6,000 p.s.i. where no close coiling or close bending is to be done, if visual examination indicates that the pipe is in good condition and that it is free of split seams and other defects that would cause leakage. If it is to be welded, steel pipe that has not been manufactured to a listed specification must also pass the weldability tests prescribed in paragraph II-B of Appendix B to this part.

(d) New steel pipe that has been cold expanded must comply with the mandatory provisions of API Standard 5LX.

§ 192.57 Cast iron or ductile iron pipe.

(a) New cast iron or new ductile iron pipe is qualified for use under this part if it has been manufactured in accordance with a listed specification.

(b) Used cast iron or used ductile iron pipe is qualified for use under this part if inspection shows that the pipe is sound and allows the makeup of tight joints and—

- (1) It has been removed from an existing pipeline that operated at the same or higher pressure; or
- (2) It was manufactured in accordance with a listed specification.

§ 192.59 Plastic pipe.

- (a) New plastic pipe is qualified for use under this part if—
- (1) It is manufactured in accordance with a listed specification; and
 - (2) It is resistant to chemicals with which contact may be anticipated.
- (b) Used plastic pipe is qualified for use under this part if—
- (1) It meets the requirements of a listed specification;
 - (2) It is resistant to chemicals with which contact may be anticipated;
 - (3) It has been used only in natural gas service;
 - (4) Its dimensions are still within the tolerances of the specification to which it was manufactured; and
 - (5) It is free of visible defects.

§ 192.61 Copper pipe.

Copper pipe is qualified for use under this part if it has been manufactured in accordance with a listed specification.

§ 192.63 Marking of materials.

- (a) Each valve, fitting, length of pipe, and other component must be marked as prescribed in—
- (1) The specification or standard to which it was manufactured; or
 - (2) MSS standard practice, SP-25.
- (b) Surfaces of pipe and components that are subject to stress from internal pressure may not be field die stamped.
- (c) If any item is marked by die stamping, the die must have blunt or rounded edges that will minimize stress concentrations.

§ 192.65 Transportation of pipe.

In a pipeline to be operated at a hoop stress of 20 percent or more of SMYS, no operator may use pipe having an outer diameter to wall thickness ratio of 70 to one, or more, that is transported by railroad unless that transportation was performed in accordance with API RP5L1.

Subpart C—Pipe Design

§ 192.101 Scope.

This subpart prescribes the minimum requirements for the design of pipe.

§ 192.103 General.

Pipe must be designed with sufficient wall thickness, or must be installed with adequate protection, to withstand anticipated external pressures and loads that will be imposed on the pipe after installation.

§ 192.105 Design formula for steel pipe.

(a) The design pressure for steel pipe is determined in accordance with the following formula:

$$P = \frac{2 St}{D} \times F \times E \times T$$

P = Design pressure in pounds per square inch gage.

S = Yield strength in pounds per square inch determined in accordance with § 192.107.

D = Nominal outside diameter of the pipe in inches.

t = Nominal wall thickness of the pipe in inches. If this is unknown, it is determined in accordance with § 192.109. Additional wall thickness required for concurrent external loads in accordance with § 192.103 may not be included in computing design pressure.

F = Design factor determined in accordance with § 192.111.

E = Longitudinal joint factor determined in accordance with § 192.113.

T = Temperature derating factor determined in accordance with § 192.115.

(b) If steel pipe that has been cold worked to meet the SMYS is heated, other than by welding, to 600° F. or more, the design pressure is limited to 75 percent of the pressure determined under paragraph (a) of this section.

§ 192.107 Yield strength (S) for steel pipe.

(a) For pipe that is manufactured in accordance with a specification listed in section I of Appendix B of this part, the yield strength to be used in the design formula in § 192.105 is the SMYS stated in the listed specification, if that value is known.

(b) For pipe that is manufactured in accordance with a specification not listed in section I of Appendix B to this part or whose specification or tensile properties are unknown, the yield strength to be used in the design formula in § 192.105 is one of the following:

(1) If the pipe is tensile tested in accordance with section 11-D of Appendix B to this part, the lower of the following:

(i) 80 percent of the average yield strength determined by the tensile tests.

(ii) The lowest yield strength determined by the tensile tests, but not more than 52,000 p.s.i.

(2) If the pipe is not tensile tested as provided in subparagraph (1) of this paragraph 24,000 p.s.i.

§ 192.109 Nominal wall thickness (t) for steel pipe.

(a) If the nominal wall thickness for steel pipe is not known, it is determined by measuring the thickness of each piece of pipe at quarter points on one end.

(b) However, if the pipe is of uniform grade, size, and thickness and there are more than 10 lengths, only 10 percent of the individual

lengths, but not less than 10 lengths, need be measured. The thickness of the lengths that are not measured must be verified by applying a gage set to the minimum thickness found by the measurement. The nominal wall thickness to be used in the design formula in § 192.105 is the next wall thickness found in commercial specifications that is below the average of all the measurements taken. However, the nominal wall thickness used may not be more than 1.14 times the smallest measurement taken on pipe less than 20 inches in outside diameter, nor more than 1.11 times the smallest measurement taken on pipe 20 inches or more in outside diameter.

§ 192.111 Design factor (*F*) for steel pipe.

(a) Except as otherwise provided in paragraphs (b), (c), and (d) of this section, the design factor to be used in the design formula in § 192.105 is determined in accordance with the following table:

<i>Class location</i>	<i>Design factor (<i>F</i>)</i>
1 -----	0.72
2 -----	0.60
3 -----	0.50
4 -----	0.40

(b) A design factor of 0.60 or less must be used in the design formula in § 192.105 for steel pipe in Class 1 locations that:

(1) Crosses the right-of-way of an unimproved public road, without a casing;

(2) Crosses without a casing, or makes a parallel encroachment on, the right-of-way of either a hard surfaced road, a highway, a public street, or a railroad;

(3) Is supported by a vehicular, pedestrian, railroad, or pipeline bridge; or

(4) Is used in a fabricated assembly, (including separators, main-line valve assemblies, cross-connections, and river crossing headers) or is used within five pipe diameters in any direction from the last fitting of a fabricated assembly, other than a transition piece or an elbow used in place of a pipe bend which is not associated with a fabricated assembly.

(c) For Class 2 locations, a design factor of 0.50, or less, must be used in the design formula in § 192.105 for uncased steel pipe that crosses the right-of-way of a hard surfaced road, a highway, a public street, or a railroad.

(d) For Class 1 or Class 2 locations, a design factor of 0.50, or less, must be used in the design formula in § 192.105 for each compressor station, regulator station, and measuring station.

§ 192.113 Longitudinal joint factor (*E*) for steel pipe.

The longitudinal joint factor to be used in the design formula in § 192.105 is determined in accordance with the following table:

Specification	Pipe class	Longitudinal joint factor (E)
ASTM A 53	Seamless	1.00
	Electric resistance welded	1.00
	Furnace butt welded	.60
ASTM A 106	Seamless	1.00
ASTM A 134	Electric fusion arc welded	.80
ASTM A 135	Electric resistance welded	1.00
ASTM A 139	Electric fusion welded	.80
ASTM A 155	Electric fusion arc welded	1.00
ASTM A 211	Spiral welded steel pipe	.80
ASTM A 333	Seamless	1.00
	Electric resistance welded	1.00
ASTM A 381	Double submerged arc welded	1.00
API 5 L	Seamless	1.00
	Electric resistance welded	1.00
	Electric flash welded	1.00
	Submerged arc welded	1.00
	Furnace butt welded	.60
	Furnace lap-welded	.80
API 5 LX	Seamless	1.00
	Electric resistance welded	1.00
	Electric flash welded	1.00
	Submerged arc welded	1.00
API 5 LS	Electric resistance welded	1.00
	Submerged arc welded	1.00
Other	Pipe over 4 inches	.80
Other	Pipe 4 inches or less	.60

If the type of longitudinal joint cannot be determined, the joint factor to be used must not exceed that designated for "Other".

§ 192.115 Temperature derating factor (T) for steel pipe.

The temperature derating factor to be used in the design formula in § 192.105 is determined as follows:

<i>Gas temperature in degrees Fahrenheits</i>	<i>Temperature derating factor (T)</i>
250 or less	1.000
300	0.967
350	0.933
400	0.900
450	0.867

For intermediate gas temperatures, the derating factor is determined by interpolation.

§ 192.117 Design of cast iron pipe.

Cast iron pipe must be designed in accordance with ANSI A 21.1 using the following values for S (bursting tensile strength) and R (modulus of rupture) in the design equations:

Specification	Type of pipe	S	R
		psi	psi
ANSI A 21.8	Pit cast	11,000	31,000
ANSI A 21.7	Centrifugal (metal mold)	18,000	40,000
ANSI A 21.9	Centrifugal (sand-lined mold)	18,000	40,000

§ 192.119 Design of ductile iron pipe.

(a) Ductile iron pipe must be designed in accordance with ANSI A21.50 using the following values in the design equations:

s (design hoop stress) = 16,800 p.s.i.

f (design bending stress) = 36,000 p.s.i.

(b) Ductile iron pipe must be grade (60-42-10) and must conform to the requirements of ANSI A21.52.

§ 192.121 Design of plastic pipe.

(a) The design pressure for plastic pipe is determined in accordance with the following formula and is subject to the limitations of § 192.123:

$$P = 2S \frac{t}{(D - t)} \times F$$

P = Design pressure in pounds per square inch gage.

S = For thermoplastic pipe, the long-term hydrostatic strength in pounds per square inch as stated in the listed specification; for thermosetting plastic pipe, 11,000 p.s.i.

t = Specified wall thickness in inches.

D = Specified outside diameter in inches.

F = Design factor for plastic pipe.

(b) The design factor for plastic pipe is determined as follows:

<i>Class location</i>	<i>Design factor</i>
1 -----	0.32
2 -----	0.25
3 -----	0.25
4 -----	0.20

§ 192.123 Design limitation for plastic pipe.

(a) The design pressure may not exceed 100 p.s.i.g. for plastic pipe used in—

(1) Distribution systems; or

(2) Classes 3 and 4 locations.

(b) Plastic pipe may not be used where operating temperatures of the pipe will be—

(1) Below minus 20° F.; or

(2) Above 100° F. for thermoplastic pipe or above 150° F. for reinforced thermosetting plastic pipe.

(c) The wall thickness for thermoplastic pipe may not be less than 0.062 inches.

(d) The wall thickness for reinforced thermosetting plastic pipe may not be less than that listed in the following table:

<i>Nominal size in inches</i>	<i>Minimum wall thickness in inches</i>
2 -----	0.060
3 -----	0.060
4 -----	0.070
6 -----	0.100

§ 192.125 Design of copper pipe.

(a) Copper pipe used in mains must have a minimum wall thickness of 0.065 inches and must be hard drawn.

(b) Copper pipe used in service lines must have a minimum wall thickness as specified for type "L" pipe in ASTM B 88.

(c) Copper pipe used in mains and service lines may not be used at pressures in excess of 100 p.s.i.g.

(d) Copper pipe that does not have an internal corrosion resistant lining may not be used to carry gas that has an average hydrogen sulfide content of more than 0.3 grains per 100 standard cubic feet of gas.

Subpart D—Design of Pipeline Components**§ 192.141 Scope.**

This subpart prescribes minimum requirements for the design and installation of pipeline components and facilities. In addition, it prescribes requirements relating to protection against accidental overpressuring.

§ 192.143 General requirements.

Each component of a pipeline must be able to withstand operating pressures and other anticipated loadings with unit stresses equivalent to those allowed for comparable material in pipe in the same location and kind of service.

§ 192.145 Valves.

(a) Each valve must meet the minimum requirements of API 6D, or MSS SP-52, or the equivalent, and may not be used under operating conditions that exceed the applicable pressure-temperature ratings contained in those standards.

(b) Each valve must be able to meet the anticipated operating conditions.

(c) No valve having shell components made of ductile iron may be used at pressures exceeding 80 percent of the pressure ratings for comparable steel valves at their listed temperature. However, a valve having shell components made of ductile iron may be used at pressures up to 80 percent of the pressure ratings for comparable steel valves at their listed temperature, if—

(1) The temperature-adjusted service pressure does not exceed 1,000 p.s.i.g.; and

(2) Welding is not used on any ductile iron component in the fabrication of the valve shells or their assembly.

(d) No valve having pressure containing parts made of ductile iron may be used in the gas pipe components of compressor stations.

§ 192.147 Flanges and flange accessories.

(a) *General requirements.* Each flange or flange accessory must meet the minimum requirements of ANSI B16.5, MSS SP-44, or ANSI B16.24, or the equivalent.

(b) Each flange assembly must be able to withstand the maximum pressure at which the pipeline is to be operated and to maintain its physical and chemical properties at any temperature to which it is anticipated that it might be subjected in service.

§ 192.149 Standard fittings.

(a) The minimum metal thickness of threaded fittings may not be less than specified for the pressures and temperatures in the applicable standards referenced in this part, or their equivalent.

(b) Each steel butt-welding fitting must have pressure and temperature ratings based on stresses for pipe of the same or equivalent material. The actual bursting strength of the fitting must at least equal the computed bursting strength of pipe of the designated material and wall thickness, as determined by a prototype that was tested to at least the pressure required for the pipeline to which it is being added.

§ 192.151 Tapping.

(a) Each mechanical fitting used to make a hot tap must be designed for at least the operating pressure of the pipeline.

(b) Where a ductile iron pipe is tapped, the extent of full-thread engagement and the need for the use of outside-sealing service connections, tapping saddles, or other fixtures must be determined by service conditions.

(c) Where a threaded tap is made in cast iron or ductile iron pipe, the diameter of the tapped hole may not be more than 25 percent of the nominal diameter of the pipe unless the pipe is reinforced, except that

(1) Existing taps may be used for replacement service, if they are free of cracks and have good threads; and

(2) A 1¼-inch tap may be made in a 4-inch cast iron or ductile iron pipe, without reinforcement.

However, in areas where climate, soil, and service conditions may create unusual external stresses on cast iron pipe, unreinforced taps may be used only on 6-inch or larger pipe.

§ 192.153 Components fabricated by welding.

(a) Except for branch connections and assemblies of standard pipe and fittings joined by circumferential welds, the design pressure of each component fabricated by welding, whose strength cannot be determined, must be established in accordance with paragraph UG-101 of section VIII of the ASME Boiler and Pressure Vessel Code.

(b) Each prefabricated unit that uses plate and longitudinal seams must be designed, constructed, and tested in accordance with the ASME Boiler and Pressure Vessel Code, except for the following:

(1) Regularly manufactured butt-welding fittings.

(2) Pipe that has been produced and tested under a specification listed in Appendix B to this part.

(3) Partial assemblies such as split rings or collars.

(c) Orange-peel bull plugs and orange-peel swages may not be used on pipelines that are to operate at a hoop stress of 20 percent or more of the SMYS of the pipe.

(d) Except for flat closures designed in accordance with section VIII of the ASME Boiler and Pressure Code, flat closures and fish tails may not be used on pipe that either operates at 100 p.s.i.g., or more, or is more than 3 inches nominal diameter.

§ 192.155 Welded branch connections.

Each welded branch connection made to pipe in the form of a single connection, or in a header or manifold as a series of connections, must be designed to ensure that the strength of the pipeline system is not reduced, taking into account the stresses in the remaining pipe wall due to the opening in the pipe or header, the shear stresses produced by the pressure acting on the area of the branch opening, and any external loadings due to thermal movement, weight, and vibration.

§ 192.157 Extruded outlets.

Each extruded outlet must be suitable for anticipated service conditions and must be at least equal to the design strength of the pipe and other fittings in the pipeline to which it is attached.

§ 192.159 Flexibility.

Each pipeline must be designed with enough flexibility to prevent thermal expansion or contraction from causing excessive stresses in the pipe or components, excessive bending or unusual loads at joints, or undesirable forces or moments at points of connection to equipment, or at anchorage or guide points.

§ 192.161 Supports and anchors.

(a) Each pipeline and its associated equipment must have enough anchors or supports to—

- (1) Prevent undue strain on connected equipment;
- (2) Resist longitudinal forces caused by a bend or offset in the pipe; and
- (3) Prevent or damp out excessive vibration.

(b) Each exposed pipeline must have enough supports or anchors to protect the exposed pipe joints from the maximum end force caused by internal pressure and any additional forces caused by temperature expansion or contraction or by the weight of the pipe and its contents.

(c) Each support or anchor on an exposed pipeline must be made of durable, noncombustible material and must be designed and installed as follows:

- (1) Free expansion and contraction of the pipeline between supports or anchors may not be restricted.
- (2) Provision must be made for the service conditions involved.
- (3) Movement of the pipeline may not cause disengagement of the support equipment.

(d) Each support on an exposed pipeline operated at a stress level of 50 percent or more of SMYS must comply with the following:

(1) A structural support may not be welded directly to the pipe.
(2) The support must be provided by a member that completely encircles the pipe.

(3) If an encircling member is welded to a pipe, the weld must be continuous and cover the entire circumference.

(e) Each underground pipeline that is connected to a relatively unyielding line or other fixed object must have enough flexibility to provide for possible movement, or it must have an anchor that will limit the movement of the pipeline.

(f) Each underground pipeline that is being connected to new branches must have a firm foundation for both the header and the branch to prevent lateral and vertical movement.

§ 192.163 Compressor stations: design and construction.

(a) *Location of compressor building.* Each main compressor building of a compressor station must be located on property under the control of the operator. It must be far enough away from adjacent property, not under control of the operator, to minimize the possibility of fire being communicated to the compressor building from structures on adjacent property. There must be enough open space around the main compressor building to allow the free movement of fire-fighting equipment.

(b) *Building construction.* Each building on a compressor station site must be made of noncombustible materials if it contains either—

(1) Pipe more than 2 inches in diameter that is carrying gas under pressure; or

(2) Gas handling equipment other than gas utilization equipment used for domestic purposes.

(c) *Exits.* Each operating floor of a main compressor building must have at least two separated and unobstructed exits located so as to provide a convenient possibility of escape and an unobstructed passage to a place of safety. Each door latch on an exit must be of a type which can be readily opened from the inside without a key. Each swinging door located in an exterior wall must be mounted to swing outward.

(d) *Fenced areas.* Each fence around a compressor station must have at least two gates located so as to provide a convenient opportunity for escape to a place of safety, or have other facilities affording a similarly convenient exit from the area. Each gate located within 200 feet of any compressor plant building must open outward and, when occupied, must be openable from the inside without a key.

(e) *Electrical facilities.* Electrical equipment and wiring installed in compressor stations must conform to the National Electrical Code, ANSI Standard C1, so far as that code is applicable.

§ 192.165 Compressor stations: liquid removal.

(a) Where entrained vapors in gas may liquefy under the anticipated pressure and temperature conditions, the compressor must be

protected against the introduction of those liquids in quantities that could cause damage.

(b) Each liquid separator used to remove entrained liquids at a compressor station must—

(1) Have a manually operable means of removing these liquids.

(2) Where slugs of liquid could be carried into the compressors, have either automatic liquid removal facilities, an automatic compressor shutdown device, or a high liquid level alarm; and

(3) Be manufactured in accordance with section VIII of the ASME Boiler and Pressure Vessel Code, except that liquid separators constructed of pipe and fittings without internal welding must be fabricated with a design factor of 0.4, or less.

§ 192.167 Compressor stations: emergency shutdown.

(a) Except for unattended field compressor stations of 1,000 horsepower or less, each compressor station must have an emergency shutdown system that meets the following:

(1) It must be able to block gas out of the station and blow down the station piping.

(2) It must discharge gas from the blowdown piping at a location where the gas will not create a hazard.

(3) It must provide means for the shutdown of gas compressing equipment, gas fires, and electrical facilities in the vicinity of gas headers and in the compressor building, except, that—

(i) Electrical circuits that supply emergency lighting required to assist station personnel in evacuating the compressor building and the area in the vicinity of the gas headers must remain energized; and

(ii) Electrical circuits needed to protect equipment from damage may remain energized.

(4) It must be operable from at least two locations, each of which is—

(i) Outside the gas area of the station;

(ii) Near the exit gates in the station fence; and

(iii) Not more than 500 feet from the limits of the station.

(b) If a compressor station supplies gas directly to a distribution system with no other adequate source of gas available, the emergency shutdown system must be designed so that it will not function at the wrong time and cause an unintended outage on the distribution system.

§ 192.169 Compressor stations: pressure limiting devices.

(a) Each compressor station must have pressure relief or other suitable protective devices of sufficient capacity and sensitivity to ensure that the maximum allowable operating pressure of the station piping and equipment is not exceeded by more than 10 percent.

(b) Each vent line that exhausts gas from the pressure relief valves of a compressor station must extend to a location where the gas may be discharged without hazard.

§ 192.171 Compressor stations: additional safety equipment.

(a) Each compressor station must have adequate fire protection facilities. If fire pumps are a part of these facilities, their operation may not be affected by the emergency shutdown system.

(b) Each compressor station prime mover, other than an electrical induction or synchronous motor, must have an automatic device to shut down the unit before the speed of either the prime mover or the driven unit exceeds a maximum safe speed.

(c) Each compressor unit in a compressor station must have a shut-down or alarm device that operates in the event of inadequate cooling or lubrication of the unit.

(d) Each compressor station gas engine that operates with pressure gas injection must be equipped so that stoppage of the engine automatically shuts off the fuel and vents the engine distribution manifold.

(e) Each muffler for a gas engine in a compressor station must have vent slots or holes in the baffles of each compartment to prevent gas from being trapped in the muffler.

§ 192.173 Compressor stations: ventilation.

Each compressor station building must be ventilated to ensure that employees are not endangered by the accumulation of gas in rooms, sumps, attics, pits, or other enclosed places.

§ 192.175 Pipe-type and bottle-type holders.

(a) Each pipe-type and bottle-type holder must be designed so as to prevent the accumulation of liquids in the holder, in connecting pipe, or in auxiliary equipment, that might cause corrosion or interfere with the safe operation of the holder.

(b) Each pipe-type or bottle-type holder must have minimum clearance from other holders in accordance with the following formula:

$$C = \frac{3D \times P \times F}{1,000}$$

in which:

C = Minimum clearance between pipe containers or bottles in inches.

D = Outside diameter of pipe containers or bottles in inches.

P = Maximum allowable operating pressure, p.s.i.g.

F = Design factor as set forth in § 192.111 of this part.

§ 192.177 Additional provisions for bottle-type holders.

(a) Each bottle-type holder must be—

(1) Located on a storage site entirely surrounded by fencing that prevents access by unauthorized persons and with minimum clearance from the fence as follows:

<i>Maximum allowable operating pressure</i>	<i>Minimum clearance (feet)</i>
Less than 1,000 p.s.i.g. -----	25
1,000 p.s.i.g. or more -----	100

(2) Designed using the design factors set forth in § 192.111; and

(3) Buried with a minimum cover in accordance with § 192.327.

(b) Each bottle-type holder manufactured from steel that is not weldable under field conditions must comply with the following:

(1) A bottle-type holder made from alloy steel must meet the chemical and tensile requirements for the various grades of steel in either API Standard 5A or ASTM A 372.

(2) The actual yield-tensile ratio of the steel may not exceed 0.85.

(3) Welding may not be performed on the holder after it has been heat treated or stress relieved, except that copper wires may be attached to the small diameter portion of the bottle end closure for cathodic protection if a localized thermit welding process is used.

(4) The holder must be given a mill hydrostatic test at a pressure that produces a hoop stress at least equal to 85 percent of the SMYS.

(5) The holder, connection pipe, and components must be leak tested after installation as required by Subpart J of this part.

§ 192.179 Transmission line valves.

(a) Each transmission line, other than offshore segments, must have sectionalizing block valves spaced as follows:

(1) Each point on the pipeline in a Class 4 location must be within 2½ miles of a valve.

(2) Each point on the pipeline in a Class 3 location must be within 4 miles of a valve.

(3) Each point on the pipeline in a Class 2 location must be within 7½ miles of a valve.

(4) Each point on the pipeline in a Class 1 location must be within 10 miles of a valve.

(b) Each sectionalizing block valve on a transmission line, other than offshore segments, must comply with the following:

(1) The valve and the operating device to open or close the valve must be readily accessible and protected from tampering and damage.

(2) The valve must be supported to prevent settling of the valve or movement of the pipe to which it is attached.

(c) Each section of a transmission line, other than offshore segments, between main line valves must have a blowdown valve with enough capacity to allow the transmission line to be blown down as rapidly as practicable. Each blowdown discharge must be located so the gas can be blown to the atmosphere without hazard and, if the transmission line is adjacent to an overhead electric line, so that the gas is directed away from the electrical conductors.

§ 192.181 Distribution line valves.

(a) Each high-pressure distribution system must have valves spaced so as to reduce the time to shut down a section of main in an emergency. The valve spacing is determined by the operating pressure, the size of the mains, and the local physical conditions.

(b) Each regulator station controlling the flow or pressure of gas in a distribution system must have a valve installed on the inlet piping at a distance from the regulator station sufficient to permit the operation of the valve during an emergency that might preclude access to the station.

(c) Each valve on a main installed for operating or emergency purposes must comply with the following:

(1) The valve must be placed in a readily accessible location so as to facilitate its operation in an emergency.

(2) The operating stem or mechanism must be readily accessible.

(3) If the valve is installed in a buried box or enclosure, the box or enclosure must be installed so as to avoid transmitting external loads to the main.

§ 192.183 Vaults: structural design requirements.

(a) Each underground vault or pit for valves, pressure relieving, pressure limiting, or pressure regulating stations, must be able to meet the loads which may be imposed upon it, and to protect installed equipment.

(b) There must be enough working space so that all of the equipment required in the vault or pit can be properly installed, operated, and maintained.

(c) Each pipe entering, or within, a regulator vault or pit must be steel for sizes 10 inches, and less, except that control and gage piping may be copper. Where pipe extends through the vault or pit structure, provision must be made to prevent the passage of gases or liquids through the opening and to avert strains in the pipe.

§ 192.185 Vaults: accessibility.

Each vault must be located in an accessible location and, so far as practical, away from—

(a) Street intersections or points where traffic is heavy or dense;

(b) Points of minimum elevation, catch basins, or places where the access cover will be in the course of surface waters; and

(c) Water, electric, steam, or other facilities.

§ 192.187 Vaults: sealing, venting, and ventilation.

Each underground vault or closed top pit containing either a pressure regulating or reducing station, or a pressure limiting or relieving station, must be sealed, vented or ventilated, as follows:

(a) When the internal volume exceeds 200 cubic feet—

(1) The vault or pit must be ventilated with two ducts, each having at least the ventilating effect of a pipe 4 inches in diameter;

(2) The ventilation must be enough to minimize the formation of combustible atmosphere in the vault or pit; and

(3) The ducts must be high enough above grade to disperse any gas-air mixtures that might be discharged.

(b) When the internal volume is more than 75 cubic feet but less than 200 cubic feet—

(1) If the vault or pit is sealed, each opening must have a tight fitting cover without open holes through which an explosive mixture

might be ignited, and there must be a means for testing the internal atmosphere before removing the cover;

(2) If the vault or pit is vented, there must be a means of preventing external sources of ignition from reaching the vault atmosphere; or

(3) If the vault or pit is ventilated, paragraph (a) or (c) of this section applies.

(c) If a vault or pit covered by paragraph (b) of this section is ventilated by openings in the covers or gratings and the ratio of the internal volume, in cubic feet, to the effective ventilating area of the cover or grating, in square feet, is less than 20 to 1, no additional ventilation is required.

§ 192.189 Vaults: drainage and waterproofing.

(a) Each vault must be designed so as to minimize the entrance of water.

(b) A vault containing gas piping may not be connected by means of a drain connection to any other underground structure.

(c) All electrical equipment in vaults must conform to the applicable requirements of Class 1, Group D, of the National Electrical Code, ANSI Standard C1.

§ 192.191 Design pressure of plastic fittings.

(a) Thermosetting fittings for plastic pipe must conform to ASTM D 2517.

(b) The design pressure of alaphabuna-styrene (ABS) and polyvinyl chloride (PVC) Schedule 40 and 80 thermoplastic fittings must be obtained from the following table:

DESIGN PRESSURE OF THERMOPLASTIC FITTINGS. P.S.I.G. OF VARIOUS STRENGTHS, MATERIALS AND CLASS LOCATIONS

Size inches	Schedule	ABS Type I and PVC Type II class location			PVC Type I class location		
		1	2 and 3	4	1	2 and 3	4
½	40	100	100	100	100	100	100
	80	100	100	100	100	100	100
¾	40	100	100	96	100	100	100
	80	100	100	100	100	100	100
1	40	100	100	90	100	100	100
	80	100	100	100	100	100	100
1¼	40	100	92	74	100	100	100
	80	100	100	100	100	100	100
1½	40	100	83	66	100	100	100
	80	100	100	94	100	100	100
2	40	89	69	55	100	100	100
	80	100	100	81	100	100	100
2½	40	99	76	61	100	100	100
	80	100	100	85	100	100	100
3	40	84	66	53	100	100	100
	80	100	94	75	100	100	100
3½	40	77	60	48	100	100	96
	80	100	86	69	100	100	100
4	40	71	56	44	100	100	89
	80	100	81	65	100	100	100
5	40	62	49	39	100	97	78
	80	98	72	58	100	100	100
6	40	56	44	35	100	88	71
	80	89	70	56	100	100	100

NOTE: These pressure ratings are the same value as the design pressure of the corresponding pipe size and schedule in the same class location, as determined by the formula given in § 192.121 and the limitations in § 192.123 of this part.

§ 192.193 Valve installation in plastic pipe.

Each valve installed in plastic pipe must be designed so as to protect the plastic material against excessive torsional or shearing loads when the valve or shutoff is operated, and from any other secondary stresses that might be exerted through the valve or its enclosure.

§ 192.195 Protection against accidental overpressuring.

(a) *General requirements.* Except as provided in § 192.197, each pipeline that is connected to a gas source so that the maximum allowable operating pressure could be exceeded as the result of pressure control failure or of some other type of failure, must have pressure relieving or pressure limiting devices that meet the requirements of §§ 192.199 and 192.201.

(b) *Additional requirements for distribution systems.* Each distribution system that is supplied from a source of gas that is at a higher pressure than the maximum allowable operating pressure for the system must—

(1) Have pressure regulation devices capable of meeting the pressure, load, and other service conditions that will be experienced in normal operation of the system, and that could be activated in the event of failure of some portion of the system; and

(2) Be designed so as to prevent accidental overpressuring.

§ 192.197 Control of the pressure of gas delivered from high-pressure distribution systems.

(a) If the maximum actual operating pressure of the distribution system is under 60 p.s.i.g. or less and a service regulator having the following characteristics is used, no other pressure limiting device is required:

(1) A regulator capable of reducing distribution line pressure to pressures recommended for household appliances.

(2) A single port valve with proper orifice for the maximum gas pressure at the regulator inlet.

(3) A valve seat made of resilient material designed to withstand abrasion of the gas, impurities in gas, cutting by the valve, and to resist permanent deformation when it is pressed against the valve port.

(4) Pipe connections to the regulator not exceeding 2 inches in diameter.

(5) A regulator that, under normal operating conditions, is able to regulate the downstream pressure within the necessary limits of accuracy and to limit the build-up of pressure under no-flow conditions to prevent a pressure that would cause the unsafe operation of any connected and properly adjusted gas utilization equipment.

(6) A self-contained service regulator with no external static or control lines.

(b) If the maximum actual operating pressure of the distribution system is 60 p.s.i.g., or less, and a service regulator that does not have all of the characteristics listed in paragraph (a) of this section

is used, or if the gas contains materials that seriously interfere with the operation of service regulators, there must be suitable protective devices to prevent unsafe overpressuring of the customer's appliances if the service regulator fails.

(c) If the maximum actual operating pressure of the distribution systems exceeds 60 p.s.i.g. one of the following methods must be used to regulate and limit, to the maximum safe value, the pressure of gas delivered to the customer:

(1) A service regulator having the characteristics listed in paragraph (a) of this section, and another regulator located upstream from the service regulator. The upstream regulator may not be set to maintain a pressure higher than 60 p.s.i.g. A device must be installed between the upstream regulator and the service regulator to limit the pressure on the inlet of the service regulator to 60 p.s.i.g. or less in case the upstream regulator fails to function properly. This device may be either a relief valve or an automatic shutoff that shuts, if the pressure on the inlet of the service regulator exceeds the set pressure (60 p.s.i.g. or less), and remains closed until manually reset.

(2) A service regulator and a monitoring regulator set to limit, to a maximum safe value, the pressure of the gas delivered to the customer.

(3) A service regulator with a relief valve vented to the outside atmosphere, with the relief valve set to open so that the pressure of gas going to the customer does not exceed a maximum safe value. The relief valve may either be built into the service regulator or it may be a separate unit installed downstream from the service regulator. This combination may be used alone only in those cases where the inlet pressure on the service regulator does not exceed the manufacturer's safe working pressure rating of the service regulator, and may not be used where the inlet pressure on the service regulator exceeds 125 p.s.i.g. For higher inlet pressures, the methods in subparagraph (1) or (2) of this paragraph must be used.

(4) A service regulator and an automatic shutoff device that closes upon a rise in pressure downstream from the regulator and remains closed until manually reset.

§ 192.199 Requirements for design of pressure relief and limiting devices.

Each pressure relief or pressure limiting device must—

(a) Be constructed of materials such that the operation of the device will not be impaired by corrosion;

(b) Have valves and valve seats that are designed not to stick in a position that will make the device inoperative;

(c) Be designed and installed so that it can be readily operated to determine if the valve is free, can be tested to determine the pressure at which it will operate, and can be tested for leakage when in the closed position;

(d) Have support made of noncombustible material;

(e) Have discharge stacks, vents, or outlet ports designed to prevent accumulation of water, ice, or snow, located where gas can be discharged into the atmosphere without undue hazard;

(f) Be designed and installed so that the size of the openings, pipes, and fittings located between the system to be protected and the pressure relieving device, and the size of the vent line, are adequate to prevent hammering of the valve and to prevent impairment of relief capacity;

(g) Where installed at a district regulator station to protect a pipeline system from overpressuring, be designed and installed to prevent any single incident such as an explosion in a vault or damage by a vehicle from affecting the operation of both the overpressure protective device and the district regulator; and

(h) Except for a valve that will isolate the system under protection from its source of pressure, be designed to prevent unauthorized operation of any stop valve that will make the pressure relief valve or pressure limiting device inoperative.

§ 192.201 Required capacity of pressure relieving and limiting stations.

(a) Each pressure relief station or pressure limiting station or group of those stations installed to protect a pipeline must have enough capacity, and must be set to operate, to prevent—

(1) The pressure from exceeding the maximum allowable operating pressure plus 10 percent or the pressure that produces a hoop stress of 75 percent of SMYS, whichever is lower; or

(2) In a low-pressure distribution system, a pressure that would cause the unsafe operation of any connected and properly adjusted gas utilization equipment.

(b) When more than one pressure regulating or compressor station feeds into a pipeline, relief valves or other protective devices must be installed at each station to ensure that the complete failure of the largest capacity regulator or compressor, or any single run of lesser capacity regulators or compressors in that station, will not impose pressures on any part of the pipeline or distribution system in excess of those for which it was designed, or against which it was protected, whichever is lower.

(c) Relief valves or other pressure limiting devices must be installed at or near each regulator station in a low-pressure distribution system, with a capacity to limit the maximum pressure in the main to a pressure that will not exceed the safe operating pressure for any connected and properly adjusted gas utilization equipment.

§ 192.203 Instrument, control, and sampling pipe and components.

(a) *Applicability.* This section applies to the design of instrument, control, and sampling pipe and components. It does not apply to permanently closed systems, such as fluid-filled temperature-responsive devices.

(b) *Materials and design.* All materials employed for pipe and components must be designed to meet the particular conditions of service and the following:

(1) Each takeoff connection and attaching boss, fitting, or adapter must be made of suitable material, be able to withstand the maximum service pressure and temperature of the pipe or equipment to which

it is attached, and be designed to satisfactorily withstand all stresses without failure by fatigue.

(2) A shutoff valve must be installed in each takeoff line as near as practicable to the point of takeoff. Blowdown valves must be installed where necessary.

(3) Brass or copper material may not be used for metal temperatures greater than 400° F.

(4) Pipe or components that may contain liquids must be protected by heating or other means from damage due to freezing.

(5) Pipe or components in which liquids may accumulate must have drains or drips.

(6) Pipe or components subject to clogging from solids or deposits must have suitable connections for cleaning.

(7) The arrangement of pipe, components, and supports must provide safety under anticipated operating stresses.

(8) Each joint between sections of pipe, and between pipe and valves or fittings, must be made in a manner suitable for the anticipated pressure and temperature condition. Slip type expansion joints may not be used. Expansion must be allowed for by providing flexibility within the system itself.

(9) Each control line must be protected from anticipated causes of damage and must be designed and installed to prevent damage to any one control line from making both the regulator and the over-pressure protective device inoperative.

Subpart E—Welding of Steel in Pipelines

§ 192.221 Scope.

(a) This subpart prescribes minimum requirements for welding steel materials in pipelines.

(b) This subpart does not apply to welding that occurs during the manufacture of steel pipe or steel pipeline components.

§ 192.223 General.

(a) Welding must be performed in accordance with established written welding procedures that have been qualified under § 192.225 to produce sound, ductile welds.

(b) Welding must be performed by welders who are qualified under §§ 192.227 and 192.229 for the welding procedures to be used.

§ 192.225 Qualifications of welding procedures.

(a) Each welding procedure must be qualified under either section IX of the ASME Boiler and Pressure Vessel Code or section 2 of API Standard 1104, whichever is appropriate to the function of the weld.

(b) When a welding procedure is being qualified under section IX of the ASME Boiler and Pressure Vessel Code, the following steels are considered to fall within the P-Number 1 grouping for the purpose of the essential variable and do not require separate qualification of welding procedures:

(1) Carbon steels that have a carbon content of 0.32 (ladle analysis) or less.

(2) Carbon steels that have a carbon equivalent ($C + \frac{1}{4} Mn$) of 0.65 percent (ladle analysis) or less.

(3) Alloy steels with weldability characteristics that have been shown to be similar to the carbon steels listed in subparagraphs (1) and (2) of this paragraph.

Alloy steels and carbon steels that are not covered by subparagraph (1), (2), or (3) of this paragraph require separate qualification of procedures for each individual pipe specification in accordance with sections VIII and IX of the ASME Boiler and Pressure Vessel Code.

(c) Each welding procedure must be recorded in detail during the qualifying tests. This record must be retained and followed whenever the procedure is used.

§ 192.227 Qualification of welders.

(a) Except as provided in paragraph (c) of this section, each welder must be qualified in accordance with one of the following:

(1) Section IX of the ASME Boiler and Pressure Vessel Code.

(2) Section 3 of API Standard 1104.

(b) When a welder is being qualified under section IX of the ASME Boiler and Pressure Vessel Code, the following steels are considered to fall within the P-Number 1 grouping for the purpose of the essential variables and do not require separate qualification:

(1) Carbon steels that have a carbon content of 0.32 percent (ladle analysis) or less.

(2) Carbon steels that have a carbon equivalent ($C + \frac{1}{4} Mn$) of 0.65 percent (ladle analysis) or less.

(3) Alloy steels with weldability characteristics that have been shown to be similar to the carbon steels listed in subparagraphs (1) and (2) of this paragraph.

Alloy steels and carbon steels that are not covered by subparagraph (1), (2), or (3) of this paragraph require separate qualification of welders for each individual pipe specification in accordance with sections VIII and IX of the ASME Boiler and Pressure Vessel Code.

(c) A welder may qualify to perform welding on pipe to be operated at a pressure that produces a hoop stress of less than 20 percent of SMYS by performing an acceptable test weld, for the process to be used, under the test set forth in section I of Appendix C to this part. A welder who makes welded service line connections to mains must also perform an acceptable test weld under section II of Appendix C to this part as a part of his qualifying test. After initial qualification, a welder may not perform welding unless—

(1) Within the preceding 12 calendar months, he has requalified; or

(2) Within the preceding 6 calendar months he has had—

(i) A production weld cut out, tested and found acceptable in accordance with the qualifying test; or

(ii) For welders who work only on service lines 2 inches or smaller in diameter, two sample welds tested and found acceptable in accordance with the test in section III of Appendix C to this part.

§ 192.229 Limitations on welders.

(a) No welder whose qualification is based on nondestructive testing may weld compressor station pipe and components.

(b) No welder may weld with a particular welding process unless, within the preceding 6 calendar months, he has engaged in welding with that process.

(c) No welder who is qualified under § 192.227(a) may weld unless, within the preceding 6 calendar months, he has had at least one weld tested and found acceptable under either section 3 or 6 of API Standards 1104.

§ 192.231 Protection from weather.

The welding operation must be protected from weather conditions that would impair the quality of the completed weld.

§ 192.233 Miter joints.

(a) A miter joint on steel pipe to be operated at a pressure that produces a hoop stress of 30 percent or more of SMYS may not deflect the pipe more than 3°.

(b) A miter joint on steel pipe to be operated at a pressure that produces a hoop stress of less than 30 percent, but more than 10 percent, of SMYS may not deflect the pipe more than 12½° and must be a distance equal to one pipe diameter or more away from any other miter joint, as measured from the crotch of each joint.

(c) A miter joint on steel pipe to be operated at a pressure that produces a hoop stress of 10 percent or less of SMYS may not deflect the pipe more than 90°.

§ 192.235 Preparation for welding.

Before beginning any welding, the welding surfaces must be clean and free of any material that may be detrimental to the weld, and the pipe or component must be aligned to provide the most favorable condition for depositing the root bead. This alignment must be preserved while the root bead is being deposited.

§ 192.237 Preheating.

(a) Carbon steel that has a carbon content in excess of 0.32 percent (ladle analysis) or a carbon equivalent ($C + \frac{1}{4} Mn$) in excess of 0.65 percent (ladle analysis) must be preheated for welding.

(b) Carbon steel that has a lower carbon content or carbon equivalent than the steels covered by paragraph (a) of this section must be preheated for welding when reheating will alleviate existing conditions that would limit the welding technique or tend to adversely affect the quality of the weld.

(c) When steel materials with different preheat temperatures are being preheated for welding, the higher temperature must be used.

(d) Preheat temperature must be monitored to ensure that the required preheat temperature is reached before, and maintained during, the welding operation.

§ 192.239 Stress relieving.

(a) Except as provided in paragraph (f) of this section, each weld on carbon steel that has a carbon content in excess of 0.32 percent (ladle analysis) or a carbon equivalent ($C + \frac{1}{4} Mn$) in excess of 0.65 percent (ladle analysis) must be stress relieved as prescribed in section VIII of the ASME Boiler and Pressure Vessel Code.

(b) Except as provided in paragraph (f) of this section, each weld on carbon steel that has a carbon content of less than 0.32 percent (ladle analysis) or a carbon equivalent ($C + \frac{1}{4} Mn$) of less than 0.65 percent (ladle analysis) must be thermally stress relieved when conditions exist which cool the weld at a rate detrimental to the quality of the weld.

(c) Except as provided in paragraph (f) of this section, each weld on carbon steel pipe with a wall thickness of more than $1\frac{1}{4}$ inches must be stress relieved.

(d) When a weld connects pipe or components that are of different thickness, the wall thickness to be used in determining whether stress relieving is required under this section is—

(1) In the case of pipe connections, the thicker of the two pipes joined; or

(2) In the case of branch connections, slip-on flanges, or socket weld fittings, the thickness of the pipe run or header.

(e) Each weld of different materials must be stress relieved, if either material requires stress relieving under this section.

(f) Notwithstanding paragraphs (a), (b), and (c) of this section, stress relieving is not required for the following:

(1) A fillet or groove weld one-half inch, or less, in size (leg) that attaches a connection 2 inches, or less, in diameter; or

(2) A fillet or groove weld three-eighths inch, or less, in groove size that attaches a supporting member or other nonpressure attachment.

(g) Stress relieving required by this section must be performed at a temperature of at least 1,100° F. for carbon steels and at least 1,200° F. for ferritic alloy steels. When stress relieving a weld between steel materials with the different stress relieving temperatures, the higher temperature must be used.

(h) When stress relieving, the temperature must be monitored to ensure that a uniform temperature is maintained and that the proper stress relieving cycle is accomplished.

§ 192.241 Inspection and test of welds.

(a) Visual inspection of welding must be conducted to insure that—

(1) The welding is performed in accordance with the welding procedure; and

(2) The weld is acceptable under paragraph (C) of this section.

(b) The welds on a pipeline to be operated at a pressure that produces a hoop stress of 20 percent or more of SMYS must be non-destructively tested in accordance with § 192.243, except that welds that are visually inspected and approved by a qualified welding inspector need not be nondestructively tested if—

- (1) The pipe has a nominal diameter of less than 6 inches; or
 - (2) The pipeline is to be operated at a pressure that produces a hoop stress of less than 40 percent of SMYS and the welds are so limited in number that nondestructive testing is impractical.
- (c) The acceptability of a weld that is nondestructively tested or visually inspected is determined according to the standards in section 6 of API Standard 1104.

§ 192.243 Nondestructive testing.

(a) Nondestructive testing of welds must be performed by any process, other than trepanning, that will clearly indicate defects that may affect the integrity of the weld.

(b) Nondestructive testing of welds must be performed—

- (1) In accordance with written procedures; and
- (2) By persons who have been trained and qualified in the established procedures and with the equipment employed in testing.

(c) Procedures must be established for the proper interpretation of each nondestructive test of a weld to ensure the acceptability of the weld under § 192.241(c).

(d) When nondestructive testing is required under § 192.241(b), the following percentages of each day's field butt welds, selected at random by the operator, must be nondestructively tested over their entire circumference:

- (1) In Class 1 locations, at least 10 percent.
- (2) In Class 2 locations, at least 15 percent.
- (3) In Classes 3 and 4 locations and at crossings of major or navigable rivers, 100 percent if practicable, but not less than 90 percent.
- (4) Within railroad or public highway rights-of-way, including tunnels, bridges and overhead road crossings, and at pipeline tie-ins, 100 percent.

(e) Except for a welder whose work is isolated from the principal welding activity, a sample of each welder's work for each day must be nondestructively tested, when nondestructive testing is required under § 192.241(b).

(f) When nondestructive testing is required under § 192.241(b), each operator must retain, for the life of the pipeline, a record showing by milepost, engineering station, or by geographic feature, the number of girth welds made, the number of nondestructively tested, the number of rejected, and the disposition of the rejects.

§ 192.245 Repair or removal of defects.

(a) Each weld that is unacceptable under § 192.241(c) must be removed or repaired. A weld must be removed if it has a crack that is more than 2 inches long or that penetrates either the root or second bead.

(b) Each weld that is repaired must have the defect removed down to clean metal and the segment to be repaired must be preheated. After repair, the segment of the weld that was repaired must be inspected to insure its acceptability. If the repair is not acceptable, the weld must be removed.

Subpart F—Joining of Materials Other Than by Welding**§ 192.271 Scope.**

(a) This subpart prescribes minimum requirements for joining materials in pipelines, other than by welding.

(b) This subpart does not apply to joining during the manufacture of pipe or pipeline components.

§ 192.273 General.

(a) The pipeline must be designed and installed so that each joint will sustain the longitudinal pullout or thrust forces caused by contraction or expansion of the piping or by anticipated external or internal loading.

(b) Each joint must be made in accordance with written procedures that have been proven by test or experience to produce strong gastight joints.

(c) Each joint must be inspected to insure compliance with this subpart.

§ 192.275 Cast iron pipe.

(a) Each caulked bell and spigot joint in cast iron pipe must be sealed with mechanical leak clamps.

(b) Each mechanical joint in cast iron pipe must have a gasket made of a resilient material as the sealing medium. Each gasket must be suitably confined and retained under compression by a separate gland or follower ring.

(c) Cast iron pipe may not be joined by threaded joints.

(d) Cast iron pipe may not be joined by brazing.

(e) Each flange on a flanged joint in cast iron pipe must conform in dimensions and drilling to ANSI Standard B16.1 and be cast integrally with the pipe, valve, or fitting.

§ 192.277 Ductile iron pipe.

(a) Each mechanical joint in ductile iron pipe must conform to ANSI Standard A21.52 and ANSI Standard A21.11.

(b) Ductile iron pipe may not be joined by threaded joints.

(c) Ductile iron pipe may not be joined by brazing.

§ 192.279 Copper pipe.

Copper pipe may not be threaded, except that copper pipe used for joining screw fittings or valves may be threaded if the wall thickness is equivalent to the comparable size of standard wall pipe, as defined in ANSI Standard B36.10.

§ 192.281 Plastic pipe.

(a) *General.* Each plastic pipe joint must be made in accordance with written procedures that have been proven by destructive burst test to produce joints at least as strong as the pipe being joined. A plastic pipe joint that is joined by solvent cement, adhesive, or heat fusion may not be disturbed until it has properly set. Plastic pipe may not be joined by a threaded joint or miter joint.

(b) *Solvent cement joints.* Each solvent cement joint on plastic pipe must comply with the following:

(1) The mating surfaces of the joint must be clean, dry, and free of material which might be detrimental to the joint.

(2) The solvent cement must conform to ASTM Specification D 2513.

(3) The safety requirements of Appendix A of ASTM Specification D 2513 must be met.

(4) The joint may not be heated to accelerate the setting of the cement.

(c) *Heat-fusion joints.* Each heat-fusion joint on plastic pipe must comply with the following:

(1) A butt heat-fusion joint must be joined by a device that holds the heater element square to the ends of the piping, compresses the heated ends together, and holds the pipe in proper alignment while the plastic hardens.

(2) A socket heat-fusion joint must be joined by a device that heats the mating surfaces of the joint uniformly and simultaneously to essentially the same temperature.

(3) Heat may not be applied with a torch or other open flame.

(d) *Adhesive joints.* Each adhesive joint on plastic pipe must comply with the following:

(1) The adhesive must conform to ASTM Specification D 2517.

(2) The materials and adhesive must be compatible with each other.

(e) *Mechanical joints.* Each compression type mechanical joint on plastic pipe must comply with the following:

(1) The gasket material in the coupling must be compatible with the plastic.

(2) A rigid internal tubular stiffener, other than a split tubular stiffener, must be used in conjunction with the coupling.

Subpart G—General Construction Requirements for Transmission Lines and Mains

§ 192.301 Scope.

This subpart prescribes minimum requirements for constructing transmission lines and mains.

§ 192.303 Compliance with specifications or standards.

Each transmission line or main must be constructed in accordance with comprehensive written specifications or standards that are consistent with this part.

§ 192.305 Inspection: general.

Each transmission line or main must be inspected to ensure that it is constructed in accordance with this part.

§ 192.307 Inspection of materials.

Each length of pipe and each other component must be visually inspected at the site of installation to ensure that it has not sustained any visually determinable damage that could impair its serviceability.

§ 192.309 Repair of steel pipe.

(a) Each imperfection or damage that impairs the serviceability of a length of steel pipe must be repaired or removed. If a repair is made by grinding, the remaining wall thickness must at least be equal to either:

(1) The minimum thickness required by the tolerances in the specification to which the pipe was manufactured; or

(2) The nominal wall thickness required for the design pressures of the pipeline.

(b) Each of the following dents must be removed from steel pipe to be operated at a pressure that produces a hoop stress of 20 percent, or more, of SMYS:

(1) A dent that contains a stress concentrator such as a scratch, gouge, groove, or arc burn.

(2) A dent that affects the longitudinal weld or a circumferential weld.

(3) In pipe to be operated at a pressure that produces a hoop stress of 40 percent or more of SMYS, a dent that has a depth of—

(i) More than one-quarter inch in pipe 12¼ inches or less in outer diameter; or

(ii) More than 20 percent of the nominal pipe diameter in pipe over 12¼ inches in outer diameter.

For the purpose of this section a "dent" is a depression that produces a gross disturbance in the curvature of the pipe wall without reducing the pipe-wall thickness. The depth of a dent is measured as the gap between the lowest point of the dent and a prolongation of the original contour of the pipe.

(c) Each arc burn on steel pipe to be operated at a pressure that produces a hoop stress of 40 percent, or more, of SMYS must be repaired or removed. If a repair is made by grinding, the arc burn must be completely removed and the remaining wall thickness must be at least equal to either:

(1) The minimum wall thickness required by the tolerances in the specification to which the pipe was manufactured; or

(2) The nominal wall thickness required for the design pressure of the pipeline.

(d) A gouge, groove, arc burn, or dent may not be repaired by insert patching or by pounding out.

(e) Each gouge, groove, arc burn, or dent that is removed from a length of pipe must be removed by cutting out the damaged portion as a cylinder.

§ 192.311 Repair of plastic pipe.

Each imperfection or damage that would impair the serviceability of plastic pipe must be repaired by a patching saddle or removed.

§ 192.313 Bends and elbows.

(a) Each field bend in steel pipe, other than a wrinkle bend made in accordance with § 192.315, must comply with the following:

(1) A bend may not impair the serviceability of the pipe.

(2) On pipe containing a longitudinal weld, the longitudinal seam must be as near as practicable to the neutral axis of the bend.

(3) A bend on pipe that is 12 inches, or more, in nominal diameter must not deflect the pipe more than $1\frac{1}{2}^\circ$ in any length of pipe equal to the diameter.

(4) For pipe more than 4 inches in nominal diameter, the difference between the maximum and minimum diameter at a bend may not be more than $2\frac{1}{2}$ percent of the nominal diameter.

(b) Each circumferential weld of steel pipe that is subjected to stress during bending must be nondestructively tested.

(c) Wrought-steel welding elbows and transverse segments of these elbows may not be used for changes in direction on steel pipe that is 2 inches or more in diameter unless the arc length, as measured along the crotch, is at least 1 inch.

(d) Each bend, other than a wrinkle bend made in accordance with § 192.315, must have a smooth contour and be free of mechanical damage.

§ 192.315 Wrinkle bends in steel pipe.

(a) A wrinkle bend may not be made on steel pipe to be operated at a pressure that produces a hoop stress of 30 percent, or more, of SMYS.

(b) Each wrinkle bend on steel pipe must comply with the following:

(1) The bend must not have any sharp kinks.

(2) When measured along the crotch of the bend, the wrinkles must be a distance of at least one pipe diameter.

(3) On pipe 16 inches or larger in diameter, the bend may not have a deflection of more than $1\frac{1}{2}^\circ$ for each wrinkle.

(4) On pipe containing a longitudinal weld the longitudinal seam must be as near as practicable to the neutral axis of the bend.

§ 192.317 Protection from hazards.

(a) Each transmission line or main must be protected from wash-outs, floods, unstable soil, landslides, or other hazards that may cause the pipe to move or to sustain abnormal loads.

(b) Each transmission line or main that is constructed above ground must be protected from accidental damage by vehicular traffic or other similar causes, either by being placed at a safe distance from the traffic or by installing barricades.

§ 192.319 Installation of pipe in a ditch.

(a) When installed in a ditch, each transmission line that is to be operated at a pressure producing a hoop stress of 20 percent or more of SMYS must be installed so that the pipe fits the ditch so as to minimize stresses and protect the pipe coating from damage.

(b) Each ditch for a transmission line or main must be backfilled in a manner that—

(1) Provides firm support under the pipe; and

(2) Prevents damage to the pipe and pipe coating from equipment or from the backfill material.

§ 192.321 Installation of plastic pipe.

- (a) Plastic pipe must be installed below ground level.
- (b) Plastic pipe that is installed in a vault or any other below grade enclosure must be completely encased in gas-tight metal pipe and fittings that are adequately protected from corrosion.
- (c) Plastic pipe must be installed so as to minimize shear or tensile stresses.
- (d) Thermoplastic pipe that is not encased must have a minimum wall thickness of 0.090 inches, except that pipe with an outside diameter of 0.875 inches or less may have a minimum wall thickness of 0.062 inches.
- (e) Plastic pipe that is not encased must have an electrically conductive wire or other means of locating the pipe while it is underground.
- (f) Plastic pipe that is being encased must be inserted into the casing pipe in a manner that will protect the plastic. The leading end of the plastic must be closed before insertion.

§ 192.323 Casing.

Each casing used on a transmission line or main under a railroad or highway must comply with the following:

- (a) The casing must be designed to withstand the superimposed loads.
- (b) If there is a possibility of water entering the casing, the ends must be sealed.
- (c) If the ends of an unvented casing are sealed and the sealing is strong enough to retain the maximum allowable operating pressure of the pipe, the casing must be designed to hold this pressure at a stress level of not more than 72 percent of SMYS.
- (d) If vents are installed on a casing, the vents must be protected from the weather to prevent water from entering the casing.

§ 192.325 Underground clearance.

- (a) Each transmission line must be installed with at least 12 inches of clearance from any other underground structure not associated with the transmission line. If this clearance cannot be attained, the transmission line must be protected from damage that might result from the proximity of the other structure.
- (b) Each main must be installed with enough clearance from any other underground structure to allow proper maintenance and to protect against damage that might result from proximity to other structures.
- (c) In addition to meeting the requirements of paragraph (a) or (b) of this section, each plastic transmission line or main must be installed with sufficient clearance, or must be insulated, from any source of heat so as to prevent the heat from impairing the serviceability of the pipe.

(d) Each pipe-type or bottle-type holder must be installed with a minimum clearance from any other holder as prescribed in § 192.175 (b).

§ 192.327 **Cover.**

(a) Except as provided in paragraph (c) of this section, each buried transmission line must be installed with a minimum cover as follows:

Location	Normal soil	Consolidated rock
	Inches	Inches
Class 1 locations.....	30	18
Class 2, 3, and 4 locations.....	36	24
Drainage ditches of public roads and railroad crossings.....	36	24

(b) Except as provided in paragraphs (c) and (d) of this section, each buried main must be installed with at least 24 inches of cover.

(c) Where an underground structure prevents the installation of a transmission line or main with the minimum cover, the transmission line or main may be installed with less cover if it is provided with additional protection to withstand anticipated external loads.

(d) A main may be installed with less than 24 inches of cover if the law of the State or municipality—

- (1) Establishes a minimum cover of less than 24 inches;
- (2) Requires that mains be installed in a common trench with other utility lines; and
- (3) Provides adequately for prevention of damage to the pipe by external forces.

Subpart H—Customer Meters, Service Regulators, and Service Lines

§ 192.351 **Scope.**

This subpart prescribes minimum requirements for installing customer meters, service regulators, service lines, service line valves, and service line connections to mains.

§ 192.353 **Customer meters and regulators: location.**

(a) Each meter and service regulator, whether inside or outside of a building, must be installed in a readily accessible location and be protected from corrosion and other damage. However, the upstream regulator in a series may be buried.

(b) Each service regulator installed within a building must be located as near as practical to the point of service line entrance.

(c) Each meter installed within a building must be located in a ventilated place and not less than 3 feet from any source of ignition or any source of heat which might damage the meter.

(d) Where feasible, the upstream regulator in a series must be located outside the building, unless it is located in a separate metering or regulated building.

§ 192.355 Customer meters and regulators: protection from damage.

(a) *Protection from vacuum or back pressure.* If the customer's equipment might create either a vacuum or a back pressure, a device must be installed to protect the system.

(b) *Service regulator vents and relief vents.* The outside terminal of each service regulator vent and relief vent must—

(1) Be rain and insect resistant;

(2) Be located at a place where gas from the vent can escape freely into the atmosphere and away from any opening into the building; and

(3) Be protected from damage caused by submergence in areas where flooding may occur.

(c) *Pits and vaults.* Each pit or vault that houses a customer meter or regulator at a place where vehicular traffic is anticipated, must be able to support that traffic.

§ 192.357 Customer meters and regulators: installation.

(a) Each meter and each regulator must be installed so as to minimize anticipated stresses upon the connecting piping and the meter.

(b) When close all-thread nipples are used, the wall thickness remaining after the threads are cut must meet the minimum wall thickness requirements of this part.

(c) Connections made of lead or other easily damaged material may not be used in the installation of meters or regulators.

(d) Each regulator that might release gas in its operation must be vented to the outside atmosphere.

§ 192.359 Customer meter installations: operating pressure.

(a) A meter may not be used at a pressure that is more than 67 percent of the manufacturer's shell test pressure.

(b) Each new meter must have been tested by the manufacturer to a minimum of 10 p.s.i.g.

(c) A rebuilt or repaired tinned steel case meter may not be used at a pressure that is more than 50 percent of the pressure used to test the meter after rebuilding or repairing.

§ 192.361 Service lines: installation.

(a) *Depth.* Each buried service line must be installed with at least 12 inches of cover in private property and at least 18 inches of cover in streets and roads. However, where an underground structure prevents installation at those depths, the service line must be able to withstand any anticipated external load.

(b) *Support and backfill.* Each service line must be properly supported on undisturbed or well-compacted soil, and material used for backfill must be free of materials that could damage the pipe or its coating.

(c) *Grading for drainage.* Where condensate in the gas might cause interruption in the gas supply to the customer, the service line must be graded so as to drain into the main or into drips at the low points in the service line.

(d) *Protection against piping strain and external loading.* Each service line must be installed so as to minimize anticipated piping strain and external loading.

(e) *Installation of service lines into buildings.* Each underground service line installed below grade through the outer foundation wall of a building must—

(1) In the case of a metal service line, be protected against corrosion;

(2) In the case of a plastic service line, be protected from shearing action and backfill settlement; and

(3) Be sealed at the foundation wall to prevent leakage into the building.

(f) *Installation of service lines under buildings.* Where an underground service line is installed under a building—

(1) It must be encased in a gas-tight conduit;

(2) The conduit and the service line must, if the service line supplies the building it underlies, extend into a normally usable and accessible part of the building; and

(3) The space between the conduit and the service line must be sealed to prevent gas leakage into the building and, if the conduit is sealed at both ends, a vent line from the annular space must extend to a point where gas would not be a hazard, and extend above grade, terminating in a rain and insect resistant fitting.

§ 192.363 Service lines; valve requirements.

(a) Each service line must have a service-line valve that meets the applicable requirements of subparts B and D of this part. A valve incorporated in a meter bar, that allows the meter to be bypassed, may not be used as a service-line valve.

(b) A soft seat service line valve may not be used if its ability to control the flow of gas could be adversely affected by exposure to anticipated heat.

(c) Each service-line valve on a high-pressure service line, installed above ground or in an area where the blowing of gas would be hazardous, must be designed and constructed to minimize the possibility of the removal of the core of the valve with other than specialized tools.

§ 192.365 Service lines: location of valves.

(a) *Relation to regulator or meter.* Each service-line valve must be installed upstream of the regulator or, if there is no regulator, upstream of the meter.

(b) *Outside valves.* Each service line must have a shut-off valve in a readily accessible location that, if feasible, is outside of the building.

(c) *Underground valves.* Each underground service-line valve must be located in a covered durable curb box or standpipe that allows ready operation of the valve and is supported independently of the service lines.

§ 192.367 Service lines: general requirements for connections to main piping.

(a) *Location.* Each service-line connection to a main must be located at the top of the main or, if that is not practical, at the side of the main, unless a suitable protective device is installed to mini-

mize the possibility of dust and moisture being carried from the main into the service line.

(b) *Compression-type connection to main.* Each compression-type service line to main connection must—

(1) Be designed and installed to effectively sustain the longitudinal pull-out or thrust forces caused by contraction or expansion of the piping, or by anticipated external or internal loading; and

(2) If gaskets are used in connecting the service line to the main connection fitting, have gaskets that are compatible with the kind of gas in the system.

§ 192.369 Service lines: connections to cast iron or ductile iron mains.

(a) Each service line connected to a cast iron or ductile iron main must be connected by a mechanical clamp, by drilling and tapping the main, or by another method meeting the requirements of § 192.273.

(b) If a threaded tap is being inserted, the requirements of § 192.151 (b) and (c) must also be met.

§ 192.371 Service lines: steel.

Each steel service line to be operated at less than 100 p.s.i.g. must be designed for a minimum of 100 p.s.i.g.

§ 192.373 Service lines: cast iron and ductile iron.

(a) Cast iron or ductile iron pipe less than 6 inches in diameter may not be installed for service lines.

(b) If cast iron pipe or ductile iron pipe is installed for use as a service line, the part of the service line which extends through the building wall must be of steel pipe.

(c) A cast iron or ductile iron service line may not be installed in unstable soil or under a building.

§ 192.375 Service lines: plastic.

(a) Each plastic service line outside a building must be installed below ground level, except that it may terminate above ground and outside the building, if—

(1) The above ground part of the plastic service line is protected against deterioration and external damage; and

(2) The plastic service line is not used to support external loads.

(b) Each plastic service line inside a building must be protected against external damage.

§ 192.377 Service lines: copper.

Each copper service line installed within a building must be protected against external damage.

Subpart I—[Reserved]

Subpart J—Test Requirements

§ 192.501 Scope.

This subpart prescribes minimum leak-test and strength-test requirements for pipelines.

§ 192.503 General requirements.

(a) No person may operate a new segment of pipeline, or return to service a segment of pipeline that has been relocated or replaced, until—

(1) It has been tested in accordance with this subpart to substantiate the proposed maximum allowable operating pressure; and

(2) Each potentially hazardous leak has been located and eliminated.

(b) The test medium must be liquid, air, natural gas, or inert gas that is—

(1) Compatible with the material of which the pipeline is constructed;

(2) Relatively free of sedimentary materials; and

(3) Except for natural gas, nonflammable.

(c) Except as provided in § 192.505 (a), if air, natural gas, or inert gas is used as the test medium, the following maximum hoop stress limitations apply:

Class location	Maximum hoop stress allowed as percentage of SMYS	
	Natural gas	Air or inert gas
1.-----	80	80
2.-----	80	75
3.-----	80	50
4.-----	80	40

(d) Each weld used to tie-in a test segment of pipeline is excepted from the test requirements of this subpart.

§ 192.505 Strength test requirements for steel pipeline to operate at a hoop stress of 30 percent or more of SMYS.

(a) Except for service lines, each segment of a steel pipeline that is to operate at a hoop stress of 30 percent or more of SMYS must be strength tested in accordance with this section to substantiate the proposed maximum allowable operating pressure. In addition, in a Class 1 or Class 2 location, if there is a building intended for human occupancy within 300 feet of a pipeline, a hydrostatic test must be conducted to a test pressure of at least 125 percent of maximum operating pressure on that segment of the pipeline within 300 feet of such a building, but in no event may the test section be less than 600 feet unless the length of the newly installed or relocated pipe is less than 600 feet. However, if the buildings are evacuated while the hoop stress exceeds 50 percent of SMYS, air or inert gas may be used as the test medium.

(b) In a Class 1 or Class 2 location, each compressor station, regulator station, and measuring station, must be tested to at least Class 3 location test requirements.

(c) Except as provided in paragraph (e) of this section, the strength test must be conducted by maintaining the pressure at or above the test pressure for at least 8 hours.

(d) If a component other than pipe is the only item being replaced or added to a pipeline, a strength test after installation is not required, if the manufacturer of the component certifies that—

(1) The component was tested to at least the pressure required for the pipeline to which it is being added; or

(2) The component was manufactured under a quality control system that ensures that each item manufactured is at least equal in strength to a prototype and that the prototype was tested to at least the pressure required for the pipeline to which it is being added.

(e) For fabricated units and short sections of pipe, for which a post installation test is impractical, a preinstallation strength test must be conducted by maintaining the pressure at or above the test pressure for at least 4 hours.

§ 192.507 Test requirements for pipelines to operate at a hoop stress less than 30 percent of SMYS and above 100 p.s.i.g.

Except for service lines and plastic pipelines, each segment of a pipeline that is to be operated at a hoop stress less than 30 percent of SMYS and above 100 p.s.i.g. must be tested in accordance with the following:

(a) The pipeline operator must use a test procedure that will ensure discovery of all potentially hazardous leaks in the segments being tested.

(b) If, during the test, the segment is to be stressed to 20 percent or more of SMYS and natural gas, inert gas, or air is the test medium—

(1) A leak test must be made at a pressure between 100 p.s.i.g. and the pressure required to produce a hoop stress of 20 percent of SMYS; or

(2) The line must be walked to check for leaks while the hoop stress is held at approximately 20 percent of SMYS.

(c) The pressure must be maintained at or above the test pressure for at least 1 hour.

§ 192.509 Test requirements for pipelines to operate at or below 100 p.s.i.g.

Except for service lines and plastic pipelines, each segment of a pipeline that is to be operated at or below 100 p.s.i.g. must be leak tested in accordance with the following:

(a) The test procedure used must ensure discovery of all potentially hazardous leaks in the segment being tested.

(b) Each main that is to be operated at less than 1 p.s.i.g. must be tested to at least 10 p.s.i.g. and each main to be operated at or above 1 p.s.i.g. must be tested to at least 90 p.s.i.g.

§ 192.511 Test requirements for service lines.

(a) Each segment of a service line (other than plastic) must be leak tested in accordance with this section before being placed in service. If feasible, the service-line connection to the main must be included in the test; if not feasible, it must be given a leakage test at the operating pressure when placed in service.

(b) Each segment of a service line (other than plastic) intended to be operated at a pressure of at least 1 p.s.i.g. but not more than 40 p.s.i.g. must be given a leak test at a pressure of not less than 50 p.s.i.g.

(c) Each segment of a service line (other than plastic) intended to be operated at pressures of more than 40 p.s.i.g. must be tested to at least 90 p.s.i.g., except that each segment of a steel service line stressed to 20 percent or more of SMYS must be tested in accordance with § 192.507 of this subpart.

§ 192.513 Test requirements for plastic pipelines.

(a) Each segment of a plastic pipeline must be tested in accordance with this section.

(b) The test procedure must insure discovery of all potentially hazardous leaks in the segment being tested.

(c) The test pressure must be at least 150 percent of the maximum operating pressure or 50 p.s.i.g., whichever is greater. However, the maximum test pressure may not be more than three times the design pressure of the pipe.

(d) The temperature of thermoplastic material must not be more than 100° F. during the test.

§ 192.515 Environmental protection and safety requirements.

(a) In conducting tests under this subpart, each operator shall insure that every reasonable precaution is taken to protect its employees and the general public during the testing. Whenever the hoop stress of the segment of the pipeline being tested will exceed 50 percent of SMYS, the operator shall take all practicable steps to keep persons not working on the testing operation outside of the testing area until the pressure is reduced to or below the proposed maximum allowable operating pressure.

(b) The operator shall insure that the test medium is disposed of in a manner that will minimize damage to the environment.

§ 192.517 Records.

Each operator shall make, and retain for the useful life of the pipeline, a record of each test performed under §§ 192.505 and 192.507. The record must contain at least the following information:

(a) The operator's name, the name of the operator's employee responsible for making the test, and the name of any test company used.

(b) Test medium used.

(c) Test pressure.

(d) Test duration.

(e) Pressure recording charts, or other record of pressure readings.

(f) Elevation variations, whenever significant for the particular test.

(g) Leaks and failures noted and their disposition.

Subpart K—Uprating

§ 192.551 Scope.

This subpart prescribes minimum requirements for increasing maximum allowable operating pressures (uprating) for pipelines.

§ 192.553 General requirements.

(a) *Pressure increases.* Whenever the requirements of this subpart require that an increase in operating pressure be made in increments, the pressure must be increased gradually, at a rate that can be controlled, and in accordance with the following:

(1) At the end of each incremental increase, the pressure must be held constant while the entire segment of pipeline that is affected is checked for leaks.

(2) Each leak detected must be repaired before a further pressure increase is made, except that a leak determined not to be potentially hazardous need not be repaired, if it is monitored during the pressure increase and it does not become potentially hazardous.

(b) *Records.* Each operator who uprates a segment of pipeline shall retain for the life of the segment a record of each investigation required by this subpart, of all work performed, and of each pressure test conducted, in connection with the uprating.

(c) *Written plan.* Each operator who uprates a segment of pipeline shall establish a written procedure that will ensure that each applicable requirement of this subpart is complied with.

(d) *Limitation on increase in maximum allowable operating pressure.* Except as provided in § 192.555 (c), a new maximum allowable operating pressure established under this subpart may not exceed the maximum that would be allowed under this part for a new segment of pipeline constructed of the same materials in the same location.

§ 192.555 Uprating to a pressure that will produce a hoop stress of 30 percent or more of SMYS in steel pipelines.

(a) Unless the requirements of this section have been met, no person may subject any segment of a steel pipeline to an operating pressure that will produce a hoop stress of 30 percent or more of SMYS and that is above the established maximum allowable operating pressure.

(b) Before increasing operating pressure above the previously established maximum allowable operating pressure the operator shall—

(1) Review the design, operating, and maintenance history and previous testing of the segment of pipeline and determine whether the proposed increase is safe and consistent with the requirements of this part; and

(2) Make any repairs, replacements, or alterations in the segment of pipeline that are necessary for safe operation at the increased pressure.

(c) After complying with paragraph (b) of this section, an operator may increase the maximum allowable operating pressure of a segment of pipeline constructed before September 12, 1970, to the highest pressure that is permitted under § 192.619, using as test pressure the highest pressure to which the segment of pipeline was previously subjected (either in a strength test or in actual operation).

(d) After complying with paragraph (b) of this section, an operator that does not qualify under paragraph (c) of this section may increase the previously established maximum allowable operating pressure if at least one of the following requirements is met:

(1) The segment of pipeline is successfully tested in accordance with the requirements of this part for a new line of the same material in the same location.

(2) An increased maximum allowable operating pressure may be established for a segment of pipeline in a Class 1 location if the line has not previously been tested, and if—

(i) It is impractical to test it in accordance with the requirements of this part;

(ii) The new maximum operating pressure does not exceed 80 percent of that allowed for a new line of the same design in the same location; and

(iii) The operator determines that the new maximum allowable operating pressure is consistent with the condition of the segment of pipeline and the design requirements of this part.

(e) Where a segment of pipeline is uprated in accordance with paragraph (c) or (d) (2) of this section, the increase in pressure must be made in increments that are equal to—

(1) 10 percent of the pressure before the uprating; or

(2) 25 percent of the total pressure increase, whichever produces the fewer number of increments.

§ 192.557 Uprating: steel pipelines to a pressure that will produce a hoop stress less than 30 percent of SMYS; plastic, cast iron, and ductile iron pipelines.

(a) Unless the requirements of this section have been met, no person may subject—

(1) A segment of steel pipeline to an operating pressure that will produce a hoop stress less than 30 percent of SMYS and that is above the previously established maximum allowable operating pressure; or

(2) A plastic, cast iron, or ductile iron pipeline segment to an operating pressure that is above the previously established maximum allowable operating pressure.

(b) Before increasing operating pressure above the previously established maximum allowable operating pressure, the operator shall—

(1) Review the design, operating, and maintenance history of the segment of pipeline;

(2) Make a leakage survey (if it has been more than 1 year since the last survey) and repair any leaks that are found, except that a leak determined not to be potentially hazardous need not be repaired, if it is monitored during the pressure increase and it does not become potentially hazardous;

(3) Make any repairs, replacements, or alterations in the segment of pipeline that are necessary for safe operation at the increased pressure;

(4) Reinforce or anchor offsets, bends and dead ends in pipe joined by compression couplings or bell and spigot joints to prevent failure of the pipe joint, if the offset, bend, or dead end is exposed in an excavation;

(5) Isolate the segment of pipeline in which the pressure is to be increased from any adjacent segment that will continue to be operated at a lower pressure; and

(6) If the pressure in mains or service lines, or both, is to be higher than the pressure delivered to the customer, install a service regulator on each service line and test each regulator to determine that it is functioning. Pressure may be increased as necessary to test each regulator, after a regulator has been installed on each pipeline subject to the increased pressure.

(c) After complying with paragraph (b) of this section, the increase in maximum allowable operating pressure must be made in increments that are equal to 10 p.s.i.g. or 25 percent of the total pressure increase, whichever produces the fewer number of increments. Whenever the requirements of paragraph (b) (6) of this section apply, there must be at least two approximately equal incremental increases.

(d) If records for cast iron or ductile iron pipeline facilities are not complete enough to ascertain compliance with § 192.117 or § 192.119, as applicable, the following procedures must be followed:

(1) If the original laying conditions cannot be ascertained, the operator shall assume, when applying the design formulas of ANSI A21.1, that cast iron pipe was supported on blocks with tamped backfill and, when applying the design formulas of ANSI A21.50, that ductile iron pipe was laid without blocks with tamped backfill.

(2) Unless the actual maximum cover depth is known, the operator shall measure the actual cover in at least three places where the cover is most likely to be greatest and shall use the greatest cover measured.

(3) Unless the actual nominal wall thickness is known, the operator shall determine the wall thickness by cutting and measuring coupons from at least three separate pipe lengths. The coupons must be cut from pipe lengths in areas where the cover depth is most likely to be the greatest. The average of all measurements taken must be increased by the allowance indicated in the following table:

Pipe size (inches)	Allowance (inches)		
	Cast iron pipe		
	Pit cast pipe	Centrifugally cast pipe	Ductile iron pipe
3-8.....	0.075	0.065	0.065
10-12.....	0.08	0.07	0.07
14-24.....	0.08	0.08	0.075
30-42.....	0.09	0.09	0.075
48.....	0.09	0.09	0.08
54-60.....	0.09	-----	-----

NOTE.—The nominal wall thickness of the cast iron is the standard thickness listed in table 10 or table 11, as applicable, of ANSI A21.1 nearest the value obtained under this subparagraph. The nominal wall thickness of ductile iron pipe is the standard thickness listed in table 6 of ANSI A21.50 nearest the value obtained under this subparagraph.

(4) For cast iron pipe, unless the pipe manufacturing process is known, the operator shall assume that the pipe is pit case pipe with a bursting tensile strength of 11,000 p.s.i. and a modulus of rupture of 31,000 p.s.i.

Subpart L—Operations**§ 192.601 Scope.**

This subpart prescribes minimum requirements for the operation of pipeline facilities.

§ 192.603 General provisions.

(a) No person may operate a segment of pipeline unless it is operated in accordance with this subpart.

(b) Each operator shall establish a written operating and maintenance plan meeting the requirements of this part and keep records necessary to administer the plan.

§ 192.605 Essentials of operating and maintenance plan.

Each operator shall include the following in its operating and maintenance plan:

(a) Instructions for employees covering operating and maintenance procedures during normal operations and repairs.

(b) Items required to be included by the provisions of Subpart M of this part.

(c) Specific programs relating to facilities presenting the greatest hazard to public safety either in an emergency or because of extraordinary construction or maintenance requirements.

(d) A program for conversion procedures, if conversion of a low-pressure distribution system to a higher pressure is contemplated.

(e) Provision for periodic inspections to ensure that operating pressures are appropriate for the class location.

§ 192.607 Initial determination of class location and confirmation or establishment of maximum allowable operating pressure.

(a) Before April 15, 1971, each operator shall complete a study to determine for each segment of pipeline with a maximum allowable operating pressure that will produce a hoop stress that is more than 40 percent of SMYS—

(1) The present class location of all such pipeline in its system; and

(2) Whether the hoop stress corresponding to the maximum allowable operating pressure for each segment of pipeline is commensurate with the present class location.

(b) If an operator finds that the hoop stress corresponding to the established maximum allowable operating pressure of a segment of pipeline is not commensurate with the present class location and the segment is in satisfactory physical condition, the operator shall confirm or revise the maximum allowable operating pressure of the affected segment of pipeline as required by § 192.611 in accordance with the following schedule:

(1) Before January 1, 1972, the operator shall complete the confirmation or revision of at least 50 percent of the affected pipelines.

(2) Before January 1, 1973, the operator shall complete the confirmation or revision of the remainder of the affected pipelines.

§ 192.609 Change in class location: required study.

Whenever an increase in population density indicates a change in class location for a segment of an existing steel pipeline operating at hoop stress that is more than 40 percent of SMYS, or indicates that the hoop stress corresponding to the established maximum allowable operating pressure for a segment of existing pipeline is not commensurate with the present class location, the operator shall immediately make a study to determine—

- (a) The present class location for the segment involved.
- (b) The design, construction, and testing procedures followed in the original construction, and a comparison of these procedures with those required for the present class location by the applicable provisions of this part.
- (c) The physical condition of the segment to the extent it can be ascertained from available records;
- (d) The operating and maintenance history of the segment;
- (e) The maximum actual operating pressure and the corresponding operating hoop stress, taking pressure gradient into account, for the segment of pipeline involved; and
- (f) The actual area affected by the population density increase, and physical barriers or other factors which may limit further expansion of the more densely populated area.

§ 192.611 Change in class location: confirmation or revision of maximum allowable operating pressure.

If the hoop stress corresponding to the established maximum allowable operating pressure of a segment of pipeline is not commensurate with the present class location, and the segment is in satisfactory physical condition, the maximum allowable operating pressure of that segment of pipeline must be confirmed or revised as follows:

- (a) If the segment involved has been previously tested in place to at least 90 percent of its SMYS for a period of not less than 8 hours, the maximum allowable operating pressure must be confirmed or reduced so that the corresponding hoop stress will not exceed 72 percent of SMYS of the pipe in Class 2 locations, 60 percent of SMYS in Class 3 locations, or 50 percent of SMYS in Class 4 locations.
- (b) If the segment involved has not been previously tested in place as described in paragraph (a) of this section, the maximum allowable operating pressure must be reduced so that the corresponding hoop stress is not more than that allowed by this part for new segments of pipelines in the existing class location.
- (c) If the segment of pipeline involved has not been qualified for operation under paragraph (a) or (b) of this section, it must be tested in accordance with the applicable requirements of Subpart J of this part, and its maximum allowable operating pressure must then be established so as to be equal to or less than the following:
 - (1) The maximum allowable operating pressure after the requalification test is 0.8 times the test pressure for Class 2 locations, 0.667 times the test pressure for Class 3 locations, and 0.555 times the test pressure for Class 4 locations.
 - (2) The maximum allowable operating pressure confirmed or revised in accordance with this section, may not exceed the maximum

allowable operating pressure established before the confirmation or revision.

(3) The corresponding hoop stress may not exceed 72 percent of the SMYS of the pipe in Class 2 locations, 60 percent of SMYS in Class 3 locations, or 50 percent of the SMYS in Class 4 locations.

(d) Confirmation or revision of the maximum allowable operating pressure of a segment of pipeline in accordance with this section does not preclude the application of §§ 192.553 and 192.555.

(e) After completing the study required by § 192.609, the operator shall confirm or revise the maximum allowable operating pressure in each segment of pipeline in accordance with this section within 1 year of the date when a change in class location has occurred.

§ 192.613 Continuing surveillance.

(a) Each operator shall have a procedure for continuing surveillance of its facilities to determine and take appropriate action concerning changes in class location, failures, leakage history, corrosion, substantial changes in cathodic protection requirements, and other unusual operating and maintenance conditions.

(b) If a segment of pipeline is determined to be in unsatisfactory condition but no immediate hazard exists, the operator shall initiate a program to recondition or phase out the segment involved, or, if the segment cannot be reconditioned or phased out, reduce the maximum allowable operating pressure in accordance with §192.619 (a) and (b).

§ 192.615 Emergency plans.

Each operator shall—

(a) Have written emergency procedures;

(b) Acquaint appropriate operating and maintenance employees with the procedures;

(c) Establish liaison with appropriate public officials, including fire and police officials, with respect to the procedures; and

(d) Establish an educational program to enable customers and the general public to recognize and report a gas emergency to the appropriate officials.

§ 192.617 Investigation of failures.

Each operator shall establish procedures for analyzing accidents and failures, including the selection of samples of the failed facility or equipment for laboratory examination, where appropriate, for the purpose of determining the causes of the failure and minimizing the possibility of a recurrence.

§ 192.619 Maximum allowable operating pressure: steel or plastic pipelines.

(a) Except as provided in paragraph (c) of this section, no person may operate a segment of steel or plastic pipeline at a pressure that exceeds the lowest of the following:

(1) The design pressure of the weakest element in the segment, determined in accordance with Subparts C and D of this part.

(2) The pressure obtained by dividing the pressure to which the segment was tested after construction as follows:

(i) For plastic pipe in all locations, the test pressure is divided by a factor of 1.5.

(ii) For steel pipe, the test pressure is divided by a factor determined in accordance with the following table:

Class location	Factor	
	Segment installed before (Nov. 12, 1970)	Segment installed after (Nov. 11, 1970)
1-----	1.1	1.1
2-----	1.25	1.25
3-----	1.4	1.5
4-----	1.4	1.5

(3) The highest actual operating pressure to which the segment was subjected during the 5 years preceding July 1, 1970, unless the segment was tested in accordance with paragraph (a) (2) of this section after July 1, 1965, or the segment was uprated in accordance with Subpart K of this part.

(4) For furnace butt welded steel pipe, a pressure equal to 60 percent of the mill test pressure to which the pipe was subjected.

(5) For steel pipe other than furnace butt welded pipe, a pressure equal to 85 percent of the highest test pressure to which the pipe has been subjected, whether by mill test or by the post installation test.

(6) The pressure determined by the operator to be the maximum safe pressure after considering the history of the segment, particularly known corrosion and the actual operating pressure.

(b) No person may operate a segment to which paragraph (a) (6) of this section is applicable, unless over-pressure protective devices are installed on the segment in a manner that will prevent the maximum allowable operating pressure from being exceeded, in accordance with § 192.195.

(c) Notwithstanding the other requirements of this section, an operator may operate a segment of pipeline found to be in satisfactory condition, considering its operating and maintenance history, at the highest actual operating pressure to which the segment was subjected during the 5 years preceding July 1, 1970, subject to the requirements of § 192.611.

§ 192.621 Maximum allowable operating pressure: high-pressure distribution systems.

(a) No person may operate a segment of a high pressure distribution system at a pressure that exceeds the lowest of the following pressures, as applicable:

(1) The design pressure of the weakest element in the segment, determined in accordance with Subparts C and D of this part.

(2) 60 p.s.i.g., for a segment of a distribution system otherwise designed to operate at over 60 p.s.i.g., unless the service lines in the segment are equipped with service regulators or other pressure limiting devices in series that meet the requirements of § 192.197 (c).

(3) 25 p.s.i.g. in segments of cast iron pipe in which there are unreinforced bell and spigot joints.

(4) The pressure limits to which a joint could be subjected without the possibility of its parting.

(5) The pressure determined by the operator to be the maximum safe pressure after considering the history of the segment, particularly known corrosion and the actual operating pressures.

(b) No person may operate a segment of pipeline to which paragraph (a) (5) of this section applies, unless overpressure protective devices are installed on the segment in a manner that will prevent the maximum allowable operating pressure from being exceeded, in accordance with § 192.195.

§ 192.623 Maximum and minimum allowable operating pressure: low-pressure distribution systems.

(a) No person may operate a low-pressure distribution system at a pressure high enough to make unsafe the operation of any connected and properly adjusted low-pressure gas burning equipment.

(b) No person may operate a low pressure distribution system at a pressure lower than the minimum pressure at which the safe and continuing operation of any connected and properly adjusted low-pressure gas burning equipment can be assured.

§ 192.625 Odorization of gas.

(a) Combustible gases in mains and service lines must be odorized as provided in this section.

(b) The intensity of the odor of combustible gases must be such as to be readily detectable at concentrations of one fifth of the lower explosive limit.

(c) In the concentrations in which it is used, the odorant in combustible gases must comply with the following:

(1) The odorant may not be deleterious to persons, materials, or pipe.

(2) The products of combustion from the odorant may not be toxic when breathed nor may they be corrosive or harmful to those materials to which the products of combustion will be exposed.

(d) The odorant may not be soluble in water to an extent greater than 2.5 parts to 100 parts by weight.

(e) Equipment for odorization must introduce the odorant without wide variations in the level of odorant.

(f) Each operator shall conduct periodic sampling of combustible gases to assure the proper concentration of odorant in accordance with this section.

§ 192.627 Tapping pipelines under pressure.

Each tap made on a pipeline under pressure must be performed by a crew qualified to make hot taps.

§ 192.629 Purging of pipelines.

(a) When a pipeline is being purged of air by use of gas, the gas must be released into one end of the line in a moderately rapid

and continuous flow. If gas cannot be supplied in sufficient quantity to prevent the formation of a hazardous mixture of gas and air, a slug of inert gas must be released into the line before the gas.

(b) When a pipeline is being purged of gas by use of air, the air must be released into one end of the line in a moderately rapid and continuous flow. If air cannot be supplied in sufficient quantity to prevent the formation of a hazardous mixture of gas and air, a slug of inert gas must be released into the line before the air.

Subpart M—Maintenance

§ 192.701 Scope.

This subpart prescribes minimum requirements for maintenance of pipeline facilities.

§ 192.703 General.

(a) No person may operate a segment of pipeline, unless it is maintained in accordance with this subpart.

(b) Each segment of pipeline that becomes unsafe must be replaced, repaired, or removed from service.

(c) Hazardous leaks must be repaired promptly.

§ 192.705 Transmission lines: patrolling.

(a) Each operator shall have a patrol program to observe, at intervals not exceeding 1 year, surface conditions on and adjacent to the transmission line right-of-way for indications of leaks, construction activity, and other factors affecting safety and operation.

(b) The frequency of the patrol must be determined by the size of the line, the operating pressures, the class location, terrain, weather, and other relevant factors.

(c) Highway and railroad crossings must be patrolled more often and in greater detail than transmission lines in open country.

§ 192.707 Transmission lines: markers.

Each operator shall install signs or markers wherever necessary to identify the location of a transmission line in order to reduce the possibility of damage or interference.

§ 192.709 Transmission lines: record-keeping.

Each operator shall keep records covering each leak discovered, repair made, transmission line break, leakage survey, line patrol, and inspection, for as long as the segment of transmission line involved remains in service.

§ 192.711 Transmission lines: general requirements for repair procedures.

(a) Each operator shall take immediate temporary measures to protect the public whenever—

(1) A leak, imperfection, or damage that impairs its serviceability is found in a segment of steel transmission line operating at or above 40 percent of the SMYS; and

(2) It is not feasible to make a permanent repair at the time of discovery.

As soon as feasible, the operator shall make permanent repairs.

(b) Except as provided in § 192.717(c), no operator may use a welded patch as a means of repair.

§ 192.713 Transmission lines: permanent field repair of imperfections and damage.

Each imperfection or damage that impairs the serviceability of a segment of steel transmission line operating at or above 40 percent of SMYS must be repaired as follows:

(a) If it is feasible to take the segment out of service, the imperfection or damage must be removed by cutting out a cylindrical piece of pipe and replacing it with pipe of similar or greater design strength.

(b) If it is not feasible to take the segment out of service, a full encirclement welded split sleeve of appropriate design must be applied over the imperfection or damage.

(c) If the segment is not taken out of service, the operating pressure must be reduced to a safe level during the repair operations.

§ 192.715 Transmission lines: permanent field repair of welds.

Each weld that is unacceptable under § 192.241(c) must be repaired as follows:

(a) If it is feasible to take the segment of transmission line out of service, the weld must be repaired in accordance with the applicable requirements of § 192.245.

(b) A weld may be repaired in accordance with § 192.245 while the segment of transmission line is in service if—

(1) The weld is not leaking;

(2) The pressure in the segment is reduced so that it does not produce a stress that is more than 20 percent of the SMYS of the pipe; and

(3) Grinding of the defective area can be limited so that at least 1/8-inch thickness in the pipe weld remains.

(c) A defective weld which cannot be repaired in accordance with paragraph (a) or (b) of this section must be repaired by installing a full encirclement welded split sleeve of appropriate design.

§ 192.717 Transmission lines: permanent field repair of leaks.

Each permanent field repair of a leak must be made as follows:

(a) If feasible, the segment of transmission line must be taken out of service and repaired by cutting out a cylindrical piece of pipe and replacing it with pipe of similar or greater design strength.

(b) If it is not feasible to take the segment of transmission line out of service, it must be repaired by installing a full encirclement welded split sleeve of appropriate design.

(c) If the leak is due to a corrosion pit, the repair may be made by installing a properly designed bolt-on leak clamp; or, if the leak is due to a corrosion pit and on pipe of not more than 40,000 p.s.i.

SMYS, the repair may be made by fillet welding over the pitted area a steel plate patch with rounded corners, of the same or greater thickness than the pipe, and not more than one-half the diameter of the pipe in size.

§ 192.719 Transmission lines: testing of repairs.

(a) *Testing of replacement pipe.* (1) If a segment of transmission line is repaired by cutting out the damaged portion of the pipe as a cylinder, the replacement pipe must be tested to the pressure required for a new line installed in the same location.

(2) The test required by subparagraph (1) of this paragraph may be made on the pipe before it is installed, but all field girth butt welds that are not strength tested must be tested after installation by nondestructive tests meeting the requirements of § 192.243.

(b) *Testing of repairs made by welding.* Each repair made by welding in accordance with §§ 192.713, 192.715, and 192.717 must be examined in accordance with § 192.241.

§ 192.721 Distribution systems: patrolling.

(a) The frequency of patrolling mains must be determined by the severity of the conditions which could cause failure or leakage, and the consequent hazards to public safety.

(b) Mains in places or on structures where anticipated physical movement or external loading could cause failure or leakage must be patrolled at intervals not exceeding 3 months.

§ 192.723 Distribution systems: leakage surveys and procedures.

(a) Each operator of a distribution system shall provide for periodic leakage surveys in its operating and maintenance plan.

(b) The type and scope of the leakage control program must be determined by the nature of the operations and the local conditions, but it must meet the following minimum requirements:

(1) A gas detector survey must be conducted in business districts, including tests of the atmosphere in gas, electric, telephone, sewer and water system manholes, at cracks in pavement and sidewalks, and at other locations providing an opportunity for finding gas leaks, at intervals not exceeding 1 year.

(2) Leakage surveys of the distribution system outside of the principal business areas must be made as frequently as necessary, but at intervals not exceeding 5 years.

§ 192.725 Test requirements for reinstating service lines.

(a) Except as provided in paragraph (b) of this section, each disconnected service line must be tested in the same manner as a new service line, before being reinstated.

(b) Each service line temporarily disconnected from the main must be tested from the point of disconnection to the service line valve in the same manner as a new service line, before reconnecting. However, if provisions are made to maintain continuous service, such as by installation of a bypass, any part of the original service line used to maintain continuous service need not be tested.

§ 192.727 Abandonment or inactivation of facilities.

Each operator shall provide for abandonment or inactivation of facilities in its operating and maintenance plan, including the following provisions:

(a) Each facility abandoned in place, or, except when undergoing maintenance, each line not subject to gas pressure, must be disconnected from all sources and supplies of gas, purged of gas, and the ends sealed; however, the line need not be purged when the volume of gas is so small that there is no potential hazard.

(b) If air is used for purging, the operator shall ensure that a combustible mixture is not present after purging.

(c) Each abandoned vault must be filled with a suitable compacted material.

§ 192.729 Compressor stations: procedures for gas compressor units.

Each operator shall establish starting, operating, and shutdown procedures for gas compressor units.

§ 192.731 Compressor stations: inspection and testing of relief devices.

(a) Except for rupture discs, each pressure relieving device in a compressor station must be inspected and tested in accordance with § 192.739 and 192.743, and must be operated periodically to determine that it opens at the correct set pressure.

(b) Any defective or inadequate equipment found must be promptly repaired or replaced.

(c) Each remote control shutdown device must be inspected and tested, at intervals not to exceed 1 year, to determine that it functions properly.

§ 192.733 Compressor stations: isolation of equipment for maintenance or alterations.

Each operator shall establish procedures for maintaining compressor stations, including provisions for isolating units or sections of pipe for purging before returning to service.

§ 192.735 Compressor stations: storage of combustible materials.

(a) Flammable or combustible materials in quantities beyond those required for everyday use, or other than those normally used in compressor buildings, must be stored a safe distance from the compressor building.

(b) Aboveground oil or gasoline storage tanks must be protected in accordance with National Fire Protection Association Standard No. 30.

§ 192.737 Pipe-type and bottle-type holders: plan for inspection and testing.

Each operator having a pipe-type or bottle-type holder shall establish a plan for the systematic, routine inspection and testing of these facilities, including the following:

(a) Provision must be made for detecting external corrosion before the strength of the container has been impaired.

(b) Periodic sampling and testing of gas in storage must be made to determine the dew point of vapors contained in the stored gas, that if condensed, might cause internal corrosion or interfere with the safe operation of the storage plant.

(c) The pressure control and pressure limiting equipment must be inspected and tested periodically to determine that it is in a safe operating condition and has adequate capacity.

§ 192.739 Pressure limiting and regulating stations: inspection and testing.

Each pressure limiting station, relief device (except rupture discs), and pressure regulating station and its equipment must be subjected, at intervals not exceeding 1 year, to inspections and tests to determine that it is—

- (a) In good mechanical condition;
- (b) Adequate from the standpoint of capacity and reliability of operation for the service in which it is employed;
- (c) Set to function at the correct pressure; and
- (d) Properly installed and protected from dirt, liquids, or other conditions that might prevent proper operation.

§ 192.741 Pressure limiting and regulating stations: telemetering or recording gages.

(a) Each distribution system supplied by more than one district pressure regulating station must be equipped with telemetering or recording pressure gages to indicate the gas pressure in the district.

(b) On distribution systems supplied by a single district pressure regulating station, the operator shall determine the necessity of installing telemetering or recording gages in the district, taking into consideration the number of customers supplied, the operating pressures, the capacity of the installation, and other operating conditions.

(c) If there are indications of abnormally high- or low-pressure, the regulator and the auxiliary equipment must be inspected and the necessary measures employed to correct any unsatisfactory operating conditions.

§ 192.743 Pressure limiting and regulating stations: testing of relief devices.

(a) If feasible, pressure relief devices (except rupture discs) must be tested in place, at intervals not exceeding 1 year, to determine that they have enough capacity to limit the pressure on the facilities to which they are connected to the desired maximum pressure.

(b) If a test is not feasible, review and calculation of the required capacity of the relieving device at each station must be made, at intervals not exceeding one year, and these required capacities compared with the rated or experimentally determined relieving capacity of the device for the operating conditions under which it works.

(c) If the relieving device is of insufficient capacity, a new or additional device must be installed to provide the additional capacity required.

§ 192.745 Valve maintenance: transmission lines.

Each transmission line valve that might be required during any emergency must be inspected and partially operated, at intervals not exceeding 1 year.

§ 192.747 Valve maintenance: distribution systems.

Each valve, the use of which may be necessary for the safe operation of a distribution system, must be checked and serviced, at intervals not exceeding 1 year.

§ 192.749 Vault maintenance.

(a) Each vault housing pressure regulating and pressure limiting equipment, and having a volumetric internal content of 200 cubic feet or more, must be inspected, at intervals not exceeding 1 year, to determine that it is in good physical condition and adequately ventilated.

(b) If gas is found in the vault, the equipment in the vault must be inspected for leaks, and any leaks found must be repaired.

(c) The ventilating equipment must also be inspected to determine that it is functioning properly.

(d) Each vault cover must be inspected to assure that it does not present a hazard to public safety.

§ 192.751 Prevention of accidental ignition.

Each operator shall take steps to minimize the danger of accidental ignition of gas in any structure or area where the presence of gas constitutes a hazard of fire or explosion, including the following:

(a) When a hazardous amount of gas is being vented into open air, each potential source of ignition must be removed from the area and a fire extinguisher must be provided.

(b) Gas or electric welding or cutting may not be performed on pipe or on pipe components that contain a combustible mixture of gas and air in the area of work.

(c) Post warning signs, where appropriate.

§ 192.753 Caulked bell and spigot joints.

(a) Each cast iron caulked bell and spigot joint that is subject to pressures of 25 p.s.i.g. or more must be sealed with mechanical leak clamps.

(b) Each cast iron caulked bell and spigot joint that is subject to pressures of less than 25 p.s.i.g. and is exposed for any reason, must be sealed by a means other than caulking.

APPENDIX A—INCORPORATED BY REFERENCE

I. List of organizations and addresses.

A. American National Standards Institute (ANSI), 1430 Broadway, New York, N. Y. 10018 (formerly the United States of American Standards Institute (USASI)). All current standards issued by USASI and ASA have been redesigned as American National Standards and continued in effect.

B. American Petroleum Institute (API), 1271 Avenue of the Americas, New York, N. Y. 10020 or 300 Corrigan Tower Building, Dallas, Tex. 75201.

C. The American Society of Mechanical Engineers (ASME) United Engineering Center, 345 East 47th Street, New York, N. Y. 10017.

D. American Society for Testing and Materials (ASTM), 1916 Race Street, Philadelphia, Pa. 19103.

E. Manufacturers Standardization Society of the Valve and Fittings Industry (MSS), 1815 North Fort Myer Drive, Room 913, Arlington, Va. 22209.

F. National Fire Protection Association (NFPA), 60 Batterymarch Street, Boston, Mass. 02110.

II. Documents incorporated by reference.

A. American Petroleum Institute:

1. API Standard 5L "API Specification for Line Pipe" (1970 edition).
2. API Standard 5LS "API Specification for Spiral-Weld Line Pipe" (1970 edition).
3. API Standard 5LX "API Specification for High-Test Line Pipe" (1970 edition).
4. API Recommended Practice 5LI entitled "API Recommended Practice for Railroad Transportation of Line Pipe" (1967 edition).
5. API Standard 5A "API Specification for Casing, Tubing, and Drill Pipe" (1968 edition).
6. API Standard 6D "Specification for Pipeline Valves" (1968 edition).
7. API Standard 1104 "Standard for Welding Pipe Line and Related Facilities" (1968 edition).

B. The American Society for Testing and Materials:

1. ASTM Specification A53 "Standard Specification for Welded and Seamless Steel Pipe" (A53-68).
2. ASTM Specification A72 "Standard Specification for Welded Wrought-Iron Pipe" (A72-68).
3. ASTM Specification A106 "Standard Specification for Seamless Carbon Steel Pipe for High-Temperature Service" (A106-68).
4. ASTM Specification A134 "Standard Specification for Electric-Fusion (ARC)-Welded Steel Plate Pipe, Sizes 16 in. and Over" (A134-68).
5. ASTM Specification A135 "Standard Specification for Electric-Resistance-Welded Steel Pipe" (A135-68).
6. ASTM Specification A139 "Standard Specification for Electric-Fusion (ARC)-Welded Steel Pipe (Sizes 4 in. and over)" (A139-68).
7. ASTM Specification A155 "Standard Specification for Electric-Fusion-Welded Steel Pipe for High-Pressure Service" (A155-68).
- 7a. ASTM Specification 211 "Standard Specification for Spiral Welded Steel or Iron Pipe" (A211-68).
8. ASTM Specification A333 "Standard Specification for Seamless and Welded Steel Pipe for Low-Temperature Service" (A333-67).
9. ASTM Specification A377 "Standard Specification for Cast Iron and Ductile Iron Pressure Pipe" (A377-66).
10. ASTM Specification A381 "Standard Specification for Metal-Arc-Welded Steel Pipe for High-Pressure Transmission Service" (A381-68).
- 10a. ASTM Specification A539 "Standard Specification for Electric-Resistance Welded Coiled Steel Tubing for Gas and Fuel Oil Lines" (A539-65).
11. ASTM Specification B42 "Standard Specification for Seamless Copper Pipe, Standard Sizes" (B42-66).
12. ASTM Specification B68 "Standard Specification for Seamless Copper Tube, Bright Annealed" (B68-68).
13. ASTM Specification B75 "Standard Specification for Seamless Copper Tube" (75-68).
14. ASTM Specification B88 "Standard Specification for Seamless Copper Water Tube" (B88-66).
15. ASTM Specification B251 "Standard Specification for General Requirements for Wrought Seamless Copper and Copper-Alloy Tube" (B251-68).
16. ASTM Specification D2513 "Standard Specification for Thermoplastic Gas Pressure Pipe, Tubing, and Fittings" (D2513-68).
17. ASTM Specification D2517 "Standard Specification for Reinforced Thermosetting Plastic Gas Pressure Piping and Fittings" (D2517-67).
18. ASTM Specification A372 "Standard Specification for Carbon and Alloy Steel Forgings for Pressure Vessel Shells" (A372-67).

C. The American National Standards Institute, Inc.:

1. ANSI A21.1 "Thickness Design of Cast-Iron Pipe" (A21.1-1967).
2. ANSI A21.3 "Specifications for Cast Iron Pit Cast Pipe for Gas" (A21.3-1953).
3. ANSI A21.7 "Cast-Iron Pipe Centrifugally Cast in Metal Molds for Gas" (A21.7-1962).
4. ANSI A21.9 is titled "Cast-Iron Pipe Centrifugally Cast in Sand-Lined Molds for Gas" (A21.9-1962).
5. ANSI A21.11 "Rubber Gasket Joints for Cast-Iron Pressure Pipe and Fittings" (A21.11-1964).
6. ANSI 21.50 "Thickness Design of Ductile-Iron Pipe" (A21.50-1965).
- 6a. ANSI A21.52 "Ductile-Iron Pipe, Centrifugally Cast, in Metal Molds or Sand-Lined Molds for Gas" (A21.52-1965).

7. ANSI B16.1 "Cast Iron Pipe Flanges and Flanged Fittings" (B16.1-1967).
8. ANSI B16.5 "Steel Pipe Flanges and Flanged Fittings" (B16.5-1968).
9. ANSI B16.24 "Bronze Flanges and Flanged Fittings" (B16.24-1962).
10. ANSI B36.10 "Wrought-Steel and Wrought-Iron Pipe" (B36.10-1959).
11. ANSI C1 "National Electrical Code, 1968" (C1-1968).

D. The American Society of Mechanical Engineers:

1. ASME Boiler and Pressure Vessel Code, section VIII is titled "Pressure Vessels, Division 1" (1968 edition).
2. ASME Boiler and Pressure Vessel Code, section IX is titled "Welding Qualifications" (1968 edition).

E. Manufacturer's Standardization Society of the Valve and Fittings Industry:

1. MSS SP-25 "Standard Marking System for Valves, Fittings, Flanges, and Union" (1964 edition).
2. MSS SP-44 "Steel Pipe Line Flanges" (1955 edition).
3. MSS SP-52 "Cast Iron Pipe Line Valves" (1957 edition).

F. National Fire Protection Association:

1. NFPA Standard 30 "Flammable and Combustible Liquids Code" (1969 edition).
2. NFPA Standard 58 "Storage and Handling, Liquefied Petroleum Gases" (1969 edition).
3. NFPA Standard 59 "LP Gases at Utility Gas Plants" (1968 edition).

APPENDIX B—QUALIFICATION OF PIPE

I. *Listed Pipe Specifications.*

- API 5 L—Steel and iron pipe (1970).
 API 5 LS—Steel pipe (1970).
 API 5 LX—Steel pipe (1970).
 ASTM A 53—Steel pipe (1968).
 ASTM A 106—Steel pipe (1968).
 ASTM A 134—Steel pipe (1968).
 ASTM A 135—Steel pipe (1968).
 ASTM A 139—Steel pipe (1968).
 ASTM A 155—Steel pipe (1968).
 ASTM A 211—Steel and iron pipe (1968).
 ASTM A 333—Steel pipe (1967).
 ASTM A 377—Cast iron pipe (1966).
 ASTM A 381—Steel pipe (1968).
 ASTM A 539—Steel tubing (1965).
 ANSI A 21.3—Cast iron pipe (1953).
 ANSI A 21.7—Cast iron pipe (1962).
 ANSI A 21.9—Cast iron pipe (1962).
 ANSI A 21.52—Ductile iron pipe (1965).
 ASTM A 72—Wrought iron pipe (1968).
 ASTM B 42—Copper pipe (1966).
 ASTM B 68—Copper tubing (1963).
 ASTM B 75—Copper tubing (1968).
 ASTM B 88—Copper tubing (1966).
 ASTM B 251—Copper pipe and tubing (1968).
 ASTM D 2513—Thermoplastic pipe and tubing (1968).
 ASTM D 2517—Thermosetting plastic pipe and tubing (1967).

II. *Steel pipe of unknown or unlisted specification.*

A. *Bending Properties.* For pipe 2 inches or less in diameter, a length of pipe must be cold bent through at least 90 degrees around a cylindrical mandrel that has a diameter 12 times the diameter of the pipe, without developing cracks at any portion and without opening the longitudinal weld. For pipe more than 2 inches in diameter, the pipe must meet the requirements of the flattening test set forth in ASTM A53, except that the number of tests must be at least equal to the minimum required in paragraph II-D of this appendix to determine yield strength.

B. *Weldability.* A girth weld must be made in the pipe by a welder who is qualified under Subpart E of this part. The weld must be made under the most severe conditions under which welding will be allowed in the field and by means of the same procedure that will be used in the field. On pipe more than 4 inches in diameter, at least one test weld must be made for each 100 lengths of pipe. On pipe 4 inches or less in diameter, at least one test weld must be made for each 400 lengths of pipe. The weld must be tested in accordance with API Standard 1104. If the requirements of API Standard 1104 cannot be met, weldability may be established by making chemical tests for carbon and manganese, and proceeding in accordance with section IX of the ASME Boiler and Pressure Vessel Code. The same number of chemical tests must be made as are required for testing a girth weld.

C. *Inspection.* The pipe must be clean enough to permit adequate inspection. It must be visually inspected to ensure that it is reasonably round

and straight and there are no defects which might impair the strength or tightness of the pipe.

D. *Tensile Properties.* If the tensile properties of the pipe are not known, the minimum yield strength may be taken as 24,000 p.s.i.g. or less, or the tensile properties may be established by performing tensile tests as set forth in API Standard 5LX. All test specimens shall be selected at random and the following number of tests must be performed:

NUMBER OF TENSILE TESTS—ALL SIZES

10 lengths or less ---	1 set of tests for each length.
11 to 100 lengths ----	1 set of tests for each 5 lengths, but not less than 10 tests.
Over 100 lengths ----	1 set of tests for each 10 lengths, but not less than 20 tests.

If the yield-tensile ratio, based on the properties determined by those tests, exceeds 0.85, the pipe may be used only as provided in § 192.55(c).

APPENDIX C—QUALIFICATION FOR WELDERS OF LOW STRESS LEVEL PIPE

I. *Basic test.* The test is made on pipe 12 inches or less in diameter. The test weld must be made with the pipe in a horizontal fixed position so that the test weld includes at least one section of overhead position welding. The beveling, root opening, and other details must conform to the specifications of the procedure under which the welder is being qualified. Upon completion, the test weld is cut into four coupons and subjected to a root bend test. If, as a result of this test, two or more of the four coupons develop a crack in the weld material, or between the weld material and base metal, that is more than $\frac{1}{8}$ -inch long in any direction, the weld is unacceptable. Cracks that occur on the corner of the specimen during testing are not considered.

II. *Additional tests for welders of service line connections to mains.* A service line connection fitting is welded to a pipe section with the same diameter as a typical main. The weld is made in the same position as it is made in the field. The weld is unacceptable if it shows a serious undercutting or if it has rolled edges. The weld is tested by attempting to break the fitting off the run pipe. The weld is unacceptable if it breaks and shows incomplete fusion, overlap, or poor penetration at the junction of the fittings and run pipe.

III. *Periodic tests for welders of small service lines.* Two samples of the welder's work, each about 8 inches long with the weld located approximately in the center, are cut from steel service line and tested as follows:

(1) One sample is centered in a guided bend testing machine and bent to the contour of the die for a distance of 2 inches on each side of the weld. If the sample shows any breaks or cracks after removal from the bending machine, it is unacceptable.

(2) The ends of the second sample are flattened and the entire joint subjected to a tensile strength test. If failure occurs adjacent to or in the weld metal, the weld is unacceptable. If a tensile strength testing machine is not available, this sample must also pass the bending test prescribed in subparagraph (1) of this paragraph.

[F.R. Doc. 70-10673; Filed, Aug. 18, 1970; 8:45 a.m.]

Note: Copies of the publications referred to are available for inspection at the office of the public service commission, the secretary of state and the revisor of statutes or may be procured for personal use from the addresses listed in 192.753.

History: Cr. Register, December, 1970, No. 180, eff. 1-1-71.