

Wisconsin Department of Safety and Professional Services
Division of Industry Services
4822 Madison Yards Way
PO Box 7302
Madison WI 53707-7302



Phone: 608-266-2112
Web: <http://dsps.wi.gov>
Email: dsps@wisconsin.gov

Tony Evers, Governor
Dan Hereth, Secretary

December 22, 2022

Wisconsin State Senate
Chief Clerk
PO Box 7882
Madison, WI 53707-7882

Wisconsin State Assembly
Chief Clerk
PO Box 8952
Madison WI 53708-8952

Dear Chief Clerks:

As specified in Wis. Stat. §145.20(3)(a)2, I am submitting the 2022 Private On-Site Wastewater Treatment System Program Exempt Governmental Units Report. Questions regarding the report can be directed to Assistant Deputy Secretary Jennifer Garrett at (608) 266-6795.

Sincerely,

Dan Hereth
Secretary-designee

**2022
ANNUAL REPORT**

**PRIVATE ON-SITE WASTEWATER TREATMENT
SYSTEM PROGRAM
EXEMPT GOVERNMENTAL UNITS REPORT**



December 2022

TABLE OF CONTENTS

AuthorityPage 3

Designated (or Exempted) AgentsPage 4

AuditPage 10

Authority

This report is submitted in accordance with Section 145.20(3)(a)2, Wisconsin Statute which states:

The department may exempt a governmental unit from any category of private on-site wastewater treatment systems for which departmental approval is required prior to sanitary permit issuance under subd. 1., upon a determination, in accordance with rules promulgated by the department, that past performance of the governmental unit on reviews and audits under par. (b) has been satisfactory and that the governmental unit has the capacity to give the same level of application and plan review as that provided by the department. The department may revoke an exemption upon a finding that performance of the governmental unit on a review or audit conducted after the granting of the exemption is unsatisfactory or that the governmental unit is not giving the same level of application and plan review as that provided by the department. Findings in a revocation action may be made only after a public hearing upon 30 days' advance notice to the clerk of the governmental unit. The department shall submit a report under s.13.172 (2) to the chief clerk of each house of the legislature, at the beginning of each legislative session, describing the exemptions under this subdivision.

The department specifies categories of private on-site wastewater treatment systems (POWTS) for which department or designated agent approval is required prior to sanitary permit issuance under Section SPS Table 383.22-2, Wisconsin Administrative Code:

**Table 383.22-2
Plan Submissions to Department or Designated Agent**

| Type of Installation |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1. POWTS that will completely utilize treatment and dispersal technologies or methods either approved under s. SPS 384.10 (2) or (3) or recognized under s. SPS 383.60 (1). |
| 2. POWTS that collect and hold all wastewater of the facilities served and utilize holding components designed based on $\geq 3,000$ gpd [<i>gallons per day</i>] estimated flow either recognized under s. SPS 384.10(2) or (3) or recognized under s. SPS 383.60 (1). |

Note: Pursuant to s. 145.19(2), Stats, governmental units may require separate plan examination fees or include these fees in the cost of the sanitary permit.

Designated (or Exempted) Agents

The department has approved the delegation of plan review authority to 36 Designated Agents for POWTS. Designated Agents of the department and their specific level of delegation are current as of December 2022.

| County | Category of Review |
|---------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Adams | <ul style="list-style-type: none"> • Plan review for at-grade systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for non-pressurized in-ground systems that receive a design wastewater flow of 3,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 1,000 gpd or less. |
| Ashland | <ul style="list-style-type: none"> • Plan review for replacement septic and pump tanks for facilities with a design wastewater flow of 5,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 5,000 gpd or less for one and two-family dwellings. • Plan review for at-grade systems that receive a design wastewater flow of 5,000 gpd or less for one and two-family dwellings. |
| Brown | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 1,000 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for at-grade systems that receive a design wastewater flow of 1,000 gpd or less. |
| Calumet | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 1,000 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for at-grade systems that receive a design wastewater flow of 1,000 gpd or less. |
| Chippewa | <ul style="list-style-type: none"> • Plan review for pre-cast or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 5,000 gpd or less. |

| County | Category of Review |
|---------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Clark | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 1,000 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for at-grade systems that receive a design wastewater flow of 1,000 gpd or less. |
| Dane | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 5,000 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 5,000 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 5,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 5,000 gpd or less. • Plan review for at-grade systems that receive a design wastewater flow of 5,000 gpd or less. |
| Door | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 900 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 900 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 900 gpd or less. • Plan review for at-grade systems that receive a design wastewater flow of 900 gpd or less. |
| Eau Claire | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 5,000 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for at-grade systems that receive a design wastewater flow of 1,000 gpd or less. |
| Fond du Lac | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 3,000 gpd or less. |

| County | Category of Review |
|---------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Grant | <ul style="list-style-type: none"> • Plan review for at-grade systems that receive a design wastewater flow up to 1,000 gallons per day. • Plan review for non-pressurized in-ground systems that receive a design wastewater flow up to 1,000 gallons per day. |
| Juneau | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for at-grade systems that receive a design wastewater flow of 1,000 gpd or less. |
| Langlade | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. |
| Lincoln | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 2,500 gpd or less. |
| Manitowoc | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 5,000 gpd or less. • Pressurized in-ground systems that receive a design wastewater flow of 5,000 gpd or less. • Mound systems that receive a design wastewater flow of 5,000 gpd or less. • At-grade systems that receive a design wastewater flow of 5,000 gpd or less. |
| Marathon | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 3,000 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 5,000 gpd or less for one and two-family dwellings. • Plan review for mound systems that receive a design wastewater flow of 5,000 gpd or less for one and two-family dwellings. • Plan review for at-grade systems that receive a design wastewater flow of 5,000 gpd or less for one and two-family dwellings. |
| Marinette | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 3,000 gpd or less. |

| County | Category of Review |
|---------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Marquette | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 3,000 gpd or less. • Plan review for at-grade systems with a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems with a design wastewater flow of 1,000 gpd or less. |
| Monroe | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 3,000 gpd or less. • Plan review for at-grade systems with a design wastewater flow of 1,000 gpd or less. • Plan review for in-ground pressure systems with a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems with a design wastewater flow of 1,000 gpd or less. |
| Oconto | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 3,000 gpd or less. |
| Oneida | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 5,000 gpd or less. |
| Outagamie | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 3,000 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 3,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 3,000 gpd or less. • Plan review for at-grade systems that receive a design wastewater flow of 3,000 gpd or less. |
| Ozaukee | <ul style="list-style-type: none"> • Plan review for pre-cast or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 1,000 gpd or less. • Plan review for pressurized in-ground systems with a design wastewater flow of 1,000 gpd or less. • Plan review for at-grade systems with a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems with a design wastewater flow of 1,000 gpd or less. |

| County | Category of Review |
|---------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Polk | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 1,000 gpd or less. • Plan review for pressurized in-ground systems with a design wastewater flow of 1,000 gpd or less. • Plan review for at-grade systems with a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems with a design wastewater flow of 1,000 gpd or less. • Plan review for replacement septic and pump tanks with a design wastewater flow of 3,000 gpd or less. • Plan review for pre-cast or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 3,000 gpd or less. |
| Rusk | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 5,000 gpd or less. |
| Sauk | <ul style="list-style-type: none"> • Plan review for at-grade systems with a design wastewater flow of 1,000 gpd or less. |
| Sheboygan | <ul style="list-style-type: none"> • Plan review for replacement septic and pump tanks for facilities with a design wastewater flow of 5,000 gpd or less. |
| Shawano | <ul style="list-style-type: none"> • Plan review for mound systems that receive a design wastewater flow of 5,000 gpd or less for one and two-family dwellings. • Plan review for at-grade systems that receive a design wastewater flow of 5,000 gpd or less for one and two-family dwellings. |
| Trempealeau | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. |
| Vilas | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 3,000 gallons per day or less. • Plan review for replacement septic and pump tanks with a design wastewater flow of 3,000 gpd or less. • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 3,000 gpd or less. |
| Washington | <ul style="list-style-type: none"> • Plan review for at-grade systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for in-ground pressure distribution systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 1,000 gpd or less. |

| County | Category of Review |
|---------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Waukesha | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 5,000 gpd or less. • Pressurized in-ground systems that receive a design wastewater flow of 5,000 gpd or less. • Mound systems that receive a design wastewater flow of 5,000 gpd or less. • At-grade systems that receive a design wastewater flow of 5,000 gpd or less. |
| Waupaca | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. |
| Waushara | <ul style="list-style-type: none"> • Plan review for pre-cast, or manufactured holding tanks for public or commercial facilities with an estimated wastewater flow of 4,500 gpd or less. • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 4,500 gpd or less. • Mound systems that receive a design wastewater flow of 3,000 gpd or less. |
| Winnebago | <ul style="list-style-type: none"> • Plan review for at-grade systems that receive a design wastewater flow of 1,000 gpd or less for one and two-family dwellings. • Plan review for non-pressurized in-ground systems that receive a design wastewater flow of 1,000 gpd or less for one and two-family dwellings. • Plan review for mound systems that receive a design wastewater flow of 1,000 gpd or less for one and two-family dwellings. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 1,000 gpd or less for one and two-family dwellings. |
| Wood | <ul style="list-style-type: none"> • Plan review for non-pressurized in-ground systems for public or commercial facilities with a design wastewater flow of 1,000 gpd or less. • Plan review for pressurized in-ground systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for mound systems that receive a design wastewater flow of 1,000 gpd or less. • Plan review for at-grade systems that receive a design wastewater flow of 1,000 gpd or less. |

Audits

Throughout 2022, the department conducted audits of governmental programs in accordance with Section 145.20(3)(b), Wisconsin Statutes. These audits consisted of self-reporting electronic audits of all 71 counties, and 8 municipalities with historical sanitary permit programs in Milwaukee County. These self-reporting audits collect essential data, self-compliance, and ordinance changes through the year. During this period, the department also conducted 44 office audits which consist of a review of sanitary permit, plan review and inspection files. 33 counties received a field audit which consist of verifying that onsite features of installed systems and those under construction follow the applicable approved plans and codes.

In summary, the department concluded with the information available, that all audited delegated agent programs were satisfactory under s. 145.20(3)(b), Wisconsin Statutes, and were conducting plan reviews at the same level provided by the department. The department did not revoke or attempt to revoke any plan review exemptions under this section.